

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月21日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.80	9.51	51.27	1.40	18.82	11.30	0.99	73858.99
1	4.95	11.78	51.98	1.43	19.13	11.28	1.02	73630.50
2	5.11	13.13	49.48	2.37	15.98	11.89	1.03	69611.08
3	9.71	10.23	53.56	1.95	17.86	11.56	1.02	71751.29
4	5.60	8.67	50.20	2.13	17.38	11.48	1.01	72150.61
5	10.55	3.77	31.22	2.68	16.97	10.13	1.00	77396.68
6	7.90	8.13	37.63	3.11	14.59	11.64	1.00	67726.29
7	6.98	9.80	46.45	2.22	16.04	11.96	1.03	69212.09
8	7.38	9.02	53.39	2.44	15.37	11.91	1.01	71061.82
9	8.66	9.04	49.94	2.37	16.04	11.54	1.01	71429.05
10	7.79	8.34	52.31	1.92	15.93	11.72	1.03	69450.52
11	3.00	10.53	56.24	1.38	16.50	11.87	1.01	70870.39
12	5.43	14.63	47.23	1.74	16.05	11.81	1.02	71239.27
13	9.34	7.24	52.19	2.27	15.93	11.92	1.02	69978.35
14	11.25	6.59	49.39	2.38	15.44	11.71	1.02	71047.54
15	5.16	8.14	62.15	1.38	16.88	12.03	1.02	68154.55
16	9.57	8.89	50.82	1.91	16.64	11.56	1.00	73879.90
17	4.61	12.85	63.55	1.18	17.08	12.72	1.05	64686.26
18	3.55	8.41	48.22	0.80	18.98	11.09	1.03	75794.79
19	9.41	12.48	43.05	1.36	17.82	10.98	1.05	77301.94
20	9.58	8.82	47.13	2.40	16.85	11.54	1.04	73697.49
21	8.47	13.09	49.62	2.38	16.34	11.87	1.02	72416.86
22	10.52	6.74	52.71	2.87	16.07	11.62	1.02	73996.40
23	9.81	9.81	51.31	3.03	15.77	11.96	1.00	71602.54
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.51	9.57	50.04	2.05	16.69	11.63	1.02	71747.72
最大值	11.25	14.63	63.55	3.11	19.13	12.72	1.09	77396.68
發生時間	14	12	17	6	1	17		5
最小值	3.00	3.77	31.22	0.80	14.59	10.13	0.99	64686.26
發生時間	11	5	5	18	6	5		17
零點偏移(率)	-0.01 %	-0.03 %	-0.01 %	0.00 %		0.01		0.00 %
全幅偏移(率)	0.04 %	0.53 %	0.00 %	0.23 %		0.04		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月21日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.50	5.53	47.02	1.19	19.21	10.06	1.01	85191.22
1	9.01	5.75	60.38	1.85	19.45	9.64	1.02	87385.57
2	7.18	9.18	33.40	3.07	16.04	10.51	1.02	82185.00
3	9.49	6.47	41.94	2.88	15.96	10.52	1.00	82681.97
4	7.66	6.88	48.64	2.45	15.90	10.51	0.99	84822.10
5	7.68	4.63	58.11	2.57	15.02	10.75	0.99	84206.55
6	9.36	5.95	59.64	2.40	15.95	10.64	1.02	82230.45
7	9.89	7.42	51.65	2.59	14.79	10.81	1.04	83898.38
8	10.47	7.40	56.96	3.23	13.65	11.03	1.04	83269.06
9	7.79	4.48	54.04	2.32	15.08	11.02	1.04	81980.53
10	7.07	4.53	48.95	1.97	14.23	11.07	1.02	78987.31
11	3.20	3.43	57.33	1.59	16.12	10.92	1.02	79061.64
12	3.90	3.59	50.17	1.53	16.29	10.98	1.04	80039.32
13	3.42	5.87	53.98	1.71	15.41	11.06	1.04	80773.81
14	5.12	4.29	44.95	1.63	15.63	10.43	1.04	82482.70
15	8.49	6.83	51.28	1.60	16.30	10.59	1.04	83533.91
16	3.49	3.83	54.33	1.72	15.65	11.11	1.02	80318.60
17	0.22	11.23	66.53	3.30	12.74	13.80	1.04	59793.51
18	0.15	3.84	51.20	1.93	13.95	12.57	1.00	70786.08
19	0.11	4.97	62.85	1.08	16.38	11.65	1.02	76941.20
20	1.19	8.10	45.54	1.72	16.37	10.54	0.99	85560.28
21	4.66	5.66	45.02	2.32	16.11	10.63	0.99	85158.64
22	6.81	6.82	52.57	2.47	15.69	10.90	1.00	83143.16
23	8.28	3.84	54.08	2.43	15.74	11.09	1.00	81206.38
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.84	5.86	52.11	2.15	15.74	10.95	1.02	81068.22
最大值	10.47	11.23	66.53	3.30	19.45	13.80	1.08	87385.57
發生時間	8	17	17	17	1	17		1
最小值	0.11	3.43	33.40	1.08	12.74	9.64	0.99	59793.51
發生時間	19	11	2	19	17	1		17
零點偏移(率)	-0.04 %	-0.05 %	-0.02 %	-0.03 %		0.03		-0.20 %
全幅偏移(率)	-0.31 %	1.38 %	-0.70 %	0.10 %		-0.04		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月21日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.72	6.22	55.20	1.24	17.19	10.72	1.00	75220.43
1	5.51	9.99	63.31	1.40	18.61	9.98	1.01	81413.18
2	6.93	10.92	46.47	1.82	17.01	9.79	1.00	80502.63
3	9.39	5.85	46.14	2.83	16.41	9.63	1.00	76503.47
4	9.22	4.86	51.38	2.77	15.27	10.12	1.00	72639.64
5	7.34	10.10	38.07	3.28	16.99	9.59	0.99	73994.03
6	10.09	4.07	56.20	2.78	15.29	10.00	1.01	78021.68
7	10.85	8.11	52.27	2.61	15.05	9.85	0.99	76985.09
8	10.01	11.24	40.74	2.85	14.10	10.40	0.99	73197.79
9	2.13	8.53	41.17	2.09	13.64	10.50	1.00	73288.93
10	2.18	4.16	46.83	1.24	15.57	9.78	0.99	77895.26
11	3.97	3.05	48.60	2.02	14.14	10.59	1.03	75737.57
12	3.57	4.28	54.38	1.64	14.81	11.12	1.05	74712.51
13	3.82	5.99	50.38	2.14	13.60	11.09	1.02	75068.85
14	6.21	4.07	53.74	2.03	14.10	11.28	1.02	74749.79
15	9.74	7.61	54.11	2.21	14.35	11.08	1.01	73486.08
16	8.15	2.93	56.79	1.37	15.88	10.77	0.99	78134.25
17	7.53	5.83	59.44	1.10	16.69	10.71	0.97	82080.97
18	7.40	3.88	47.55	1.50	15.48	10.89	1.00	83400.90
19	6.99	3.68	57.81	1.35	16.53	10.84	1.02	82212.28
20	8.35	4.60	49.60	1.73	15.36	11.10	1.02	82583.45
21	9.21	3.45	56.69	1.56	15.93	11.09	1.01	82754.32
22	9.20	6.36	54.13	2.45	14.08	11.11	0.98	75986.52
23	8.16	5.40	52.20	1.98	14.80	11.07	0.97	75129.36
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.07	6.05	51.38	2.00	15.45	10.55	1.00	77320.79
最大值	10.85	11.24	63.31	3.28	18.61	11.28	1.12	83400.90
發生時間	7	8	1	5	1	14		18
最小值	2.13	2.93	38.07	1.10	13.60	9.59	0.95	72639.64
發生時間	9	16	5	17	13	5		4
零點偏移(率)	-0.02 %	-0.02 %	-0.01 %	-0.03 %		0.01		0.00 %
全幅偏移(率)	0.04 %	0.74 %	-0.74 %	0.20 %		0.40		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								