

報表日期: 114年12月01日

項目 單位	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.84	14.01	59.76	1.59	15.51	12.86	1.35	69728.06
1	2.11	9.33	22.90	2.46	17.53	10.53	1.31	73778.10
2	2.27	10.82	60.47	1.18	16.43	11.21	1.32	80553.93
3	2.47	13.14	43.20	1.14	16.71	11.09	1.31	84095.30
4	2.67	13.37	57.38	1.76	15.83	11.44	1.30	81159.38
5	2.74	14.89	40.30	1.24	16.36	11.02	1.30	82636.94
6	3.12	14.87	54.09	1.99	15.61	12.16	1.29	76567.96
7	2.85	13.90	50.36	1.86	15.51	12.19	1.31	75806.92
8	0.41	16.24	41.91	0.77	18.54	10.82	1.32	85662.69
9	1.93	10.32	53.44	1.33	15.77	11.83	1.34	78935.85
10	6.41	17.10	44.82	0.96	18.68	10.99	1.34	83826.95
11	6.33	11.78	56.66	1.10	16.56	11.01	1.33	83305.36
12	6.76	12.44	54.59	2.35	14.46	12.11	1.34	74920.49
13	6.69	12.34	40.71	1.50	16.18	11.89	1.32	77939.77
14	6.49	11.77	58.10	1.02	16.08	11.68	1.30	78666.98
15	6.81	12.45	45.00	1.33	15.83	12.21	1.30	75634.91
16	6.53	11.85	51.79	0.99	17.09	11.65	1.33	79791.68
17	6.43	11.63	48.30	1.27	16.26	11.56	1.34	80795.20
18	6.81	12.37	60.80	1.27	15.98	12.16	1.32	76381.81
19	6.41	11.83	52.69	1.06	16.44	11.61	1.32	81035.24
20	9.15	12.56	54.86	2.11	15.48	11.93	1.34	78832.22
21	12.26	12.04	45.31	3.29	15.09	11.80	1.34	80362.07
22	4.33	12.38	57.24	1.60	15.68	12.08	1.34	77035.27
23	0.90	13.39	55.82	2.08	14.63	12.82	1.34	71718.92
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.82	12.78	50.44	1.55	16.18	11.69	1.32	78715.50
最 大 值	12.26	17.10	60.80	3.29	18.68	12.86	1.36	85662.69
發生時間	21	10	18	21	10	0		8
最 小 值	0.41	9.33	22.90	0.77	14.46	10.53	1.29	69728.06
發生時間	8	1	1	8	12	1		0
零點偏移(率)	-0.09 %	-0.01 %	-0.01 %	0.01 %		0.00	-0.01	0.30 %
全幅偏移(率)	-0.01 %	0.44 %	0.08 %	0.73 %		0.01	0.10	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年12月01日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.58	13.94	31.58	3.01	17.91	8.89	1.34	76440.20
1	11.64	12.08	33.42	0.63	18.73	9.26	1.35	73848.63
2	11.32	10.60	29.79	3.90	19.67	8.51	1.34	74875.64
3	11.74	11.20	25.09	0.16	17.68	8.62	1.34	70731.11
4	12.71	12.84	32.40	0.85	17.40	8.60	1.34	72639.53
5	13.47	10.91	51.05	0.27	18.16	9.34	1.35	77002.35
6	13.78	11.05	52.61	0.20	16.71	9.57	1.36	77377.77
7	10.07	15.67	35.67	1.79	16.15	9.52	1.32	77596.86
8	11.24	11.81	42.25	3.03	16.01	9.70	1.32	72179.19
9	9.30	11.39	44.34	2.16	17.55	9.72	1.32	73085.66
10	12.98	12.23	43.72	3.65	16.11	9.93	1.35	75686.94
11	11.96	12.90	36.31	2.65	15.68	9.99	1.32	72233.59
12	10.81	12.72	40.79	2.29	16.45	9.79	1.33	75040.02
13	10.71	11.89	45.91	1.89	16.86	9.79	1.32	74782.62
14	9.83	11.92	52.64	1.04	17.52	10.22	1.31	75355.52
15	12.05	11.99	44.50	1.15	17.74	10.08	1.31	75919.59
16	12.67	12.84	31.77	0.82	17.16	9.51	1.31	77411.11
17	11.87	12.73	32.55	0.73	17.17	9.72	1.31	76461.84
18	12.49	11.34	38.99	1.40	17.06	9.68	1.31	79736.22
19	12.19	12.19	37.98	1.15	17.32	9.74	1.31	77689.13
20	12.13	12.32	42.74	1.37	15.55	10.32	1.32	75352.98
21	13.16	12.01	44.20	1.48	16.69	9.97	1.32	76853.27
22	13.07	11.85	49.08	1.16	16.90	10.25	1.32	77862.95
23	10.41	12.04	57.90	0.65	16.79	10.69	1.33	76872.02
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	11.84	12.19	40.72	1.56	17.12	9.64	1.33	75543.11
最 大 值	13.78	15.67	57.90	3.90	19.67	10.69	1.36	79736.22
發生時間	6	7	23	2	2	23		18
最 小 值	9.30	10.60	25.09	0.16	15.55	8.51	1.30	70731.11
發生時間	9	2	3	3	20	2		3
零點偏移(率)	-0.03 %	-0.08 %	-0.05 %	-0.40 %		-0.28	-0.01	0.20 %
全幅偏移(率)	0.73 %	0.04 %	0.34 %	0.22 %		-0.02	0.04	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								