

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月21日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.53	9.71	56.59	2.21	17.76	11.57	1.01	85856.01
1	0.55	7.51	56.85	1.48	19.25	11.52	1.01	86692.30
2	6.02	6.86	52.99	2.44	17.53	11.48	1.00	88012.59
3	9.74	11.44	54.72	3.12	15.89	11.67	1.00	86295.27
4	7.11	8.38	55.83	2.56	16.51	11.54	1.00	87066.18
5	7.86	10.62	50.76	1.89	17.51	11.43	0.99	89913.49
6	8.85	12.76	52.79	2.53	17.17	11.48	0.99	87391.97
7	9.16	11.79	51.99	3.32	16.39	11.60	1.00	85622.59
8	10.46	11.87	58.71	3.21	17.11	11.96	1.02	82366.31
9	9.74	8.95	51.33	2.50	17.20	11.60	0.98	87490.49
10	8.41	8.74	51.96	2.26	17.21	11.39	1.01	86283.42
11	5.68	8.96	68.75	1.41	17.94	11.83	1.02	84847.17
12	6.51	10.29	50.97	1.83	17.86	11.19	0.99	92039.75
13	8.39	11.56	66.05	2.30	16.75	11.82	0.99	87450.57
14	8.41	10.17	52.05	2.26	17.15	11.35	0.99	88126.93
15	7.82	15.15	57.83	2.83	16.94	11.60	0.99	82548.43
16	1.82	11.11	64.83	1.02	18.66	11.12	0.99	83672.52
17	1.74	10.67	60.18	1.63	17.47	11.07	0.99	85826.57
18	1.98	4.73	45.59	2.03	16.48	11.70	1.01	83433.02
19	7.59	6.13	54.76	2.30	16.87	11.48	1.01	86604.74
20	4.28	5.71	62.67	1.29	18.54	11.11	1.02	90484.81
21	3.66	6.03	53.97	2.35	16.94	11.83	1.01	86634.22
22	5.02	4.42	58.33	2.34	17.27	11.40	0.99	90808.27
23	0.69	5.95	58.12	2.89	15.93	11.94	0.98	86156.98
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.92	9.15	56.19	2.25	17.26	11.53	1.00	86734.36
最大值	10.46	15.15	68.75	3.32	19.25	11.96	1.03	92039.75
發生時間	8	15	11	7	1	8		12
最小值	0.53	4.42	45.59	1.02	15.89	11.07	0.97	82366.31
發生時間	0	22	18	16	3	17		8
零點偏移(率)	-0.40 %	-0.04 %	-0.02 %	-0.01 %		0.00		0.00 %
全幅偏移(率)	0.04 %	0.56 %	-0.01 %	0.26 %		-0.14		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月21日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.03	4.00	54.48	2.67	15.79	10.66	1.10	83280.24
1	0.28	4.52	51.40	2.48	18.06	10.44	1.11	83817.74
2	3.96	10.17	51.95	2.79	16.89	10.01	1.11	88666.34
3	9.67	8.14	59.78	2.84	16.68	10.18	1.11	87939.17
4	8.67	3.38	56.27	2.44	16.99	10.08	1.11	88654.70
5	8.81	6.29	59.70	2.32	17.67	9.93	1.11	88593.75
6	7.05	7.34	54.15	2.53	16.05	10.38	1.10	86698.85
7	10.03	5.68	63.85	2.01	18.42	9.78	1.10	89098.69
8	9.06	5.82	51.75	2.21	17.06	10.05	1.11	87896.73
9	9.11	7.55	59.70	2.89	15.51	10.85	1.10	87062.49
10	5.08	4.59	55.08	2.49	15.80	11.19	1.10	84751.22
11	0.44	5.24	58.23	1.37	17.28	11.46	1.10	80405.84
12	1.20	9.73	49.43	1.69	17.50	10.86	1.10	85180.24
13	1.25	5.32	54.33	2.01	16.27	10.92	1.11	85430.38
14	6.15	5.64	56.11	1.90	16.90	11.16	1.12	83298.73
15	0.99	5.22	65.59	1.32	17.87	10.96	1.10	83929.93
16	0.73	11.46	44.83	1.73	17.45	10.82	1.10	85159.32
17	0.86	1.67	51.55	1.51	17.47	10.80	1.10	86200.21
18	0.84	2.66	46.18	1.44	17.69	10.31	1.10	86697.99
19	0.09	2.15	50.86	1.41	18.55	10.06	1.10	86778.56
20	2.95	7.51	51.71	1.43	19.46	9.57	1.10	89555.04
21	8.94	5.81	50.50	3.08	16.18	10.26	1.10	87247.18
22	3.02	3.09	47.22	1.63	18.82	9.73	1.10	88613.98
23	1.80	3.59	48.10	1.19	18.55	9.97	1.10	87811.49
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.21	5.69	53.86	2.06	17.29	10.43	1.11	86365.37
最大值	10.03	11.46	65.59	3.08	19.46	11.46	1.12	89555.04
發生時間	7	16	15	21	20	11		20
最小值	0.03	1.67	44.83	1.19	15.51	9.57	1.09	80405.84
發生時間	0	17	16	23	9	20		11
零點偏移(率)	-0.05 %	-0.01 %	-0.03 %	-0.08 %		0.01		-0.10 %
全幅偏移(率)	0.04 %	1.73 %	0.11 %	0.81 %		-0.15		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月21日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.68	4.43	56.44	2.22	15.28	11.35	1.01	75530.21
1	5.02	8.54	53.86	2.02	16.08	11.46	0.99	74912.51
2	8.82	9.57	58.06	2.24	15.71	11.16	0.99	79229.45
3	8.84	5.85	51.53	2.37	15.56	11.01	0.99	78804.91
4	9.20	5.49	51.14	2.18	16.59	10.55	0.99	79757.83
5	9.20	5.45	54.82	2.27	15.57	11.21	0.99	78393.45
6	11.35	11.03	43.93	2.64	16.43	10.30	0.99	80005.70
7	13.82	16.64	47.51	2.57	16.26	10.78	1.00	70077.27
8	9.84	8.59	41.20	2.07	15.65	10.86	1.00	71919.65
9	10.34	16.20	41.89	2.78	13.93	11.23	1.00	70245.86
10	8.13	7.17	56.16	1.80	16.39	10.85	0.99	74620.97
11	9.76	5.83	55.62	1.64	16.62	10.69	1.00	76317.81
12	5.65	7.22	48.91	1.43	16.03	10.80	1.04	75418.93
13	4.48	6.16	60.33	1.11	16.69	10.93	1.05	77128.91
14	8.66	10.89	47.27	2.31	14.03	11.91	1.02	76649.39
15	6.41	6.84	62.76	1.66	14.54	12.14	1.05	74530.69
16	9.25	9.05	53.84	2.02	14.35	12.07	1.05	74947.20
17	7.62	10.27	59.98	1.45	15.67	11.51	1.03	70826.27
18	9.29	8.15	47.05	1.33	15.78	10.86	0.99	75493.03
19	6.19	3.97	52.40	1.04	16.20	11.07	0.99	74220.91
20	8.06	7.91	51.61	1.77	14.52	11.26	1.00	74491.60
21	4.99	4.36	54.79	0.81	16.49	11.14	1.02	75139.28
22	4.72	11.29	53.03	1.00	16.94	10.81	1.02	76301.12
23	4.00	8.25	52.78	0.94	17.83	10.29	0.99	78410.29
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.72	8.30	52.37	1.82	15.80	11.09	1.01	75557.22
最大值	13.82	16.64	62.76	2.78	17.83	12.14	1.06	80005.70
發生時間	7	7	15	9	23	15		6
最小值	1.68	3.97	41.20	0.81	13.93	10.29	0.97	70077.27
發生時間	0	19	8	21	9	23		7
零點偏移(率)	-0.55 %	0.00 %	-0.01 %	-0.13 %		-0.13		0.00 %
全幅偏移(率)	-3.87 %	0.02 %	-0.78 %	-0.78 %		0.07		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								