

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月05日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.35	4.98	40.64	0.81	17.65	10.81	1.03	87653.20
1	10.29	4.64	42.04	1.45	17.00	11.04	1.02	86253.22
2	4.76	6.73	69.54	1.61	16.82	12.48	1.05	74295.64
3	6.94	5.75	41.11	1.42	16.48	11.73	1.04	81419.45
4	7.16	7.05	62.51	1.78	14.89	11.86	1.02	81731.91
5	7.34	6.39	46.60	1.75	16.10	11.57	0.98	80860.21
6	4.44	5.86	54.04	1.21	15.42	12.09	1.01	79424.48
7	9.71	5.00	45.76	2.27	14.83	11.74	1.02	82724.80
8	9.24	4.72	47.03	1.99	14.90	11.73	1.02	82957.95
9	5.07	6.14	43.03	1.33	14.91	11.94	1.02	80776.35
10	7.10	7.92	44.70	1.31	14.85	11.95	1.03	81024.88
11	9.11	11.40	39.21	1.15	15.82	11.31	1.01	85568.93
12	7.37	11.53	37.50	1.73	14.88	12.25	1.02	78624.15
13	5.29	7.00	43.02	1.19	15.13	12.27	1.03	78048.31
14	4.38	8.03	50.91	1.25	15.44	12.27	1.03	77473.27
15	2.57	7.92	51.99	0.92	15.33	12.29	1.03	77312.72
16	0.55	6.52	55.20	0.54	15.92	11.76	1.02	81559.75
17	4.06	7.86	50.19	1.24	15.83	11.49	1.02	83715.81
18	6.46	6.66	57.21	1.65	14.57	11.72	1.04	83172.30
19	9.17	2.61	61.89	1.40	15.07	11.39	1.04	85405.08
20	7.44	3.64	47.89	2.18	13.43	12.13	1.02	80455.02
21	9.13	6.08	60.60	1.84	14.72	12.03	1.02	80349.22
22	7.90	7.06	64.06	1.30	14.96	11.86	1.02	81488.22
23	9.51	7.28	49.43	2.06	14.70	11.81	1.02	81944.03
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.68	6.62	50.25	1.47	15.40	11.81	1.02	81426.62
最大值	10.29	11.53	69.54	2.27	17.65	12.48	1.13	87653.20
發生時間	1	12	2	7	0	2		0
最小值	0.55	2.61	37.50	0.54	13.43	10.81	0.97	74295.64
發生時間	16	19	12	16	20	0		2
零點偏移(率)	-0.01 %	-0.06 %	-0.01 %	-0.06 %		-0.04		0.10 %
全幅偏移(率)	0.00 %	2.22 %	0.52 %	1.12 %		-0.07		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月05日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.78	8.66	41.86	1.46	16.72	10.83	1.06	81590.99
1	6.26	8.27	49.79	1.84	17.53	10.99	1.05	79702.89
2	1.77	8.87	44.09	1.73	17.28	11.26	1.05	77989.65
3	2.84	8.77	45.75	1.32	17.02	11.18	1.04	79597.29
4	6.51	9.00	46.75	1.69	17.06	10.95	1.04	81100.45
5	3.65	8.04	35.02	2.26	16.25	10.94	1.04	81586.93
6	0.11	6.10	59.95	1.67	15.63	11.58	1.02	76764.78
7	0.04	5.01	57.55	1.99	15.21	12.49	1.02	70581.86
8	2.29	5.69	59.85	1.84	15.80	12.27	1.02	71405.87
9	2.44	4.70	40.69	1.91	16.55	10.88	1.02	81603.61
10	2.60	5.80	40.41	3.23	14.45	11.56	1.02	77888.11
11	2.60	9.33	44.32	3.47	13.75	11.83	1.03	75883.14
12	2.72	3.30	47.61	2.96	14.00	11.90	1.03	75967.20
13	2.61	2.63	43.67	2.40	15.00	11.35	1.05	79849.08
14	2.54	2.55	45.26	1.72	16.00	11.13	1.06	80349.50
15	2.80	2.75	44.56	1.63	16.18	11.05	1.04	80557.45
16	6.44	3.47	41.44	2.25	15.73	10.96	1.04	81683.54
17	6.23	3.57	40.34	2.93	14.11	11.24	1.03	81576.31
18	3.09	2.71	45.31	2.06	14.39	11.50	1.03	79407.53
19	7.48	3.00	40.86	2.57	14.65	11.33	1.05	80366.36
20	10.39	7.90	42.75	3.01	13.51	11.55	1.05	79318.77
21	7.12	2.98	51.32	2.43	14.78	11.23	1.05	80443.53
22	7.24	2.84	67.24	1.75	15.68	11.45	1.06	78608.84
23	8.10	3.61	40.06	1.71	15.84	11.20	1.06	80281.75
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.15	5.40	46.52	2.16	15.55	11.36	1.04	78921.06
最大值	10.39	9.33	67.24	3.47	17.53	12.49	1.09	81683.54
發生時間	20	11	22	11	1	7		16
最小值	0.04	2.55	35.02	1.32	13.51	10.83	1.02	70581.86
發生時間	7	14	5	3	20	0		7
零點偏移(率)	-0.10 %	-0.00 %	-0.01 %	-0.01 %		-0.02		-0.10 %
全幅偏移(率)	-0.69 %	-0.75 %	-0.38 %	0.12 %		-0.24		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月05日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.61	5.17	53.11	0.89	15.84	10.73	1.03	80779.87
1	3.84	5.71	52.47	1.01	15.81	10.88	1.03	79395.99
2	3.70	4.80	55.54	0.59	17.77	10.56	1.04	80567.19
3	4.01	4.69	40.16	0.38	17.61	10.14	1.04	84210.63
4	6.54	4.67	43.66	0.45	17.89	10.09	1.04	83564.17
5	5.23	8.16	43.96	0.60	17.47	10.23	1.04	83003.67
6	3.06	5.03	45.56	0.37	18.40	9.99	1.03	84381.97
7	0.10	7.49	45.97	0.31	18.20	10.47	1.04	84483.27
8	2.04	7.26	46.81	0.18	19.90	10.09	1.03	81303.39
9	3.12	7.49	37.11	0.33	17.62	10.18	1.04	83822.29
10	3.91	8.82	41.07	0.91	15.89	10.91	1.04	79605.40
11	3.51	1.89	42.63	0.77	15.94	10.78	1.04	80794.14
12	2.56	2.43	47.13	0.79	16.74	10.92	1.04	78793.53
13	2.36	1.69	43.52	0.50	16.36	10.86	1.04	79312.95
14	2.66	1.64	41.97	0.55	16.63	10.68	1.04	80337.38
15	2.37	2.77	45.53	0.66	16.97	10.61	1.04	80895.90
16	3.50	5.28	40.47	0.99	15.19	10.78	1.04	81307.73
17	4.91	2.79	44.70	1.19	14.98	11.01	1.04	79351.26
18	5.19	1.78	45.81	0.78	16.50	10.69	1.04	80583.70
19	4.25	1.71	43.96	0.57	16.45	10.68	1.04	81098.34
20	2.36	1.62	45.16	0.97	15.29	10.83	1.04	80556.21
21	5.80	4.33	56.09	1.00	16.89	10.41	1.04	82185.92
22	2.03	4.55	57.47	0.38	18.93	9.96	1.04	83182.42
23	4.80	4.55	58.19	0.57	18.18	10.08	1.04	83524.67
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.60	4.43	46.59	0.66	16.98	10.52	1.04	81543.42
最大值	6.54	8.82	58.19	1.19	19.90	11.01	1.06	84483.27
發生時間	4	10	23	17	8	17		7
最小值	0.10	1.62	37.11	0.18	14.98	9.96	1.02	78793.53
發生時間	7	20	9	8	17	22		12
零點偏移(率)	-0.01 %	-0.03 %	-0.04 %	-0.01 %		-0.04		0.20 %
全幅偏移(率)	0.02 %	-0.10 %	0.09 %	-0.02 %		0.06		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								