

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月01日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.36	11.04	62.36	1.10	17.91	12.11	1.03	74609.26
1	0.73	11.19	61.18	0.79	18.70	11.98	1.05	74200.97
2	3.00	9.78	58.06	1.74	15.99	11.73	1.05	78032.48
3	4.35	13.51	50.85	1.89	16.04	12.13	1.05	75719.20
4	8.50	10.39	51.13	1.94	16.55	11.73	1.04	77570.40
5	9.84	12.15	46.71	2.28	16.27	11.76	1.05	78390.89
6	8.14	10.48	47.63	1.83	16.85	11.72	1.05	77741.63
7	8.42	8.33	56.51	1.25	17.79	11.64	1.05	78666.22
8	7.88	9.54	50.08	1.69	16.74	11.91	1.05	77426.58
9	8.73	5.43	55.50	2.12	17.06	12.17	1.05	71212.90
10	8.53	8.75	48.06	1.95	16.03	11.96	1.06	74441.66
11	9.63	9.90	47.96	1.91	16.13	11.83	1.07	76695.53
12	7.33	7.30	51.85	1.54	16.12	12.04	1.05	74068.77
13	4.76	8.76	67.15	0.71	18.45	11.86	1.05	76317.53
14	6.89	9.49	54.79	0.50	18.90	10.99	1.06	82972.40
15	5.84	9.73	60.47	1.02	18.49	11.26	1.07	81326.25
16	8.05	11.12	51.42	1.47	17.63	11.59	1.06	78719.27
17	8.71	13.76	62.21	0.63	19.28	11.01	1.07	80729.52
18	11.49	9.99	45.17	1.59	18.16	11.02	1.07	82549.54
19	5.26	13.42	57.05	1.61	16.75	12.82	1.18	69730.46
20	11.58	9.97	45.44	2.34	16.12	11.83	1.07	77965.59
21	13.39	5.98	50.70	1.95	17.78	11.39	1.05	80711.28
22	9.99	12.92	50.00	1.62	16.79	11.74	1.05	79198.55
23	7.79	9.42	65.02	1.32	17.26	12.10	1.05	75613.25
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.76	10.10	54.05	1.53	17.24	11.76	1.06	77275.42
最大值	13.39	13.76	67.15	2.34	19.28	12.82	1.58	82972.40
發生時間	21	17	13	20	17	19		14
最小值	0.73	5.43	45.17	0.50	15.99	10.99	1.02	69730.46
發生時間	1	9	18	14	2	14		19
零點偏移(率)	-0.01 %	-0.04 %	-0.03 %	-0.00 %		0.00		0.00 %
全幅偏移(率)	0.02 %	0.03 %	0.03 %	0.01 %		0.04		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月01日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.84	8.55	50.08	1.21	19.99	9.85	1.17	83662.12
1	1.42	7.32	60.96	1.20	20.09	10.63	1.17	77606.54
2	6.12	12.79	40.10	1.35	18.74	9.89	1.15	85493.09
3	9.19	8.65	49.18	1.96	17.97	10.15	1.15	83777.71
4	9.17	12.72	44.48	1.51	18.53	9.94	1.15	84660.32
5	7.56	7.86	53.23	1.45	18.88	10.08	1.15	84059.35
6	8.26	12.25	51.92	2.47	17.19	10.42	1.13	87466.44
7	5.95	6.82	54.96	1.60	18.60	9.98	1.14	84289.09
8	6.42	3.04	43.36	1.27	19.51	9.62	1.13	85379.76
9	9.02	3.92	45.73	2.07	18.48	9.87	1.13	85499.11
10	9.30	13.06	55.79	1.70	18.99	9.84	1.15	85408.72
11	7.13	7.36	46.89	1.40	19.00	9.72	1.17	86156.23
12	7.23	9.72	59.61	1.49	18.60	9.97	1.15	84593.76
13	10.69	11.68	51.84	2.66	16.46	10.45	1.15	82682.52
14	10.00	9.36	57.25	2.43	17.09	9.89	1.14	82422.51
15	10.85	10.04	54.08	2.38	16.72	10.20	1.13	81783.70
16	7.78	3.66	56.69	1.13	19.10	9.88	1.15	84675.43
17	8.54	6.93	56.66	1.72	17.80	10.21	1.15	83402.28
18	9.77	6.22	47.18	2.09	17.92	10.25	1.15	83233.37
19	6.03	6.37	47.69	1.73	17.70	10.39	1.15	82646.87
20	10.24	7.15	48.53	1.56	18.37	10.35	1.14	82274.41
21	11.69	12.87	50.44	2.58	16.50	10.10	1.12	80909.62
22	9.36	11.56	55.53	2.03	17.86	9.80	1.12	83909.98
23	8.05	6.37	72.04	1.29	18.49	10.69	1.15	78888.06
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.15	8.59	52.26	1.76	18.27	10.09	1.15	83536.71
最大值	11.69	13.06	72.04	2.66	20.09	10.69	1.18	87466.44
發生時間	21	10	23	13	1	23		6
最小值	1.42	3.04	40.10	1.13	16.46	9.62	1.12	77606.54
發生時間	1	8	2	16	13	8		1
零點偏移(率)	-0.06 %	0.00 %	-0.04 %	-0.01 %		0.02		0.00 %
全幅偏移(率)	0.04 %	-1.21 %	-1.42 %	-1.54 %		-0.25		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月01日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.92	11.09	64.82	1.04	18.26	10.72	1.02	83880.91
1	6.59	5.60	53.82	1.25	17.53	10.90	1.02	83047.67
2	3.24	10.23	61.37	1.18	17.46	10.79	1.02	82026.81
3	2.16	9.87	55.43	1.23	16.75	10.80	1.01	83051.51
4	0.91	6.74	56.56	1.54	15.35	11.24	0.99	79384.63
5	1.90	11.58	56.13	1.52	16.12	10.93	0.99	80985.13
6	2.45	9.80	58.29	1.52	15.67	11.05	0.99	79088.87
7	3.06	7.21	56.05	1.79	15.34	10.96	0.99	81188.89
8	3.32	3.85	58.27	1.29	15.95	10.96	0.99	80329.63
9	11.40	11.21	54.71	2.32	15.30	11.02	1.17	80846.97
10	11.70	14.60	49.22	7.84	12.73	11.29	1.10	70544.69
11	14.34	5.41	56.81	3.49	14.24	11.54	1.03	77242.62
12	1.31	11.78	59.53	1.24	15.79	11.31	1.00	77477.61
13	1.86	13.47	57.02	0.90	16.53	11.26	1.01	75788.45
14	1.50	8.19	59.10	1.05	16.04	10.96	1.04	78143.51
15	10.83	6.77	55.46	1.77	15.11	11.04	1.04	78553.96
16	5.60	3.95	58.47	1.54	15.92	11.27	0.99	76396.63
17	6.03	7.92	59.42	1.79	15.37	11.40	0.99	76400.06
18	0.36	8.16	59.90	0.94	17.21	11.79	1.03	75963.05
19	8.59	8.49	36.88	1.13	17.32	10.86	1.02	84182.20
20	13.38	10.43	58.03	1.39	16.34	11.37	1.04	81496.66
21	13.07	13.03	62.17	2.10	15.92	11.21	1.05	83429.62
22	6.06	6.80	62.65	1.93	15.25	11.75	1.04	77127.95
23	5.81	9.51	72.26	1.26	16.03	11.71	1.03	74878.41
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.68	8.99	57.60	1.79	15.98	11.17	1.02	79227.35
最大值	14.34	14.60	72.26	7.84	18.26	11.79	1.71	84182.20
發生時間	11	10	23	10	0	18		19
最小值	0.36	3.85	36.88	0.90	12.73	10.72	0.97	70544.69
發生時間	18	8	19	13	10	0		10
零點偏移(率)	-0.08 %	0.00 %	-0.04 %	-0.02 %		0.06		0.00 %
全幅偏移(率)	-0.30 %	0.47 %	-0.19 %	0.05 %		0.13		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								