

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月07日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.30	11.19	45.81	1.61	19.25	10.69	1.24	73961.57
1	4.81	11.51	47.68	1.16	20.29	10.71	1.25	73664.64
2	7.50	11.14	55.83	1.57	20.29	10.57	1.25	75009.33
3	15.33	11.47	44.02	2.21	19.22	10.61	1.25	75639.71
4	14.96	11.25	50.21	1.80	21.05	10.06	1.25	78009.84
5	10.11	11.36	49.42	1.96	21.07	10.38	1.25	82042.50
6	5.88	11.36	46.02	1.89	19.46	10.54	1.25	76227.09
7	6.57	11.46	54.79	1.93	20.45	10.27	1.25	76984.03
8	6.01	11.98	52.20	2.12	20.83	10.07	1.25	77938.65
9	4.47	11.68	58.50	3.18	17.75	11.23	1.25	72821.32
10	7.05	11.53	62.87	2.69	18.78	11.02	1.25	73869.89
11	4.92	11.88	55.71	1.71	19.62	11.21	1.25	71656.70
12	5.07	12.07	50.80	2.80	18.22	11.31	1.25	71904.43
13	13.47	12.20	54.56	3.22	16.69	11.50	1.25	72093.91
14	13.75	12.03	58.83	3.68	16.99	11.57	1.27	71338.02
15	6.31	12.54	59.52	2.96	17.17	11.57	1.26	71924.95
16	12.94	12.23	62.95	4.66	17.21	11.25	1.26	73830.21
17	9.52	11.76	58.78	2.14	17.04	11.38	1.26	73470.62
18	7.25	11.39	55.52	1.63	18.54	10.74	1.25	77268.29
19	5.22	11.46	55.34	1.22	18.42	10.80	1.25	76688.89
20	12.79	11.81	53.39	1.24	16.67	11.46	1.25	73429.07
21	17.58	12.10	59.51	1.70	15.93	11.59	1.25	72966.17
22	10.98	11.73	59.66	1.53	17.19	11.32	1.25	73737.04
23	5.96	11.52	58.71	2.97	18.17	11.07	1.25	74639.71
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.91	11.69	54.61	2.23	18.60	10.96	1.25	74629.86
最大值	17.58	12.54	62.95	4.66	21.07	11.59	1.29	82042.50
發生時間	21	15	16	16	5	21		5
最小值	4.47	11.14	44.02	1.16	15.93	10.06	1.23	71338.02
發生時間	9	2	3	1	21	4		14
零點偏移(率)	-0.06 %	0.01 %	-0.01 %	-0.03 %		-0.08	-0.01	0.20 %
全幅偏移(率)	-1.61 %	0.68 %	0.11 %	0.58 %		-0.02	0.04	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月07日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.15	13.95	53.45	0.76	19.83	10.08	1.05	81828.83
1	10.07	12.28	40.98	1.14	20.93	10.43	1.04	74398.66
2	9.96	11.93	43.04	0.53	21.53	9.47	1.03	80792.06
3	9.49	11.66	43.67	0.52	20.31	9.87	1.02	78921.71
4	7.03	12.24	61.94	0.74	19.74	10.62	1.03	71691.06
5	7.91	12.07	47.22	0.57	20.32	10.14	1.02	76019.24
6	11.29	13.37	53.55	0.65	18.34	11.68	1.02	66931.22
7	6.54	13.04	53.04	0.63	19.02	11.34	1.02	73847.32
8	9.15	13.16	53.21	0.81	20.18	10.78	1.02	74757.94
9	11.07	12.48	50.76	0.78	20.43	10.66	1.02	82305.65
10	12.41	13.95	49.65	1.24	18.95	11.39	0.99	80253.59
11	6.00	14.15	55.07	0.62	19.64	11.43	0.98	77078.85
12	8.14	13.07	53.72	1.13	19.00	10.80	0.97	85092.79
13	10.60	13.55	58.93	1.20	18.76	11.19	0.96	80684.24
14	8.88	13.08	57.19	0.64	19.45	11.18	0.96	80275.92
15	9.89	13.17	48.47	0.76	19.44	11.25	0.97	79859.99
16	9.29	13.44	43.43	0.40	20.32	10.44	0.98	75693.67
17	7.85	12.53	33.38	0.57	19.97	10.36	0.99	76250.56
18	9.67	12.24	60.41	1.40	18.69	10.24	1.02	81410.32
19	10.68	12.08	55.87	0.99	17.45	10.74	1.02	80694.37
20	11.47	12.28	57.76	2.25	17.50	10.67	1.02	83949.59
21	14.05	12.35	52.36	4.05	17.25	10.26	1.02	82088.60
22	8.95	11.97	50.78	1.44	16.75	10.57	1.02	78956.76
23	11.15	11.41	46.64	1.93	19.11	9.91	1.02	79908.02
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.57	12.73	51.02	1.07	19.29	10.65	1.01	78487.12
最大值	14.05	14.15	61.94	4.05	21.53	11.68	1.06	85092.79
發生時間	21	11	4	21	2	6		12
最小值	6.00	11.41	33.38	0.40	16.75	9.47	0.96	66931.22
發生時間	11	23	17	16	22	2		6
零點偏移(率)	-0.12 %	0.00 %	-0.07 %	-0.00 %		-0.13	-0.01	0.10 %
全幅偏移(率)	-0.17 %	0.13 %	1.21 %	1.62 %		-0.39	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月07日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.09	12.51	61.53	2.13	19.05	10.63	1.33	75977.71
1	9.25	11.95	52.60	1.91	19.76	10.38	1.31	77388.78
2	9.30	11.59	52.78	2.02	19.30	10.06	1.31	77487.67
3	8.99	11.65	52.33	2.07	18.94	10.21	1.32	75575.76
4	9.50	11.71	51.03	2.04	18.85	10.17	1.33	76906.03
5	8.26	11.45	51.01	2.02	18.82	10.08	1.31	75913.35
6	8.59	11.75	53.11	1.98	18.29	10.35	1.32	74234.62
7	10.06	12.12	52.58	3.26	19.15	10.21	1.31	75045.80
8	9.17	11.97	58.27	3.29	19.25	10.38	1.32	75960.87
9	10.08	11.46	50.59	3.25	19.47	9.83	1.31	79243.22
10	6.76	11.64	52.67	3.06	18.14	10.21	1.31	76135.41
11	8.97	11.53	52.46	3.04	19.51	9.90	1.31	78634.06
12	9.10	11.84	53.08	3.05	18.55	10.32	1.31	77017.62
13	8.18	11.99	51.61	3.15	17.96	10.36	1.32	76444.85
14	7.80	12.99	42.73	2.99	18.66	9.42	1.31	74076.61
15	9.39	11.75	43.04	2.70	18.30	10.10	1.31	75818.94
16	9.45	11.47	48.47	3.82	19.50	9.82	1.31	82589.14
17	7.13	11.70	48.16	3.44	18.21	10.06	1.31	77746.72
18	7.14	12.21	52.04	3.37	17.91	10.20	1.31	80494.97
19	10.91	12.67	55.31	3.97	16.17	10.55	1.31	77735.18
20	8.40	13.07	52.49	3.70	17.29	10.12	1.31	75671.35
21	9.70	11.16	55.33	3.74	18.22	9.87	1.31	75674.85
22	10.88	11.38	56.65	4.11	16.71	10.19	1.31	76084.18
23	8.81	12.34	53.73	1.95	15.99	10.47	1.31	73852.02
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.95	11.91	52.23	2.92	18.42	10.16	1.31	76737.90
最大值	10.91	13.07	61.53	4.11	19.76	10.63	1.34	82589.14
發生時間	19	20	0	22	1	0		16
最小值	6.76	11.16	42.73	1.91	15.99	9.42	1.30	73852.02
發生時間	10	21	14	1	23	14		23
零點偏移(率)	-0.08 %	-0.00 %	-0.04 %	-0.01 %		-0.09	-0.01	-0.10 %
全幅偏移(率)	0.02 %	0.02 %	0.00 %	-0.01 %		0.00	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								