

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月14日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.57	12.56	36.60	1.72	15.15	12.02	1.26	75998.49
1	15.65	11.81	49.97	2.54	15.25	11.67	1.29	79496.02
2	13.21	12.51	52.00	2.09	16.81	11.35	1.29	81503.03
3	15.54	11.71	51.35	1.98	15.84	11.04	1.29	82300.31
4	11.58	12.65	55.25	2.67	13.41	12.20	1.30	75404.41
5	12.44	13.76	64.88	2.01	15.77	11.98	1.26	76246.21
6	18.38	12.67	52.17	5.21	14.82	11.31	1.26	82611.37
7	9.61	13.12	56.21	3.56	15.18	11.78	1.27	79833.39
8	13.88	12.82	53.02	3.61	14.71	11.54	1.26	79909.20
9	9.76	13.04	44.08	2.41	15.52	11.60	1.23	79056.71
10	14.36	11.74	55.32	1.57	15.83	11.64	1.26	79753.72
11	16.05	11.85	54.24	2.29	14.74	11.86	1.25	78867.86
12	8.94	11.93	54.51	2.10	15.10	11.92	1.24	78657.09
13	12.60	11.60	58.54	2.55	14.84	11.63	1.24	81212.21
14	9.17	12.32	51.74	2.94	13.55	12.19	1.25	75688.80
15	13.96	11.91	54.86	2.42	15.09	11.87	1.25	77052.72
16	8.00	11.92	57.16	2.69	14.97	11.87	1.24	77367.50
17	7.83	11.80	59.10	3.56	14.10	11.65	1.22	76924.27
18	8.37	12.24	55.02	3.13	13.99	12.09	1.22	76375.45
19	8.59	13.09	46.82	3.35	13.55	11.87	1.24	79267.37
20	10.34	13.29	50.82	3.68	13.19	12.13	1.25	77365.70
21	6.32	13.09	53.98	3.51	12.41	12.47	1.25	75129.56
22	9.72	13.02	54.13	2.74	13.21	12.46	1.24	71399.96
23	10.48	12.27	51.08	2.71	13.90	11.33	1.25	79923.29
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	11.51	12.45	53.04	2.79	14.62	11.81	1.25	78222.69
最大值	18.38	13.76	64.88	5.21	16.81	12.47	1.31	82611.37
發生時間	6	5	5	6	2	21		6
最小值	6.32	11.60	36.60	1.57	12.41	11.04	1.20	71399.96
發生時間	21	13	0	10	21	3		22
零點偏移(率)	-0.41 %	-0.08 %	-0.02 %	0.00 %		-0.05	-0.01	0.40 %
全幅偏移(率)	-1.56 %	-2.08 %	-0.51 %	-1.32 %		0.15	-0.06	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月14日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.01	11.66	40.86	1.46	15.98	10.58	1.02	75704.86
1	8.71	11.26	41.23	1.70	17.58	10.00	1.03	78528.85
2	8.97	11.85	50.36	1.77	16.68	10.68	1.05	77242.56
3	11.21	11.71	55.63	1.76	15.05	10.79	1.06	76097.98
4	13.77	11.55	51.17	2.73	14.95	10.65	1.06	76893.51
5	7.93	11.75	47.51	2.43	14.92	10.82	1.06	76626.61
6	12.91	11.58	45.17	1.87	15.35	10.88	1.06	72468.66
7	11.99	11.74	48.55	2.24	15.33	10.76	1.05	77200.15
8	12.12	11.48	50.97	1.38	16.09	10.47	1.06	78367.38
9	6.00	11.74	47.24	1.30	16.30	10.63	1.04	72771.58
10	7.45	11.21	37.04	1.18	16.69	9.46	1.04	75568.42
11	7.76	11.93	48.34	2.38	13.10	10.59	1.02	73797.94
12	11.97	12.08	51.10	2.21	13.52	10.60	1.05	73771.06
13	5.37	11.89	52.83	1.80	14.64	10.76	1.04	75536.26
14	6.88	11.81	52.82	1.75	14.76	10.71	1.03	76184.65
15	9.04	12.07	49.34	1.97	13.60	10.98	1.04	73988.89
16	10.00	11.60	44.46	1.86	14.21	10.67	1.04	75054.18
17	7.54	12.05	52.02	1.81	13.70	10.81	1.05	75069.64
18	7.10	11.89	47.33	1.89	14.11	10.82	1.03	75022.69
19	6.56	11.53	52.87	1.55	14.16	10.68	1.03	76863.46
20	5.06	11.90	52.75	1.58	14.17	11.06	1.02	74252.95
21	6.92	11.90	50.19	1.58	14.85	10.96	1.02	74952.56
22	8.30	11.40	50.00	2.11	13.36	10.61	1.02	76420.29
23	9.57	11.66	48.60	1.82	13.98	10.81	1.02	73672.18
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.63	11.72	48.68	1.84	14.88	10.66	1.04	75502.39
最大值	13.77	12.08	55.63	2.73	17.58	11.06	1.07	78528.85
發生時間	4	12	3	4	1	20		1
最小值	4.01	11.21	37.04	1.18	13.10	9.46	1.02	72468.66
發生時間	0	10	10	10	11	10		6
零點偏移(率)	-0.02 %	-0.06 %	-0.03 %	-0.01 %		-0.08	-0.01	0.10 %
全幅偏移(率)	0.83 %	0.63 %	-0.09 %	-0.03 %		-0.06	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月14日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.17	11.41	59.14	3.08	14.83	10.68	1.41	72396.85
1	9.17	11.27	57.24	2.92	15.04	10.52	1.40	72593.13
2	9.90	11.27	56.98	2.99	16.40	10.34	1.41	73364.86
3	9.49	11.41	58.61	4.05	13.63	10.74	1.41	70363.78
4	7.52	11.13	53.49	6.22	14.35	10.27	1.41	72824.41
5	9.81	11.19	54.91	4.22	14.07	10.53	1.40	71465.01
6	6.79	10.95	52.87	2.92	15.60	10.09	1.39	72053.30
7	5.60	11.62	40.68	2.67	16.41	9.52	1.42	77086.28
8	8.98	11.86	53.59	3.31	14.29	10.38	1.43	70368.45
9	10.32	11.75	51.80	2.29	15.66	10.25	1.43	70592.55
10	12.00	11.19	54.49	1.95	16.15	10.00	1.43	74254.58
11	8.25	13.10	55.14	2.67	13.84	10.72	1.43	69575.28
12	8.67	12.34	54.72	2.42	13.84	10.46	1.41	71045.07
13	9.44	13.01	55.18	2.42	14.50	10.38	1.43	71696.74
14	9.40	12.08	52.50	1.87	15.47	10.08	1.42	70329.80
15	11.29	11.80	47.53	1.89	15.62	9.68	1.43	71625.44
16	9.41	12.44	49.96	2.06	14.44	10.13	1.43	69145.59
17	8.48	12.70	51.83	2.63	14.23	9.88	1.41	70767.14
18	9.65	11.45	60.02	3.93	13.80	10.33	1.37	68033.17
19	10.70	10.68	48.51	3.90	15.49	8.91	1.37	71412.88
20	7.71	10.61	48.70	3.35	15.32	9.11	1.39	69956.79
21	10.44	10.73	50.61	3.51	15.11	9.43	1.36	69436.49
22	9.58	10.66	43.67	4.03	15.09	8.95	1.37	70088.54
23	9.33	10.69	49.07	3.05	15.37	9.50	1.39	66882.75
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.21	11.56	52.55	3.10	14.94	10.04	1.41	71139.95
最大值	12.00	13.10	60.02	6.22	16.41	10.74	1.44	77086.28
發生時間	10	11	18	4	7	3		7
最小值	5.60	10.61	40.68	1.87	13.63	8.91	1.36	66882.75
發生時間	7	20	7	14	3	19		23
零點偏移(率)	0.00 %	-0.03 %	-0.11 %	0.00 %		-0.08	-0.01	0.00 %
全幅偏移(率)	1.16 %	0.57 %	0.26 %	-0.05 %		0.14	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								