

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年06月25日

報表日期: 113年06月25日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.78	7.05	64.68	0.62	19.24	11.49	0.95	80732.12
1	9.17	37.56	38.85	2.32	17.90	10.71	0.97	81966.63
2	7.38	2.84	33.69	3.37	15.92	11.52	0.97	76718.79
3	8.48	3.21	43.60	2.02	17.17	11.43	0.97	78113.49
4	7.64	4.80	40.72	1.48	17.98	11.14	0.97	80866.33
5	10.28	4.08	48.26	2.94	18.37	11.03	0.94	90131.47
6	8.22	3.14	38.21	3.04	16.89	11.44	0.93	79135.13
7	8.64	3.24	37.15	2.80	17.69	11.15	0.91	80624.66
8	8.20	3.05	34.94	2.45	18.33	11.12	0.91	80934.89
9	7.73	3.69	33.55	2.65	17.82	11.23	0.95	82918.19
10	9.65	3.11	39.84	3.09	17.65	11.17	0.92	82314.48
11	8.96	5.94	35.89	1.41	17.26	11.30	0.94	81564.31
12	7.49	3.06	43.27	1.14	17.11	11.31	0.93	81153.04
13	7.77	3.12	49.95	0.97	18.28	11.56	0.92	77882.52
14	13.16	11.39	42.00	2.40	15.49	11.99	0.93	78321.21
15	10.82	2.00	34.64	2.04	15.82	11.89	0.91	78436.06
16	9.75	2.19	54.27	1.11	17.44	11.47	0.92	81582.42
17	9.92	2.56	51.65	1.19	17.36	11.28	0.93	84612.60
18	9.51	3.49	48.31	1.70	18.38	10.84	0.95	87063.91
19	7.98	3.77	59.17	2.38	17.16	11.52	0.96	82625.97
20	11.79	3.41	56.18	1.83	18.80	10.67	0.95	87999.73
21	10.91	3.57	55.00	2.63	16.06	11.65	0.96	82435.49
22	13.23	9.17	52.53	3.06	15.80	11.75	0.95	82204.75
23	10.72	3.87	53.97	1.96	16.50	11.59	0.94	82949.96
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.34	5.55	45.43	2.11	17.35	11.34	0.94	81803.67
最 大 值	13.23	37.56	64.68	3.37	19.24	11.99	0.97	90131.47
發生時間	22	1	0	2	0	14		5
最 小 值	6.78	2.00	33.55	0.62	15.49	10.67	0.90	76718.79
發生時間	0	15	9	0	14	20		2
零點偏移(率)	-0.06 %	-0.05 %	-0.02 %	-0.00 %		-0.05		0.00 %
全幅偏移(率)	0.00 %	0.00 %	-0.78 %	-0.11 %		0.11		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年06月25日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.51	7.04	52.54	1.05	18.43	9.87	0.94	81003.52
1	3.48	6.47	55.75	1.04	18.42	9.99	0.92	78506.49
2	4.46	3.57	54.40	1.98	15.52	11.58	0.93	68612.32
3	3.42	2.71	52.16	1.27	17.07	10.20	0.94	80830.96
4	3.95	1.02	50.79	1.21	16.58	10.42	0.95	81669.44
5	4.12	4.68	50.29	1.69	18.33	9.54	0.94	86600.17
6	6.19	3.58	58.06	1.67	17.20	9.87	0.93	78667.94
7	0.71	2.74	69.74	1.40	15.96	11.23	0.92	77860.61
8	0.86	2.33	60.96	1.23	18.36	10.37	0.98	77552.81
9	1.65	3.18	48.76	1.26	16.49	10.26	0.94	79504.18
10	2.10	5.35	49.11	1.42	16.57	10.19	0.96	80539.59
11	3.79	2.45	50.08	1.52	16.04	10.45	0.95	77679.09
12	2.66	2.66	50.52	1.39	16.32	10.39	0.96	77637.94
13	2.52	2.35	52.26	1.35	17.05	10.34	0.94	77145.78
14	2.56	7.29	48.31	2.27	14.40	11.08	0.95	76148.70
15	1.71	2.36	54.74	1.58	15.55	11.21	0.93	71162.33
16	1.71	2.14	54.99	1.88	14.75	10.98	0.92	78027.27
17	2.06	3.01	58.69	1.31	17.08	10.37	0.92	82043.28
18	1.45	7.41	50.30	1.07	17.28	10.08	0.92	85408.45
19	2.74	4.40	56.39	1.44	16.39	10.63	0.92	81833.09
20	2.98	2.38	58.69	1.54	16.35	10.80	0.92	80712.10
21	1.64	2.21	56.77	1.26	17.42	10.29	0.92	83961.10
22	1.64	2.93	56.57	1.14	16.64	10.94	0.92	78052.67
23	0.42	2.12	61.08	1.14	17.06	10.39	0.92	83108.11
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.81	3.60	54.66	1.42	16.72	10.48	0.94	79344.50
最 大 值	8.51	7.41	69.74	2.27	18.43	11.58	0.99	86600.17
發生時間	0	18	7	14	0	2		5
最 小 值	0.42	1.02	48.31	1.04	14.40	9.54	0.90	68612.32
發生時間	23	4	14	1	14	5		2
零點偏移(率)	-0.02 %	-0.00 %	-0.03 %	-0.01 %		-0.02		0.00 %
全幅偏移(率)	0.02 %	-0.43 %	-0.69 %	0.00 %		0.33		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								