

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月24日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.07	5.66	48.19	2.41	17.29	12.03	1.41	71625.80
1	9.59	2.46	52.14	2.63	16.78	12.45	1.39	68975.01
2	9.10	4.18	52.09	2.45	16.57	12.18	1.38	71491.70
3	9.22	4.92	50.95	2.60	16.35	12.27	1.41	71041.45
4	9.74	5.75	56.65	2.51	16.63	11.94	1.42	73498.01
5	10.76	4.44	53.63	2.46	16.60	12.04	1.39	72550.85
6	8.36	7.23	61.82	2.31	17.00	12.07	1.40	72208.11
7	11.51	5.17	52.58	2.50	16.55	11.73	1.42	74805.24
8	9.29	8.80	55.09	2.80	15.60	12.69	1.44	67585.64
9	5.41	7.80	56.57	2.38	16.25	12.25	1.49	70979.92
10	8.49	17.46	55.67	2.40	16.48	12.05	1.47	72515.94
11	7.17	5.98	60.21	2.81	15.96	12.99	1.52	65515.22
12	10.16	0.56	47.81	2.84	15.76	12.78	1.46	66668.54
13	6.06	4.41	51.34	2.81	15.49	12.83	1.46	66994.93
14	9.87	6.00	56.06	3.06	15.22	12.75	1.46	67408.23
15	10.45	2.01	47.58	2.70	15.63	12.27	1.42	71622.55
16	7.88	3.15	50.30	3.05	15.02	12.79	1.42	67885.13
17	7.86	8.10	55.86	3.30	14.72	13.12	1.44	65173.67
18	9.19	4.54	55.38	3.04	15.48	12.79	1.39	67365.42
19	9.44	2.42	50.63	2.40	16.44	12.17	1.39	72751.81
20	6.27	6.51	55.53	3.01	15.10	13.08	1.40	66292.52
21	7.79	2.87	57.29	2.36	16.58	12.10	1.42	72814.37
22	9.96	11.76	49.43	2.80	15.10	12.48	1.39	70813.39
23	8.48	7.66	53.52	4.03	14.05	13.30	1.38	64530.04
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.71	5.83	53.60	2.74	15.94	12.46	1.42	69713.06
最大值	11.51	17.46	61.82	4.03	17.29	13.30	1.68	74805.24
發生時間	7	10	6	23	0	23		7
最小值	5.41	0.56	47.58	2.31	14.05	11.73	1.38	64530.04
發生時間	9	12	15	6	23	7		23
零點偏移(率)	-0.01 %	-0.00 %	-0.01 %	-0.01 %		0.00	0.00	0.00 %
全幅偏移(率)	-1.60 %	0.03 %	-0.36 %	0.02 %		0.47	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								



P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月24日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.82	1.27	56.23	2.58	13.63	11.03	1.72	77718.14
1	9.64	7.47	60.97	2.46	14.16	11.11	1.73	78209.85
2	10.66	3.97	56.27	3.50	11.72	11.24	1.71	77997.60
3	9.54	6.06	54.44	3.00	12.81	11.12	1.68	78329.32
4	10.48	2.12	57.19	3.17	12.24	11.32	1.71	79951.20
5	9.08	3.02	59.15	3.02	12.48	11.33	1.69	78733.01
6	7.32	3.31	66.59	2.86	13.17	11.15	1.68	80541.67
7	9.90	2.40	54.79	2.21	13.72	10.96	1.76	76751.01
8	10.55	5.65	56.33	2.30	13.43	10.71	1.77	81653.09
9	11.04	0.57	53.82	2.85	12.27	11.35	1.76	77254.30
10	7.66	0.40	61.19	2.42	13.12	11.09	1.76	79518.99
11	10.54	0.30	58.51	2.62	12.71	11.13	1.76	80684.75
12	5.72	0.30	57.42	1.81	13.93	11.25	1.77	80362.96
13	6.66	2.77	60.49	1.60	14.40	11.15	1.78	85608.97
14	5.85	4.20	63.03	1.75	13.95	11.31	1.77	84192.26
15	11.04	5.33	57.65	2.10	13.88	11.25	1.75	84581.71
16	10.48	0.93	60.33	2.12	13.54	11.10	1.72	85292.12
17	9.70	1.13	65.90	1.95	14.10	11.30	1.72	84724.04
18	9.77	1.50	63.65	1.57	15.13	10.87	1.72	88002.74
19	9.83	1.30	65.69	1.35	15.39	10.73	1.73	88309.49
20	10.06	3.91	64.56	2.41	12.97	11.48	1.77	86450.61
21	9.52	4.95	62.49	1.73	14.54	11.07	1.78	88531.73
22	10.77	3.12	64.01	2.36	13.15	11.45	1.77	85114.93
23	11.42	4.48	60.09	2.64	12.60	11.60	1.75	85718.65
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.42	2.94	60.03	2.35	13.46	11.17	1.74	82259.71
最大值	11.42	7.47	66.59	3.50	15.39	11.60	1.79	88531.73
發生時間	23	1	6	2	19	23		21
最小值	5.72	0.30	53.82	1.35	11.72	10.71	1.67	76751.01
發生時間	12	11	9	19	2	8		7
零點偏移(率)	-0.05 %	-0.00 %	-0.18 %	0.00 %		-0.04	0.00	0.00 %
全幅偏移(率)	2.42 %	-0.72 %	0.10 %	0.25 %		0.41	-0.03	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								