

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月23日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.13	2.82	57.93	0.66	19.24	11.09	1.41	78483.47
1	9.54	1.30	54.46	0.69	19.15	11.34	1.39	76347.20
2	6.90	2.15	58.17	0.76	19.57	11.89	1.40	72261.29
3	9.64	1.36	52.80	0.85	19.21	11.52	1.40	75489.98
4	8.12	1.07	52.57	0.37	20.50	10.69	1.41	80645.83
5	3.53	4.91	60.71	0.45	18.89	11.86	1.45	76155.49
6	1.80	7.02	55.89	0.38	19.11	11.74	1.46	73712.07
7	4.55	7.04	60.41	0.52	19.15	11.81	1.46	72841.42
8	5.76	1.49	47.80	0.30	19.75	10.80	1.48	80296.42
9	4.96	2.74	48.09	0.45	18.39	11.35	1.46	77728.76
10	4.44	10.88	40.49	0.81	16.68	11.72	1.47	75970.40
11	6.17	3.07	48.91	0.62	18.18	11.38	1.50	76734.23
12	9.14	2.52	46.89	0.65	18.24	11.39	1.48	76494.12
13	7.65	2.52	59.75	0.44	19.07	11.60	1.46	73655.03
14	2.28	2.75	60.57	0.44	18.66	12.13	1.46	70868.38
15	8.00	3.21	43.93	0.47	19.07	11.20	1.45	77885.96
16	9.81	8.87	37.79	0.89	17.12	11.56	1.46	76478.22
17	9.06	1.29	48.41	0.50	18.59	11.36	1.47	76913.27
18	9.63	6.22	51.12	0.55	18.30	11.53	1.48	76247.41
19	10.73	4.89	39.44	0.78	18.11	11.49	1.46	76222.23
20	10.94	1.59	41.41	0.75	17.84	11.47	1.45	76761.76
21	9.54	0.65	38.99	0.63	17.87	11.58	1.43	75844.77
22	10.00	4.73	47.51	0.63	18.31	11.85	1.43	73239.60
23	10.56	7.92	46.50	0.70	17.68	11.74	1.44	74309.93
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.66	3.88	50.02	0.60	18.61	11.50	1.45	75899.47
最大值	11.13	10.88	60.71	0.89	20.50	12.13	1.50	80645.83
發生時間	0	10	5	16	4	14		4
最小值	1.80	0.65	37.79	0.30	16.68	10.69	1.38	70868.38
發生時間	6	21	16	8	10	4		14
零點偏移(率)	-0.26 %	0.00 %	-0.00 %	-0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	-3.41 %	-0.19 %	-0.22 %	0.06 %		0.41	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月23日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.27	1.06	45.44	1.24	18.45	9.83	1.40	66476.12
1	8.90	4.41	50.64	1.43	18.71	9.99	1.38	66628.50
2	10.44	4.22	54.53	2.25	16.56	10.47	1.38	67895.04
3	8.50	0.61	56.82	1.90	17.37	10.63	1.37	66404.40
4	9.61	1.00	50.41	2.08	17.16	10.56	1.36	64768.06
5	10.02	0.66	55.37	1.83	18.30	10.11	1.37	67026.56
6	10.54	3.43	64.30	1.17	20.32	10.24	1.38	63292.07
7	8.19	9.00	71.86	1.53	18.25	12.00	1.48	57815.71
8	5.40	2.80	53.85	1.47	18.31	11.26	1.42	62257.36
9	8.70	2.86	49.74	1.13	19.06	9.99	1.39	69027.79
10	10.25	7.71	52.24	2.17	15.62	11.01	1.39	64856.47
11	8.38	1.67	48.87	1.75	17.38	10.47	1.38	66497.69
12	9.58	9.89	59.24	2.39	14.86	11.17	1.38	64778.54
13	9.32	3.79	54.37	1.85	16.47	10.85	1.41	65649.81
14	6.66	3.03	53.51	1.49	17.80	10.75	1.40	64217.50
15	9.97	7.63	56.27	2.06	15.88	11.09	1.39	64858.33
16	9.42	11.90	49.49	2.56	16.15	10.73	1.38	66933.04
17	7.20	0.95	53.82	2.51	16.98	10.87	1.37	64864.46
18	11.52	0.67	53.40	2.04	16.55	10.84	1.36	65846.07
19	9.15	2.54	50.45	1.29	18.82	10.08	1.38	68981.39
20	9.93	1.34	52.91	1.88	16.22	10.92	1.38	65411.61
21	11.24	1.41	51.47	1.85	16.42	10.79	1.38	66132.04
22	11.89	5.67	52.96	2.04	15.42	11.03	1.38	65255.87
23	9.63	2.58	53.69	1.97	15.97	11.07	1.38	65175.20
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.24	3.78	53.99	1.83	17.21	10.70	1.39	65460.40
最大值	11.89	11.90	71.86	2.56	20.32	12.00	1.78	69027.79
發生時間	22	16	7	16	6	7		9
最小值	5.40	0.61	45.44	1.13	14.86	9.83	1.34	57815.71
發生時間	8	3	0	9	12	0		7
零點偏移(率)	0.00 %	-0.03 %	-0.01 %	0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	0.94 %	0.02 %	-0.15 %	0.01 %		0.34	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月23日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.40	4.80	49.05	1.24	17.67	10.28	1.26	86942.70
1	7.37	10.01	50.09	2.04	17.80	10.18	1.30	90492.34
2	13.06	2.43	55.62	2.62	15.28	11.11	1.30	88376.18
3	5.78	0.69	57.14	1.67	16.16	10.84	1.27	89148.99
4	8.44	1.44	55.79	1.59	16.30	10.86	1.25	88982.08
5	9.07	1.31	58.04	1.44	17.44	10.56	1.25	91145.15
6	8.72	1.81	62.69	1.42	17.09	10.81	1.28	87979.77
7	0.50	11.12	71.41	1.67	14.96	13.12	1.37	74971.95
8	0.29	8.53	57.65	1.91	15.04	12.11	1.51	79341.07
9	7.22	4.48	55.92	1.60	14.62	11.15	1.31	88226.39
10	8.32	12.54	58.68	2.30	13.73	11.39	1.30	83824.37
11	5.62	4.37	59.38	1.69	15.07	11.21	1.27	84620.63
12	6.99	9.54	55.01	2.06	14.07	11.24	1.26	82931.40
13	8.11	2.71	55.04	1.47	15.54	10.91	1.30	85204.93
14	5.33	13.80	54.69	2.28	12.93	11.28	1.30	83084.92
15	4.51	6.23	52.88	1.68	14.49	11.16	1.28	85488.61
16	2.56	5.69	60.35	1.61	14.50	11.58	1.27	81515.16
17	4.76	4.61	56.49	1.48	14.76	11.27	1.35	83900.36
18	4.57	1.81	58.32	1.05	16.26	11.13	1.31	86316.59
19	6.25	10.22	57.66	1.53	14.92	11.31	1.30	86242.26
20	8.80	5.80	56.23	2.07	13.88	11.44	1.30	85480.67
21	14.16	9.92	58.76	3.18	12.74	11.82	1.29	83954.12
22	9.64	1.62	60.81	1.61	15.47	11.25	1.28	85638.92
23	7.19	4.90	52.56	3.37	14.86	11.05	1.27	84388.15
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.69	5.85	57.09	1.86	15.23	11.21	1.30	85341.57
最大值	14.16	13.80	71.41	3.37	17.80	13.12	2.10	91145.15
發生時間	21	14	7	23	1	7		5
最小值	0.29	0.69	49.05	1.05	12.74	10.18	1.25	74971.95
發生時間	8	3	0	18	21	1		7
零點偏移(率)	-0.04 %	0.00 %	-0.01 %	-0.00 %		0.03	0.00	0.00 %
全幅偏移(率)	1.22 %	-0.30 %	-0.39 %	-0.00 %		0.57	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								