

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月21日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.75	5.13	45.15	3.75	17.80	11.56	1.33	70686.29
1	8.57	5.99	48.34	4.10	16.00	12.30	1.33	66717.31
2	6.85	3.24	62.85	3.78	16.59	12.08	1.33	68310.82
3	8.47	3.92	43.52	4.38	16.25	11.70	1.33	70204.77
4	3.69	3.76	54.96	3.66	16.02	12.26	1.33	67499.07
5	5.03	3.26	51.80	3.43	17.31	11.65	1.34	70273.94
6	6.79	3.38	60.70	3.66	16.65	12.05	1.36	67203.53
7	8.79	4.20	51.78	4.48	15.46	12.19	1.36	67204.35
8	10.23	9.29	52.46	6.53	14.70	12.32	1.35	66547.20
9	8.64	5.26	50.64	5.63	14.03	12.70	1.33	64103.46
10	6.74	2.66	54.97	4.70	15.03	12.40	1.33	65922.37
11	10.03	3.35	46.86	5.58	14.82	12.18	1.33	66034.93
12	7.99	5.76	56.69	5.26	15.08	12.38	1.34	64931.86
13	8.80	1.53	45.24	4.14	17.08	11.71	1.31	69177.99
14	9.04	2.89	55.02	4.70	15.24	12.41	1.30	64959.56
15	10.61	2.94	53.98	5.07	15.24	12.28	1.32	65715.70
16	9.63	2.51	50.32	4.79	15.21	12.29	1.33	66662.52
17	9.13	1.72	57.12	5.19	14.97	12.23	1.30	66950.09
18	8.41	1.64	51.17	4.70	15.65	12.25	1.30	65715.78
19	7.75	1.95	57.22	4.22	16.54	11.95	1.30	68317.70
20	9.55	1.74	47.44	4.91	15.09	12.27	1.32	66391.54
21	7.88	2.08	56.38	5.20	14.52	12.51	1.34	64108.81
22	9.04	2.39	49.62	5.59	14.13	12.56	1.34	63701.49
23	5.93	2.84	52.68	5.74	13.57	12.67	1.33	62657.18
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.14	3.48	52.37	4.72	15.54	12.20	1.33	66666.59
最大值	10.61	9.29	62.85	6.53	17.80	12.70	1.37	70686.29
發生時間	15	8	2	8	0	9		0
最小值	3.69	1.53	43.52	3.43	13.57	11.56	1.29	62657.18
發生時間	4	13	3	5	23	0		23
零點偏移(率)	-0.02 %	-0.07 %	-0.02 %	-0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	0.02 %	0.03 %	-0.07 %	0.03 %		0.06	-0.03	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月21日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.71	2.18	56.25	1.41	19.99	10.49	1.41	79464.35
1	8.11	2.27	50.33	2.20	20.24	9.79	1.41	87157.88
2	10.39	2.46	59.28	3.13	17.31	9.94	1.42	83456.18
3	7.36	2.96	59.59	2.10	20.62	9.45	1.42	86296.23
4	8.89	2.42	54.30	2.24	20.04	9.54	1.43	88940.55
5	8.02	5.17	50.26	2.48	18.38	9.95	1.42	85326.93
6	4.63	2.17	64.41	1.44	20.68	9.86	1.44	82677.97
7	6.93	6.08	57.15	3.55	20.75	9.50	1.44	85038.70
8	9.64	1.95	44.09	3.90	18.65	9.40	1.43	82788.10
9	9.77	2.73	51.53	2.92	18.04	9.39	1.44	81843.89
10	11.21	4.47	52.81	3.60	17.02	9.59	1.44	81740.70
11	9.51	4.54	56.74	2.65	17.58	10.27	1.46	82493.85
12	7.57	2.03	61.65	1.85	19.71	9.86	1.46	82080.45
13	9.85	4.16	46.37	2.50	18.20	9.80	1.46	81226.07
14	9.18	4.40	60.81	2.53	18.06	9.76	1.45	83504.55
15	10.37	2.28	50.37	2.36	18.38	9.70	1.45	81956.82
16	10.18	3.56	59.21	2.27	19.38	9.66	1.44	83748.25
17	6.74	2.89	48.68	2.30	18.21	9.65	1.45	81628.48
18	8.20	1.96	55.64	2.21	18.53	9.60	1.45	81155.71
19	6.99	2.88	45.68	2.29	18.84	9.44	1.46	79442.64
20	9.09	4.52	53.57	2.60	18.38	9.56	1.46	81685.86
21	9.81	12.27	37.70	3.33	18.83	8.80	1.45	81817.77
22	10.90	4.95	42.83	5.59	19.52	8.36	1.45	87419.19
23	9.18	2.18	37.87	3.24	18.84	8.83	1.46	84389.39
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.51	3.65	52.38	2.70	18.92	9.59	1.44	83220.02
最大值	11.21	12.27	64.41	5.59	20.75	10.49	1.48	88940.55
發生時間	10	21	6	22	7	0		4
最小值	1.71	1.95	37.70	1.41	17.02	8.36	1.40	79442.64
發生時間	0	8	21	0	10	22		19
零點偏移(率)	-0.26 %	-0.08 %	-0.02 %	-0.02 %		0.00	0.00	-0.10 %
全幅偏移(率)	1.48 %	0.69 %	-0.27 %	0.11 %		0.05	-0.03	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月21日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.01	8.01	47.57	2.32	19.25	10.10	1.38	87580.82
1	10.27	4.89	58.59	2.56	19.38	10.11	1.38	87388.85
2	10.62	4.78	51.97	2.79	18.23	9.97	1.37	86478.11
3	9.44	7.00	53.81	2.74	17.22	10.18	1.38	85579.94
4	12.16	3.60	54.13	3.04	18.24	10.11	1.38	82654.66
5	12.18	7.55	54.89	3.13	18.44	9.89	1.38	85232.20
6	17.12	6.26	55.66	4.37	17.33	10.63	1.38	84718.30
7	8.48	3.40	53.14	2.76	16.92	10.31	1.38	77912.37
8	11.92	2.35	63.69	3.20	17.45	10.48	1.37	83549.66
9	13.60	4.06	56.72	3.67	17.11	10.37	1.37	84251.77
10	7.13	6.63	56.31	4.68	15.24	10.69	1.34	81278.81
11	8.76	5.10	57.63	2.74	16.78	10.65	1.37	79963.52
12	12.22	6.15	51.55	2.68	18.62	9.85	1.37	86139.27
13	9.22	8.96	50.08	2.38	17.60	10.20	1.36	82433.72
14	9.85	2.87	56.62	2.69	19.51	9.73	1.39	85073.82
15	9.87	2.95	53.49	2.65	18.21	10.08	1.40	84253.50
16	9.61	1.79	61.41	2.51	18.38	10.09	1.41	84608.62
17	8.44	4.80	48.38	2.41	18.84	9.85	1.39	85240.44
18	10.47	4.17	49.01	2.77	18.48	9.64	1.38	86669.55
19	11.16	7.52	48.33	2.92	16.40	10.30	1.34	82055.26
20	8.72	2.45	62.91	2.76	18.03	10.09	1.34	82808.09
21	10.09	2.95	49.94	2.91	16.49	10.28	1.36	81204.14
22	12.19	7.65	52.93	3.52	17.00	9.88	1.37	82425.99
23	8.38	2.22	51.86	2.74	17.44	10.11	1.37	82929.12
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.50	4.92	54.19	2.96	17.77	10.15	1.37	83851.27
最大值	17.12	8.96	63.69	4.68	19.51	10.69	1.42	87580.82
發生時間	6	13	8	10	14	10		0
最小值	7.13	1.79	47.57	2.32	15.24	9.64	1.31	77912.37
發生時間	10	16	0	0	10	18		7
零點偏移(率)	-0.01 %	-0.07 %	-0.01 %	-0.02 %		-0.01	0.00	0.00 %
全幅偏移(率)	1.61 %	0.94 %	-0.44 %	0.15 %		-0.11	0.02	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								