

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 115年09月02日

報表日期: 115年09月02日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.22	13.26	57.97	0.73	19.99	11.15	1.15	71366.04
1	9.87	15.23	47.97	2.77	21.42	9.71	1.16	79785.39
2	9.71	12.91	44.21	0.77	21.83	10.39	1.15	75133.60
3	7.05	12.95	62.02	2.16	19.77	10.81	1.15	74103.25
4	3.74	13.93	66.10	1.60	19.59	11.66	1.17	68503.80
5	1.41	14.53	54.30	1.48	19.74	11.93	1.19	62907.85
6	7.66	12.13	40.77	2.15	20.25	10.34	1.18	76279.41
7	9.23	12.58	58.20	2.98	18.72	10.73	1.18	75128.19
8	9.66	13.43	54.83	3.58	16.97	11.39	1.18	72112.32
9	7.57	13.16	63.16	3.41	16.92	11.59	1.18	70531.12
10	7.66	13.33	58.43	3.64	17.00	11.43	1.18	71711.70
11	7.98	14.11	58.32	3.85	16.81	11.54	1.18	71627.09
12	4.15	15.16	56.36	2.40	16.81	11.43	1.18	71711.73
13	8.48	13.69	59.27	3.43	16.22	11.75	1.18	70086.48
14	5.56	13.72	59.75	1.63	16.07	11.74	1.18	70845.65
15	0.24	13.17	62.00	1.83	17.70	11.31	1.18	72759.91
16	6.25	15.01	56.64	2.07	17.61	11.22	1.18	73210.57
17	8.91	13.07	54.04	0.99	18.37	11.22	1.18	72794.28
18	9.96	12.85	56.71	1.31	18.45	11.06	1.18	74313.74
19	9.22	13.42	54.82	1.07	17.78	11.30	1.18	73317.29
20	9.74	13.17	63.89	1.04	17.72	11.34	1.18	72954.80
21	9.41	13.43	56.76	0.97	19.23	10.83	1.18	74741.93
22	9.96	13.04	65.41	0.97	19.31	10.89	1.18	74216.40
23	11.74	12.92	56.45	1.30	18.57	11.02	1.18	73881.30
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.52	13.51	57.02	2.01	18.45	11.16	1.18	72667.66
最 大 值	11.74	15.23	66.10	3.85	21.83	11.93	1.23	79785.39
發生時間	23	1	4	11	2	5		1
最 小 值	0.24	12.13	40.77	0.73	16.07	9.71	1.15	62907.85
發生時間	15	6	6	0	14	1		5
零點偏移(率)	-0.08 %	-0.13 %	-0.07 %	-0.02 %		-0.01	-0.01	0.20 %
全幅偏移(率)	-0.05 %	-0.30 %	-0.12 %	-0.87 %		-0.20	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 115年09月02日

報表日期: 115年09月02日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	9.59	11.74	59.94	1.18	20.63	9.43	1.27	80279.73
1	5.09	11.79	60.22	0.99	20.67	10.00	1.27	79253.70
2	6.36	11.96	54.08	1.02	21.60	10.03	1.27	76907.81
3	6.26	12.14	59.96	2.28	19.79	10.31	1.27	78811.11
4	4.54	12.06	63.10	2.31	19.19	10.41	1.27	79184.91
5	7.85	12.12	63.29	2.34	18.47	10.64	1.27	78687.20
6	9.63	11.99	68.24	2.67	19.57	10.38	1.27	80309.18
7	7.35	13.16	49.19	2.47	18.37	10.74	1.27	78341.81
8	5.29	13.04	58.94	2.28	17.82	10.57	1.23	75137.57
9	10.45	12.87	61.06	2.65	18.31	10.40	1.24	78262.46
10	8.42	13.31	63.68	2.57	17.12	10.77	1.26	75810.37
11	4.84	13.70	60.31	2.57	15.78	10.72	1.20	74151.37
12	8.32	13.34	61.77	2.58	16.43	10.78	1.23	76682.52
13	9.30	12.47	58.56	2.91	18.24	9.98	1.23	76238.28
14	8.35	12.37	58.52	2.35	17.55	10.04	1.23	75309.93
15	7.61	12.73	60.45	2.74	16.43	10.32	1.23	73485.86
16	9.86	12.27	61.41	2.26	18.18	9.88	1.23	76900.76
17	8.48	12.44	60.99	1.14	17.55	9.98	1.21	75615.26
18	10.44	12.83	61.98	1.26	17.59	10.08	1.23	74999.04
19	17.59	13.37	56.50	2.57	15.85	10.47	1.24	73436.55
20	6.09	12.56	55.17	1.29	16.45	10.00	1.25	74233.27
21	8.23	12.59	54.43	1.21	15.77	10.31	1.24	73551.73
22	7.97	12.52	59.25	1.14	16.59	10.30	1.23	73965.91
23	10.34	12.38	57.86	1.23	17.19	10.05	1.23	74805.47
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.26	12.57	59.54	2.00	17.96	10.27	1.24	76431.74
最 大 值	17.59	13.70	68.24	2.91	21.60	10.78	1.27	80309.18
發生時間	19	11	6	13	2	12		6
最 小 值	4.54	11.74	49.19	0.99	15.77	9.43	1.18	73436.55
發生時間	4	0	7	1	21	0		19
零點偏移(率)	-0.14 %	-0.05 %	-0.04 %	0.00 %		-0.03	-0.01	-0.20 %
全幅偏移(率)	1.11 %	0.52 %	0.45 %	0.31 %		0.11	0.04	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								