

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年07月18日

報表日期: 114年07月18日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.51	12.91	58.16	1.75	17.70	11.34	1.29	81258.34
1	3.96	9.49	55.72	2.19	17.33	11.81	1.28	78124.78
2	3.77	9.83	65.78	1.61	17.79	12.21	1.28	74525.12
3	8.46	9.30	52.12	1.48	18.71	11.53	1.29	79023.98
4	7.48	10.18	41.20	3.10	17.35	11.42	1.27	81086.16
5	12.58	10.52	61.90	2.24	17.90	11.80	1.29	77931.98
6	8.94	8.81	61.19	1.61	19.17	10.85	1.29	84620.45
7	8.11	11.10	52.74	2.28	17.38	11.59	1.29	79591.87
8	7.95	9.07	58.47	1.65	18.17	11.39	1.30	80554.52
9	7.11	8.95	58.11	1.70	18.69	11.12	1.29	82521.95
10	6.41	8.95	55.42	2.67	17.09	11.48	1.29	81078.98
11	2.38	9.45	60.75	1.55	17.40	12.03	1.29	76536.03
12	8.70	9.16	55.88	2.99	16.46	11.75	1.29	79367.92
13	7.59	9.30	52.62	3.29	15.69	11.98	1.29	78215.20
14	9.85	9.21	53.19	2.63	16.75	11.76	1.29	79301.33
15	7.69	9.36	54.01	2.74	16.73	11.68	1.29	79984.00
16	5.62	8.86	50.75	3.28	16.01	11.64	1.29	78896.51
17	4.76	8.98	53.02	3.33	15.76	11.74	1.30	78938.79
18	6.28	10.29	51.32	3.39	15.44	11.90	1.30	77437.52
19	5.07	10.13	52.64	3.38	15.15	11.94	1.29	77025.03
20	8.98	9.56	61.14	3.51	15.46	12.01	1.29	77395.78
21	9.02	9.39	46.69	2.56	16.27	11.74	1.29	79558.73
22	7.10	10.30	51.23	2.78	15.64	11.94	1.29	78430.59
23	9.20	11.72	49.44	3.23	15.73	11.84	1.29	78784.63
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.35	9.78	54.73	2.54	16.91	11.69	1.29	79174.59
最 大 值	12.58	12.91	65.78	3.51	19.17	12.21	1.30	84620.45
發生時間	5	0	2	20	6	2		6
最 小 值	2.38	8.81	41.20	1.48	15.15	10.85	1.25	74525.12
發生時間	11	6	4	3	19	6		2
零點偏移(率)	-0.06 %	0.01 %	-0.01 %	-0.01 %		-0.16		0.10 %
全幅偏移(率)	0.00 %	0.43 %	-0.18 %	0.50 %		-0.24		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年07月18日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	9.83	10.52	49.86	1.60	19.69	8.75	1.43	79773.87
1	10.87	12.29	56.56	1.38	20.47	9.11	1.43	81568.37
2	6.57	13.02	55.90	1.36	19.04	9.38	1.43	81984.82
3	12.89	7.78	54.54	1.45	17.33	9.65	1.43	79552.48
4	6.55	7.46	57.47	1.95	17.16	9.49	1.47	78346.64
5	8.46	7.86	55.07	1.91	16.89	9.55	1.48	77140.69
6	7.42	7.34	60.68	1.87	17.76	9.45	1.48	78449.88
7	7.02	8.22	52.53	2.34	16.26	10.11	1.43	75573.33
8	8.78	8.18	55.35	1.98	17.03	10.16	1.45	76388.11
9	7.87	10.26	52.82	1.99	15.36	10.48	1.41	74588.47
10	10.28	9.89	51.86	2.05	16.06	9.80	1.38	73403.23
11	8.73	8.76	56.57	0.79	18.49	9.13	1.38	72953.20
12	9.33	8.74	60.30	1.05	19.08	8.99	1.39	76170.37
13	2.88	9.02	55.83	1.48	17.82	9.15	1.39	76365.51
14	2.76	7.02	59.09	1.59	17.31	9.51	1.39	75059.55
15	4.42	7.97	58.15	2.05	17.55	9.67	1.43	75372.72
16	3.49	6.34	49.89	1.72	18.38	8.80	1.39	75009.26
17	6.52	9.41	50.41	2.09	18.43	8.70	1.42	76485.91
18	1.57	9.14	51.37	1.57	18.50	9.26	1.44	76694.22
19	1.03	6.68	56.27	1.30	18.65	8.96	1.43	78850.60
20	5.15	9.93	45.74	4.35	20.14	8.28	1.43	80196.37
21	5.84	10.34	46.28	1.78	18.26	8.33	1.43	76943.41
22	7.83	9.79	53.67	1.34	17.34	9.04	1.43	76602.22
23	6.96	6.66	51.36	1.91	16.59	9.65	1.41	72990.72
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.79	8.86	54.07	1.79	17.90	9.31	1.42	76936.00
最 大 值	12.89	13.02	60.68	4.35	20.47	10.48	1.49	81984.82
發生時間	3	2	6	20	1	9		2
最 小 值	1.03	6.34	45.74	0.79	15.36	8.28	1.38	72953.20
發生時間	19	16	20	11	9	20		11
零點偏移(率)	-0.01 %	-0.05 %	-0.09 %	-0.01 %		-0.21		-0.20 %
全幅偏移(率)	0.14 %	0.02 %	0.04 %	0.42 %		0.11		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								