

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 115年01月04日

[illegible]

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 115年01月04日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.58	11.09	38.09	1.50	17.36	9.63	1.06	76903.75
1	3.89	12.26	56.30	2.66	16.96	10.31	1.06	78184.75
2	8.75	11.37	55.92	1.69	16.98	10.21	1.06	79989.26
3	8.15	11.99	62.68	1.69	16.26	10.88	1.08	79459.69
4	9.68	12.24	56.21	2.07	15.09	11.20	1.09	79163.52
5	10.75	12.03	58.24	1.95	15.49	11.01	1.09	78255.88
6	5.80	12.33	48.36	2.47	14.65	11.27	1.08	75077.00
7	11.83	13.94	57.55	3.78	13.84	11.71	1.07	76507.33
8	10.93	12.50	50.22	2.59	15.39	11.23	1.08	78938.17
9	11.50	12.17	52.31	1.98	16.39	10.91	1.09	77674.32
10	11.16	11.94	49.14	2.12	16.51	10.70	1.08	78069.49
11	8.42	12.00	47.37	1.84	16.72	10.37	1.08	80456.55
12	8.97	11.85	50.56	2.75	15.82	10.65	1.08	79505.11
13	9.82	13.15	44.03	2.62	16.56	9.94	1.09	78699.68
14	11.33	11.56	41.79	2.20	16.75	10.24	1.07	79154.65
15	11.67	11.50	38.81	2.47	16.51	10.20	1.07	78698.26
16	8.16	11.96	45.93	1.92	16.47	10.68	1.08	74780.49
17	11.56	12.01	46.25	2.33	17.02	10.67	1.07	75585.14
18	9.30	11.46	42.89	1.72	17.30	10.16	1.06	80092.09
19	11.99	11.42	40.98	1.83	17.40	10.09	1.08	80740.40
20	13.17	13.90	49.04	1.05	19.24	9.72	1.07	83918.05
21	12.11	12.04	41.38	2.21	16.86	10.37	1.06	79079.59
22	9.59	12.58	51.06	2.22	16.74	11.09	1.06	77507.83
23	11.20	12.00	53.42	2.61	16.12	10.73	1.07	79170.41
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.76	12.14	49.11	2.18	16.43	10.58	1.07	78567.14
最 大 值	13.17	13.94	62.68	3.78	19.24	11.71	1.10	83918.05
發生時間	20	7	3	7	20	7		20
最 小 值	3.89	11.09	38.09	1.05	13.84	9.63	1.05	74780.49
發生時間	1	0	0	20	7	0		16
零點偏移(率)	-0.10 %	-0.03 %	-0.05 %	-0.01 %		-0.03	-0.01	0.10 %
全幅偏移(率)	-0.66 %	-0.26 %	-0.78 %	-1.60 %		0.00	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 115年01月04日

報表日期: 115年01月04日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.43	13.65	59.69	2.45	14.34	11.28	1.36	67434.36
1	11.57	12.91	60.39	1.22	16.59	10.53	1.37	75323.45
2	12.28	12.86	56.23	1.48	15.28	10.60	1.36	73748.88
3	12.27	13.01	55.70	1.44	15.57	10.69	1.36	74095.95
4	11.01	13.10	53.79	1.34	14.91	10.87	1.37	72879.50
5	12.05	13.25	58.66	1.28	14.81	11.02	1.36	73606.28
6	11.60	13.10	62.37	1.54	14.89	11.01	1.38	72551.30
7	6.28	11.93	46.90	3.11	15.08	10.96	1.39	68401.51
8	9.34	12.23	48.27	3.98	14.22	10.84	1.40	72545.46
9	11.82	11.88	52.69	1.27	15.08	10.27	1.40	73458.45
10	10.96	12.17	47.48	2.27	16.04	9.88	1.41	73531.26
11	12.12	11.77	44.82	2.85	15.47	9.88	1.40	71838.54
12	8.24	10.63	41.92	3.50	15.57	9.79	1.38	71387.68
13	1.28	12.26	46.28	1.72	15.69	10.13	1.37	70734.97
14	2.35	12.56	46.90	2.37	14.54	10.56	1.39	66840.90
15	10.18	12.76	43.66	1.48	15.25	10.07	1.36	69295.60
16	12.22	13.42	49.57	0.84	15.90	10.29	1.37	70322.40
17	11.16	12.19	49.34	2.29	15.50	10.28	1.36	70346.23
18	11.84	11.60	53.09	2.53	16.04	10.38	1.36	69965.17
19	11.77	11.75	44.01	2.56	16.40	9.87	1.37	72955.81
20	10.28	16.04	35.00	2.61	16.60	9.27	1.36	73840.16
21	12.06	15.30	29.28	3.74	17.63	9.00	1.37	72550.88
22	12.05	12.49	29.98	2.36	19.11	8.59	1.36	73001.28
23	12.13	12.21	50.70	1.55	18.35	9.26	1.37	73106.09
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.35	12.71	48.61	2.16	15.79	10.22	1.37	71823.42
最 大 值	12.28	16.04	62.37	3.98	19.11	11.28	1.43	75323.45
發生時間	2	20	6	8	22	0		1
最 小 值	1.28	10.63	29.28	0.84	14.22	8.59	1.36	66840.90
發生時間	13	12	21	16	8	22		14
零點偏移(率)	-0.11 %	-0.04 %	-0.02 %	0.00 %		-0.06	-0.01	0.00 %
全幅偏移(率)	1.33 %	-1.69 %	0.56 %	-0.36 %		0.14	0.04	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								