

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月15日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.83	6.60	47.88	3.41	14.40	12.76	1.33	66381.45
1	8.65	7.71	58.30	3.37	14.77	12.90	1.31	64900.68
2	10.43	3.97	55.96	3.58	14.95	12.27	1.32	69688.70
3	10.41	5.67	58.03	4.59	13.25	12.61	1.36	68597.24
4	9.67	6.74	56.05	4.19	13.70	12.64	1.37	68424.77
5	11.02	5.22	57.01	4.24	13.62	12.62	1.37	67148.39
6	8.81	8.22	55.22	4.36	13.18	12.77	1.38	66631.44
7	10.41	4.08	53.76	4.21	13.59	12.47	1.39	69993.00
8	10.37	8.35	51.57	4.97	12.45	12.99	1.36	66276.46
9	10.19	4.50	55.12	4.44	13.13	12.74	1.36	67387.40
10	10.43	3.20	57.20	3.81	14.04	12.55	1.38	68333.96
11	11.30	6.93	48.62	4.61	12.94	12.78	1.39	66941.57
12	11.79	6.47	52.29	4.87	12.96	12.77	1.37	66862.84
13	10.94	11.35	53.38	6.12	12.22	13.24	1.35	63237.90
14	11.57	2.92	51.89	4.15	13.67	12.60	1.38	67784.10
15	9.62	6.08	43.84	4.98	12.06	12.90	1.40	66261.77
16	11.61	7.13	42.92	6.12	11.50	12.87	1.40	67145.04
17	9.04	3.47	52.92	4.74	13.10	12.76	1.35	66658.32
18	11.18	2.15	48.03	4.44	12.92	12.43	1.38	70319.29
19	9.93	3.63	47.29	4.77	13.36	12.65	1.40	67365.32
20	10.12	2.06	62.77	4.10	13.61	12.86	1.38	65767.34
21	9.68	1.94	60.22	3.21	14.75	12.09	1.35	71295.56
22	9.46	2.45	47.26	3.93	13.65	12.63	1.33	67546.30
23	10.41	2.02	53.39	3.67	14.00	12.57	1.34	68111.88
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.24	5.12	52.96	4.37	13.41	12.69	1.36	67460.86
最大值	11.79	11.35	62.77	6.12	14.95	13.24	1.42	71295.56
發生時間	12	13	20	13	2	13		21
最小值	8.65	1.94	42.92	3.21	11.50	12.09	1.30	63237.90
發生時間	1	21	16	21	16	21		13
零點偏移(率)	-0.01 %	-0.02 %	-0.03 %	0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	1.57 %	-0.02 %	-0.09 %	0.01 %		0.08	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月15日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.76	4.07	50.25	1.97	18.03	10.54	1.40	84921.12
1	9.49	9.44	45.05	4.43	17.17	10.63	1.39	80476.70
2	9.75	5.38	35.65	3.31	17.37	10.22	1.37	78455.84
3	10.25	5.16	47.44	3.79	15.51	10.41	1.37	80157.70
4	10.09	3.95	42.87	3.24	16.19	10.10	1.38	78914.91
5	10.58	6.97	44.83	3.12	16.61	9.99	1.40	80836.81
6	3.93	4.80	36.72	2.59	14.68	10.12	1.39	72813.46
7	9.88	5.78	42.14	2.88	15.05	10.31	1.38	78361.10
8	10.67	3.46	47.64	2.77	16.53	10.20	1.38	81996.51
9	9.68	3.41	45.75	2.92	15.40	10.49	1.42	80031.07
10	10.33	3.34	43.55	2.68	16.28	10.31	1.40	80850.47
11	11.40	6.98	45.71	3.78	14.92	10.49	1.41	79511.47
12	12.50	9.98	52.47	4.27	14.66	10.63	1.38	80025.34
13	9.33	2.30	50.09	3.00	16.05	10.09	1.39	81472.50
14	11.28	3.48	49.26	3.91	14.46	10.46	1.40	78991.15
15	11.67	2.78	53.37	5.46	15.10	10.28	1.41	80782.60
16	10.31	3.17	46.63	3.55	15.59	10.25	1.41	83996.03
17	10.20	2.11	39.71	3.00	16.05	10.10	1.38	82972.55
18	10.10	1.79	39.87	2.89	16.35	9.98	1.36	81893.62
19	9.75	2.35	38.54	2.54	17.11	9.68	1.39	83881.11
20	9.21	2.20	42.73	2.67	16.31	10.66	1.42	82694.30
21	11.30	2.44	47.02	3.24	15.02	10.65	1.40	82631.70
22	11.34	2.36	46.60	3.34	15.16	10.49	1.38	81043.72
23	9.97	2.35	45.10	2.27	18.36	9.61	1.37	85716.89
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.12	4.17	44.96	3.23	16.00	10.28	1.39	80976.19
最大值	12.50	9.98	53.37	5.46	18.36	10.66	1.44	85716.89
發生時間	12	12	15	15	23	20		23
最小值	3.93	1.79	35.65	1.97	14.46	9.61	1.36	72813.46
發生時間	6	18	2	0	14	23		6
零點偏移(率)	-0.02 %	-0.02 %	-0.01 %	0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	0.51 %	0.44 %	-0.30 %	0.13 %		0.03	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月15日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.11	2.21	51.89	1.54	16.56	10.86	1.38	86340.58
1	7.96	2.42	53.99	2.08	15.40	11.32	1.38	83442.13
2	9.84	3.52	47.64	4.08	14.74	11.01	1.38	83480.98
3	9.35	1.30	55.87	1.96	16.75	10.77	1.38	86562.63
4	9.75	1.57	56.48	2.33	15.19	11.22	1.38	84301.33
5	9.71	3.52	50.10	3.01	13.80	11.35	1.38	80985.77
6	9.21	2.47	52.80	3.00	14.23	11.41	1.38	80321.64
7	10.18	1.33	46.45	2.56	14.80	10.91	1.36	86436.64
8	11.25	1.75	50.69	2.55	15.08	11.07	1.37	82594.06
9	9.83	2.29	49.10	2.67	14.37	11.11	1.38	81791.06
10	8.78	5.06	49.32	2.73	14.20	11.25	1.40	80262.61
11	9.49	4.74	51.96	2.58	14.41	11.28	1.39	80564.25
12	11.60	10.96	52.42	3.80	13.28	11.40	1.38	79579.99
13	9.78	3.70	46.95	2.72	14.44	11.14	1.38	79610.26
14	12.90	5.59	47.96	4.57	13.14	11.58	1.39	79227.58
15	11.33	6.51	41.38	7.19	12.90	11.91	1.37	78776.01
16	10.92	4.95	47.34	4.56	13.96	11.28	1.37	82718.92
17	9.82	2.09	53.09	2.17	15.47	11.00	1.37	83557.38
18	10.30	3.44	49.60	2.35	14.80	11.09	1.38	84282.09
19	10.32	7.53	52.33	3.18	13.88	11.29	1.38	80791.12
20	10.81	5.96	54.25	3.33	13.19	11.58	1.38	81705.29
21	11.17	3.68	48.67	2.98	13.44	11.12	1.38	83547.90
22	9.45	7.94	48.42	3.18	13.65	11.06	1.38	80874.27
23	10.65	8.67	46.57	3.81	12.82	11.07	1.38	79727.62
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.15	4.30	50.22	3.12	14.35	11.21	1.38	82145.09
最大值	12.90	10.96	56.48	7.19	16.75	11.91	1.41	86562.63
發生時間	14	12	4	15	3	15		3
最小值	7.96	1.30	41.38	1.54	12.82	10.77	1.34	78776.01
發生時間	1	3	15	0	23	3		15
零點偏移(率)	-0.01 %	-0.02 %	-0.12 %	-0.02 %		0.01	0.00	0.00 %
全幅偏移(率)	0.61 %	0.17 %	-0.50 %	0.14 %		0.14	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								