

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年12月31日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.36	11.62	67.10	1.02	16.70	11.50	1.09	82676.38
1	8.14	12.46	52.23	1.46	16.64	11.46	1.10	82673.31
2	9.39	14.71	52.86	2.04	15.34	11.88	1.10	80727.51
3	8.57	13.29	56.24	2.10	14.65	12.08	1.08	79714.00
4	9.26	14.13	56.96	1.70	15.40	11.55	1.07	83408.18
5	2.73	12.47	51.28	3.04	14.65	11.82	1.05	82877.42
6	6.80	12.48	60.22	1.21	16.38	11.77	1.05	80805.23
7	9.67	12.70	50.12	2.68	14.38	11.93	1.03	80725.46
8	9.19	11.26	56.88	2.08	15.25	11.99	1.04	79577.68
9	9.18	11.02	54.07	1.27	16.12	11.58	1.06	82290.02
10	8.21	12.85	46.91	1.85	14.80	12.04	1.09	79502.41
11	8.23	11.03	53.67	1.08	16.64	11.61	1.06	81542.49
12	5.66	11.76	67.12	0.77	16.76	12.14	1.09	77034.85
13	9.33	10.33	43.83	1.33	16.78	10.97	1.08	87096.48
14	8.04	10.60	53.50	1.25	16.21	11.62	1.06	82506.87
15	9.58	11.24	59.80	0.86	17.08	11.53	1.10	82306.67
16	8.36	12.12	48.01	1.46	16.86	11.39	1.11	83959.77
17	8.54	11.43	49.39	1.56	16.17	11.56	1.08	83187.99
18	4.94	12.21	57.39	0.84	17.06	12.12	1.06	77357.15
19	5.52	12.03	49.40	0.68	19.83	10.04	1.06	91182.66
20	8.75	5.48	56.97	1.30	16.18	11.19	1.06	85032.55
21	6.94	9.91	68.91	0.67	18.14	11.09	1.06	84953.90
22	8.39	10.40	42.49	1.23	16.41	11.06	1.06	86789.14
23	9.23	12.72	57.53	1.31	17.57	11.19	1.06	84978.04
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.88	11.68	54.70	1.45	16.33	11.55	1.07	82621.09
最大值	9.67	14.71	68.91	3.04	19.83	12.14	1.12	91182.66
發生時間	7	2	21	5	19	12		19
最小值	2.73	5.48	42.49	0.67	14.38	10.04	1.02	77034.85
發生時間	5	20	22	21	7	19		12
零點偏移(率)	-0.08 %	0.01 %	-0.00 %	-0.00 %		-0.04		0.10 %
全幅偏移(率)	0.02 %	0.03 %	0.03 %	0.02 %		-0.12		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年12月31日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.22	8.75	44.29	1.95	16.99	10.54	1.06	83646.11
1	7.57	8.76	46.74	2.57	16.24	10.91	1.07	81608.58
2	6.76	8.03	45.72	3.72	14.16	11.19	1.08	80428.18
3	7.60	4.40	54.86	3.05	14.66	11.13	1.07	82426.25
4	7.14	4.75	51.26	1.99	16.03	10.90	1.06	83365.34
5	8.45	5.47	49.66	2.84	15.17	10.95	1.06	83745.49
6	5.38	4.85	46.95	3.17	14.33	11.04	1.05	79504.90
7	6.67	5.70	43.16	3.26	15.54	10.73	1.04	83649.69
8	8.25	3.13	40.27	2.12	16.91	10.39	1.05	85325.45
9	6.15	2.58	49.08	1.95	16.26	11.11	1.07	79378.70
10	2.73	2.47	62.48	1.46	16.55	11.03	1.07	81749.22
11	5.81	4.34	37.39	2.19	15.41	10.69	1.06	83241.48
12	5.83	2.41	43.95	2.40	14.90	11.09	1.08	81631.80
13	0.91	3.01	56.63	2.70	14.22	11.97	1.07	75011.01
14	2.90	2.95	47.97	2.50	15.22	11.23	1.05	80925.64
15	3.64	2.08	51.12	1.87	15.94	11.01	1.04	82366.82
16	4.50	2.30	43.25	2.44	14.92	10.95	1.07	82924.90
17	5.57	2.24	44.40	2.10	16.15	10.64	1.07	85496.31
18	5.16	4.80	52.07	1.63	17.77	10.29	1.06	85137.25
19	4.69	2.02	41.80	2.03	15.75	10.74	1.06	80495.72
20	2.35	3.44	54.54	1.18	18.24	10.25	1.06	86886.00
21	4.69	3.27	43.90	2.27	16.01	10.33	1.05	86206.51
22	1.10	2.39	53.87	1.39	16.54	10.87	1.04	82714.53
23	0.34	3.10	45.20	1.29	16.75	10.57	1.03	85059.68
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.98	4.05	47.94	2.25	15.86	10.86	1.06	82621.90
最大值	8.45	8.76	62.48	3.72	18.24	11.97	1.10	86886.00
發生時間	5	1	10	2	20	13		20
最小值	0.34	2.02	37.39	1.18	14.16	10.25	1.02	75011.01
發生時間	23	19	11	20	2	20		13
零點偏移(率)	-0.06 %	-0.10 %	-0.01 %	0.00 %		-0.01		0.00 %
全幅偏移(率)	0.02 %	0.64 %	-0.19 %	0.03 %		-0.18		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年12月31日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.60	2.83	45.95	1.07	16.06	10.12	0.95	75056.50
1	4.96	5.60	41.68	1.18	16.78	9.60	0.94	80398.47
2	8.91	8.77	44.37	2.23	14.80	10.25	0.93	76605.97
3	12.07	7.14	45.05	2.27	15.21	10.08	0.94	78652.53
4	14.54	4.77	40.58	3.42	14.90	9.98	0.93	75329.92
5	5.94	5.09	46.17	1.02	17.30	9.66	0.92	77617.19
6	9.99	6.17	37.54	2.32	16.21	9.59	0.93	79625.16
7	9.42	3.20	42.28	1.48	15.67	10.10	0.94	73780.99
8	14.38	4.57	40.58	2.09	16.40	9.46	0.94	78440.08
9	2.67	0.53	44.50	0.80	17.26	9.93	0.94	74476.19
10	2.13	2.05	34.72	0.77	17.90	9.26	0.97	78321.45
11	1.25	1.16	46.36	0.55	16.02	10.54	0.96	70908.11
12	0.40	1.05	40.56	0.71	15.99	9.75	0.93	74798.62
13	7.68	2.27	36.00	1.64	16.07	9.49	0.93	76242.32
14	2.51	2.41	35.78	2.95	17.57	9.52	0.94	76380.45
15	1.74	3.87	44.21	0.85	16.81	10.07	0.93	72775.60
16	3.08	4.04	40.10	0.69	18.39	9.16	0.93	80857.94
17	2.89	1.72	49.75	1.24	16.28	9.75	0.94	80683.79
18	1.99	4.42	43.62	0.88	15.69	10.43	0.92	73363.38
19	3.18	2.16	53.63	0.84	16.60	10.05	0.92	78645.92
20	3.63	7.42	56.25	0.86	16.17	10.47	0.93	75698.30
21	2.57	6.31	51.29	1.08	16.34	9.94	0.95	80874.95
22	1.01	10.27	50.65	0.77	15.89	10.39	0.93	74998.52
23	0.86	8.01	49.25	0.78	15.43	10.53	0.92	71913.69
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.10	4.41	44.20	1.35	16.32	9.92	0.93	76518.59
最大值	14.54	10.27	56.25	3.42	18.39	10.54	0.99	80874.95
發生時間	4	22	20	4	16	11		21
最小值	0.40	0.53	34.72	0.55	14.80	9.16	0.91	70908.11
發生時間	12	9	10	11	2	16		11
零點偏移(率)	-0.02 %	-0.07 %	-0.05 %	0.00 %		0.01		0.20 %
全幅偏移(率)	0.17 %	-0.08 %	-0.20 %	-0.00 %		0.00		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								