

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月05日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.38	2.83	56.39	3.30	14.20	12.52	1.44	68998.53
1	4.25	1.62	63.36	2.70	15.48	12.21	1.43	70155.19
2	5.53	1.80	56.58	2.72	16.17	12.24	1.43	69476.33
3	5.56	1.72	63.08	3.45	14.32	12.40	1.41	69906.79
4	7.01	3.94	58.70	3.82	13.89	12.53	1.40	68776.22
5	8.22	10.28	60.10	4.43	13.13	12.65	1.39	67666.25
6	6.99	3.51	64.77	3.90	14.18	12.45	1.40	68940.81
7	10.08	7.76	58.25	3.99	14.10	12.29	1.38	69874.49
8	9.74	2.27	57.80	4.07	14.23	12.38	1.38	68986.69
9	11.94	4.40	57.09	4.29	13.75	12.37	1.39	69541.27
10	9.54	4.23	55.72	4.11	14.01	12.37	1.41	69157.78
11	6.39	2.90	60.26	3.39	14.91	12.16	1.42	70256.41
12	5.70	2.87	63.92	3.49	14.26	12.28	1.45	69593.10
13	5.06	6.77	59.35	4.08	13.60	12.86	1.46	67058.95
14	5.46	3.72	58.25	5.20	12.54	13.43	1.43	67862.04
15	8.80	3.88	72.63	3.87	14.64	12.64	1.42	68802.33
16	9.24	1.77	62.21	3.50	14.82	12.30	1.44	70837.81
17	7.04	1.89	62.49	3.08	15.19	12.29	1.41	70177.81
18	5.37	3.12	68.61	3.26	14.47	12.48	1.39	69383.58
19	0.91	2.34	60.98	2.35	16.18	12.11	1.45	71117.45
20	1.03	2.46	54.01	2.23	16.62	11.74	1.43	73362.45
21	2.06	2.68	61.37	2.72	15.64	12.48	1.44	68695.11
22	1.45	2.08	62.84	2.32	16.37	11.79	1.44	73342.35
23	4.96	3.36	55.84	3.12	15.09	12.07	1.46	71615.99
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.99	3.51	60.61	3.47	14.66	12.38	1.42	69732.74
最大值	11.94	10.28	72.63	5.20	16.62	13.43	1.46	73362.45
發生時間	9	5	15	14	20	14		20
最小值	0.91	1.62	54.01	2.23	12.54	11.74	1.37	67058.95
發生時間	19	1	20	20	14	20		13
零點偏移(率)	0.00 %	-0.02 %	-0.01 %	-0.00 %		-0.04	0.00	0.00 %
全幅偏移(率)	2.52 %	0.48 %	-0.61 %	0.33 %		0.17	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月05日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.43	5.89	56.31	0.94	18.95	9.27	1.39	63223.64
1	3.79	2.22	50.77	0.92	19.48	9.31	1.39	64261.19
2	2.35	1.07	46.51	0.90	19.63	9.51	1.38	63308.57
3	3.94	1.30	47.54	1.42	18.16	9.90	1.38	61258.42
4	4.92	0.74	51.80	1.48	18.21	9.74	1.38	61984.16
5	10.15	5.23	45.57	2.00	17.97	9.49	1.38	64047.45
6	1.04	3.82	50.68	1.32	17.64	10.08	1.40	63595.56
7	5.44	5.10	59.98	1.75	16.39	10.47	1.41	66896.32
8	4.70	1.75	70.42	1.67	16.95	10.94	1.41	61012.52
9	1.89	1.05	47.66	1.26	18.19	10.45	1.41	65065.21
10	3.85	0.88	62.01	1.31	18.43	10.39	1.43	65504.59
11	3.73	0.93	66.91	1.40	17.76	10.60	1.43	65207.58
12	1.69	1.90	59.53	1.35	18.06	10.68	1.42	61993.80
13	0.09	3.45	49.91	1.06	18.53	10.02	1.39	62118.10
14	2.23	2.34	58.67	1.32	18.70	9.70	1.38	63998.44
15	6.08	3.78	56.61	1.72	18.20	10.04	1.38	62357.13
16	9.77	1.48	58.39	1.96	17.35	10.28	1.39	61666.56
17	6.55	1.08	65.72	1.24	18.62	10.07	1.42	62658.15
18	3.40	0.95	54.18	1.00	18.83	10.12	1.39	63528.75
19	2.22	1.17	59.18	1.21	18.55	10.86	1.38	58850.23
20	0.09	1.08	68.40	1.15	18.35	11.58	1.39	55699.41
21	0.53	1.06	44.88	0.90	19.20	10.25	1.39	65736.49
22	1.59	3.42	63.16	0.81	19.86	10.17	1.40	65770.96
23	4.50	4.27	57.05	1.43	18.68	9.95	1.40	63789.17
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.62	2.33	56.33	1.31	18.36	10.16	1.40	63063.85
最大值	10.15	5.89	70.42	2.00	19.86	11.58	1.44	66896.32
發生時間	5	0	8	5	22	20		7
最小值	0.09	0.74	44.88	0.81	16.39	9.27	1.38	55699.41
發生時間	13	4	21	22	7	0		20
零點偏移(率)	0.00 %	-0.00 %	0.00 %	-0.02 %		-0.08	0.00	0.00 %
全幅偏移(率)	1.98 %	0.06 %	-0.23 %	0.22 %		-0.04	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月05日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.31	2.08	55.89	1.21	17.91	10.31	1.74	81658.99
1	2.96	5.16	60.55	1.26	17.94	10.65	1.76	84092.03
2	9.41	1.54	55.67	1.91	17.95	10.62	1.75	82033.09
3	7.58	1.69	56.07	1.99	16.63	10.67	1.77	83353.74
4	6.32	3.48	59.63	1.88	16.84	10.62	1.79	84482.79
5	8.01	6.80	56.18	2.05	16.12	10.78	1.79	84347.96
6	7.82	2.91	64.47	2.30	15.49	11.08	1.80	83494.56
7	3.13	2.23	60.11	1.63	16.24	10.93	1.79	81007.53
8	4.30	2.51	62.37	1.73	16.30	11.09	1.79	85910.59
9	6.19	2.77	57.92	1.71	17.67	10.61	1.80	88080.46
10	7.00	3.55	57.66	2.17	16.48	10.82	1.79	85484.99
11	7.80	2.04	58.78	2.12	16.79	10.77	1.80	86131.79
12	6.65	2.14	61.59	2.04	16.67	10.77	1.80	86691.50
13	10.67	10.06	61.56	3.27	15.58	10.87	1.80	84423.22
14	10.40	1.59	65.55	2.23	16.57	11.03	1.80	83959.34
15	12.69	7.79	65.79	2.58	17.25	10.73	1.81	84547.09
16	8.99	1.56	66.70	2.12	17.18	10.61	1.80	83922.51
17	9.32	1.37	62.43	1.99	16.63	10.70	1.78	85378.10
18	7.92	4.01	67.77	1.85	17.20	10.74	1.79	86136.13
19	3.47	2.52	66.27	1.48	18.51	10.89	1.80	85189.43
20	1.63	2.02	61.56	1.39	18.36	10.77	1.79	85318.73
21	2.96	4.25	65.24	1.51	18.74	10.58	1.79	88876.81
22	5.50	1.83	62.36	1.67	18.11	10.62	1.79	88586.60
23	7.58	3.21	60.84	1.94	16.91	10.57	1.78	86929.32
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.65	3.30	61.37	1.92	17.09	10.74	1.79	85001.55
最大值	12.69	10.06	67.77	3.27	18.74	11.09	1.82	88876.81
發生時間	15	13	18	13	21	8		21
最小值	1.31	1.37	55.67	1.21	15.49	10.31	1.74	81007.53
發生時間	0	17	2	0	6	0		7
零點偏移(率)	0.00 %	-0.03 %	-0.02 %	-0.01 %		0.00	0.00	0.00 %
全幅偏移(率)	0.49 %	0.05 %	-0.41 %	0.06 %		0.13	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								