

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年09月15日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.35	14.75	61.30	1.70	16.11	12.44	1.23	73090.94
1	7.26	13.04	46.55	2.03	18.21	11.08	1.20	82578.84
2	12.95	13.10	55.34	3.26	15.67	11.47	1.21	80299.78
3	15.12	13.20	61.55	3.74	14.77	11.63	1.21	80008.51
4	4.51	13.05	60.15	2.66	16.23	11.38	1.20	81572.20
5	17.02	15.01	60.23	3.48	14.42	11.58	1.22	79390.57
6	13.80	15.66	62.22	2.70	14.80	11.62	1.23	80995.90
7	2.27	15.79	59.29	2.98	14.27	11.88	1.21	78246.80
8	4.70	16.39	55.80	3.41	14.95	11.68	1.22	77901.46
9	5.19	16.26	49.87	3.38	15.63	11.59	1.20	75712.18
10	16.64	10.17	52.76	4.98	14.47	11.71	1.19	76639.55
11	4.31	8.78	64.77	4.61	13.46	11.99	1.19	77640.11
12	4.11	8.58	39.26	4.01	13.71	11.72	1.19	74295.77
13	6.79	12.81	56.38	3.78	15.06	11.71	1.19	75374.54
14	12.78	14.94	56.86	4.01	13.81	11.86	1.19	75435.53
15	3.37	12.22	54.72	2.53	13.40	12.16	1.19	74433.98
16	0.18	12.07	60.04	2.11	16.22	11.74	1.20	79051.44
17	4.47	11.96	59.44	2.25	16.78	11.18	1.21	83550.23
18	10.13	11.79	55.98	3.14	15.44	11.61	1.21	80822.56
19	10.70	11.72	55.29	3.34	15.29	11.54	1.23	81262.39
20	7.14	12.31	61.78	3.15	15.02	11.68	1.24	79986.31
21	9.42	12.00	64.49	3.16	15.14	11.70	1.22	80039.49
22	11.49	11.99	55.78	3.24	15.13	11.78	1.20	79239.51
23	9.91	12.60	55.92	3.16	15.20	11.49	1.22	81297.25
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.19	12.92	56.91	3.20	15.13	11.68	1.21	78702.74
最 大 值	17.02	16.39	64.77	4.98	18.21	12.44	1.24	83550.23
發生時間	5	8	11	10	1	0		17
最 小 值	0.18	8.58	39.26	1.70	13.40	11.08	1.18	73090.94
發生時間	16	12	12	0	15	1		0
零點偏移(率)	-0.01 %	-0.01 %	-0.02 %	-0.01 %		0.03		0.20 %
全幅偏移(率)	0.00 %	1.13 %	-0.49 %	-0.23 %		0.07		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年09月15日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.93	12.01	63.09	1.37	16.34	11.49	1.02	77597.51
1	2.97	11.65	48.74	2.09	17.05	11.23	1.02	78963.61
2	2.81	10.84	44.43	1.64	17.49	10.21	1.01	77821.25
3	3.18	10.92	50.97	1.52	17.55	9.92	0.99	77440.97
4	3.59	13.52	49.54	1.75	17.11	9.94	0.98	79027.64
5	4.03	14.63	64.75	2.02	15.34	11.04	0.97	78341.06
6	8.29	12.19	56.80	2.16	15.87	11.13	0.99	76799.07
7	10.07	12.33	49.67	2.27	15.67	11.03	1.00	80953.01
8	4.91	13.08	50.54	2.46	14.61	11.50	1.02	80156.67
9	3.42	12.93	57.42	1.75	15.88	11.47	1.01	79156.87
10	2.95	12.62	53.41	1.82	15.25	11.31	1.02	80269.65
11	1.89	13.80	49.38	1.99	14.76	12.09	1.02	72051.97
12	2.05	13.58	63.97	1.55	16.89	10.86	1.01	83351.24
13	2.74	15.45	51.40	2.61	16.39	11.22	0.99	77496.86
14	2.58	13.95	56.64	2.54	14.98	11.57	0.99	75004.11
15	2.50	12.52	66.71	1.56	17.13	10.95	0.98	78395.11
16	2.85	12.76	47.36	1.77	16.83	11.21	0.98	77927.37
17	2.71	12.61	50.33	1.69	16.60	11.15	0.99	79407.43
18	2.68	12.86	47.93	1.81	16.26	11.07	1.00	80485.81
19	2.59	12.06	50.57	1.31	17.48	10.27	0.99	79369.06
20	3.19	11.86	56.20	1.44	17.94	10.11	1.00	78578.04
21	3.31	13.12	58.90	1.43	17.82	10.05	1.00	82635.69
22	3.13	12.83	57.43	1.93	15.90	11.20	0.99	78498.92
23	2.32	13.65	58.59	2.08	15.51	11.80	0.99	74661.72
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	3.49	12.82	54.37	1.86	16.36	10.99	1.00	78516.28
最 大 值	10.07	15.45	66.71	2.61	17.94	12.09	1.05	83351.24
發生時間	7	13	15	13	20	11		12
最 小 值	1.89	10.84	44.43	1.31	14.61	9.92	0.97	72051.97
發生時間	11	2	2	19	8	3		11
零點偏移(率)	-0.07 %	-0.02 %	-0.02 %	0.00 %		-0.04		0.00 %
全幅偏移(率)	0.14 %	0.70 %	0.23 %	0.30 %		-0.22		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

