

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年11月04日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.67	3.06	57.93	0.32	21.06	10.49	1.10	88465.73
1	10.47	7.66	36.99	0.74	21.96	9.85	1.09	92416.23
2	11.12	3.01	48.04	1.40	18.66	11.20	1.09	84894.40
3	9.86	6.74	43.31	0.76	20.20	10.44	1.09	89151.66
4	9.61	3.41	54.66	0.71	20.65	10.12	1.09	90619.44
5	7.54	1.43	50.62	0.46	20.80	9.80	1.09	94433.98
6	10.54	1.44	50.31	0.93	19.17	10.46	1.09	88758.24
7	8.99	2.27	45.79	0.60	19.22	10.51	1.09	88696.13
8	10.74	3.70	41.36	0.54	19.47	10.32	1.08	90981.90
9	10.41	2.79	58.17	0.46	19.69	10.31	1.08	90582.23
10	10.91	3.11	56.11	0.85	19.31	10.30	1.10	91479.53
11	8.87	3.15	55.16	1.11	18.10	11.20	1.06	85210.46
12	7.94	3.69	42.31	1.09	16.73	11.82	1.07	79553.77
13	10.59	3.13	44.17	2.28	18.06	10.86	1.09	88009.75
14	7.35	4.31	61.06	0.51	18.74	10.56	1.09	88195.91
15	10.81	3.32	65.79	0.57	18.43	10.46	1.07	88974.33
16	10.59	2.67	49.00	1.10	17.59	11.06	1.07	86782.27
17	8.44	5.10	33.78	0.77	17.68	11.18	1.08	86020.08
18	8.34	3.39	51.92	0.66	17.64	12.18	1.09	77236.06
19	9.36	2.81	47.94	0.89	17.29	11.36	1.10	84737.98
20	10.85	2.79	44.13	0.74	16.94	11.28	1.10	85373.76
21	15.81	2.81	46.09	0.79	17.15	11.21	1.10	85575.60
22	12.15	2.68	45.27	0.59	17.30	11.27	1.09	84940.26
23	14.40	3.04	49.22	0.75	17.38	11.36	1.09	84507.32
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.18	3.40	49.13	0.82	18.72	10.82	1.09	87316.54
最 大 值	15.81	7.66	65.79	2.28	21.96	12.18	1.11	94433.98
發生時間	21	1	15	13	1	18		5
最 小 值	7.35	1.43	33.78	0.32	16.73	9.80	1.06	77236.06
發生時間	14	5	17	0	12	5		18
零點偏移(率)	-0.05 %	0.00 %	-0.01 %	-0.02 %		0.00		0.00 %
全幅偏移(率)	0.28 %	0.00 %	-0.03 %	0.00 %		0.21		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 113年11月04日

報表日期: 113年11月04日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.13	3.03	52.72	0.19	20.74	9.71	1.78	85889.87
1	1.14	6.59	43.95	0.25	18.05	10.17	1.78	85098.85
2	1.82	6.14	50.87	0.42	16.75	11.79	1.91	73317.86
3	2.21	4.26	41.17	0.33	18.82	9.65	1.77	88014.91
4	2.26	2.85	53.68	0.40	18.40	9.96	1.76	86594.45
5	2.89	1.93	59.66	0.29	18.20	10.28	1.76	84621.42
6	2.43	3.61	56.60	0.50	17.44	10.87	1.77	80528.54
7	4.33	2.36	41.91	0.35	18.64	9.57	1.74	95269.29
8	7.02	1.55	49.62	0.34	18.04	10.01	1.73	86441.06
9	3.85	0.73	49.61	0.28	16.55	10.83	1.74	81564.26
10	4.05	4.16	47.42	0.32	16.30	10.72	1.73	82753.05
11	3.58	3.26	47.10	0.46	15.25	11.07	1.70	80679.41
12	3.48	2.71	47.77	0.36	15.64	10.74	1.70	83212.71
13	3.50	2.74	48.84	0.43	15.56	10.82	1.72	82827.53
14	3.46	2.54	48.54	0.38	15.82	10.67	1.73	84175.06
15	3.54	2.68	47.29	0.48	15.47	10.92	1.70	82212.61
16	3.50	2.59	45.33	0.21	17.20	10.62	1.70	82601.63
17	3.42	5.53	51.08	0.17	18.41	10.18	1.71	85113.15
18	3.51	3.49	36.59	0.63	14.92	10.89	1.71	82492.47
19	3.85	5.78	43.87	1.36	14.39	11.39	1.74	79379.66
20	3.85	3.39	41.65	1.40	14.25	11.36	1.74	78882.48
21	3.68	4.23	43.89	0.90	14.74	11.28	1.75	79167.24
22	3.61	2.65	43.34	0.37	15.68	11.10	1.75	79844.18
23	3.56	2.71	50.03	0.57	16.41	10.82	1.74	81620.25
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	3.32	3.40	47.61	0.47	16.74	10.64	1.74	83012.58
最 大 值	7.02	6.59	59.66	1.40	20.74	11.79	2.34	95269.29
發生時間	8	1	5	20	0	2		7
最 小 值	1.13	0.73	36.59	0.17	14.25	9.57	1.69	73317.86
發生時間	0	9	18	17	20	7		2
零點偏移(率)	-0.07 %	-0.00 %	-0.03 %	0.00 %		-0.14		-0.10 %
全幅偏移(率)	0.02 %	0.08 %	-0.01 %	0.56 %		0.37		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

