

報表日期: 114年09月19日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.72	12.98	49.78	2.89	16.01	11.37	1.19	81548.54
1	8.61	13.51	65.80	2.62	16.69	11.67	1.19	78198.13
2	9.17	13.11	51.89	2.67	18.42	11.15	1.19	80839.05
3	9.59	12.76	46.83	3.39	17.59	10.95	1.19	83861.02
4	12.70	13.23	51.29	3.67	15.37	11.57	1.19	79427.71
5	5.22	14.09	63.33	3.16	16.44	11.44	1.20	82048.53
6	8.97	14.62	52.67	3.48	15.93	11.38	1.20	82649.23
7	7.68	14.86	52.08	3.40	14.26	11.76	1.20	80358.17
8	8.97	13.08	55.77	2.84	14.27	11.86	1.19	79775.09
9	9.24	14.68	55.02	3.51	13.31	12.11	1.20	78970.37
10	13.07	13.30	58.54	3.46	13.60	12.05	1.20	77619.63
11	9.80	13.03	59.88	3.24	13.80	11.85	1.20	79347.42
12	5.05	13.39	62.28	2.51	14.13	12.06	1.20	77013.08
13	7.97	13.31	66.91	3.14	13.75	11.81	1.19	79973.95
14	14.66	14.20	53.62	4.21	13.15	11.93	1.19	79172.31
15	6.57	14.22	55.94	2.09	13.84	12.44	1.18	72400.02
16	9.83	13.05	50.13	2.56	15.43	11.25	1.19	82242.64
17	13.18	13.69	58.95	2.96	14.46	11.99	1.17	76305.80
18	4.49	13.09	51.37	2.48	14.60	11.67	1.17	76677.62
19	2.81	13.78	60.27	2.48	15.85	11.79	1.22	78407.86
20	8.06	13.63	50.59	2.94	15.60	11.55	1.22	81545.50
21	13.79	13.12	50.42	2.95	15.19	11.48	1.20	79726.73
22	11.35	13.02	54.52	2.85	14.80	11.55	1.19	78679.77
23	9.53	13.00	55.93	3.08	15.44	11.50	1.19	78453.59
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.17	13.53	55.58	3.02	15.08	11.67	1.19	79385.07
最 大 值	14.66	14.86	66.91	4.21	18.42	12.44	1.23	83861.02
發生時間	14	7	13	14	2	15		3
最 小 值	2.81	12.76	46.83	2.09	13.15	10.95	1.13	72400.02
發生時間	19	3	3	15	14	3		15
零點偏移(率)	-0.29 %	-0.01 %	-0.02 %	0.00 %		0.01		0.10 %
全幅偏移(率)	0.82 %	-0.10 %	0.65 %	-0.48 %		-0.05		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年09月19日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.73	12.74	51.76	1.53	17.19	11.07	1.02	80474.30
1	2.58	12.63	59.94	1.64	17.18	11.03	1.02	78864.15
2	2.62	12.66	56.13	2.03	18.40	10.33	1.02	83346.02
3	2.20	12.40	58.06	2.60	15.99	10.94	1.01	77934.80
4	2.28	12.30	56.77	2.72	15.54	10.92	1.02	78661.56
5	2.55	13.27	57.11	2.52	15.94	10.73	1.02	80069.99
6	2.49	12.41	55.52	3.18	15.35	10.80	1.00	88599.34
7	2.20	13.77	58.52	2.83	14.54	11.31	1.00	80718.61
8	2.29	12.33	51.15	2.63	14.76	11.10	1.00	79754.54
9	2.44	12.00	48.24	2.54	15.22	10.87	0.99	78997.57
10	2.07	12.68	55.83	2.91	13.75	11.12	1.00	77463.26
11	2.27	12.57	64.33	2.67	13.78	11.53	0.99	77005.78
12	1.46	12.48	54.80	2.85	13.66	11.23	0.99	76392.39
13	1.60	16.41	58.57	3.29	13.44	11.42	0.97	77665.15
14	1.78	14.30	58.55	2.95	13.57	11.50	0.98	79697.55
15	2.12	16.35	63.90	3.11	13.16	11.88	0.96	72876.40
16	5.26	12.77	57.35	2.80	14.99	10.28	0.98	80485.46
17	3.28	12.63	61.14	2.55	15.53	10.67	0.98	74870.39
18	3.07	11.57	56.34	1.77	15.95	10.06	0.96	76886.73
19	3.53	12.01	61.52	2.10	15.92	10.23	0.97	78344.30
20	5.75	13.70	61.18	1.87	17.33	9.90	0.98	83522.83
21	4.35	11.69	58.68	1.46	17.02	9.96	0.97	79437.36
22	5.43	12.59	63.83	1.71	15.93	10.79	0.97	82752.04
23	4.84	12.38	65.62	1.65	15.88	11.02	0.97	80026.98
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.97	12.94	58.12	2.41	15.42	10.86	0.99	79368.65
最 大 值	5.75	16.41	65.62	3.29	18.40	11.88	1.03	88599.34
發生時間	20	13	23	13	2	15		6
最 小 值	1.46	11.57	48.24	1.46	13.16	9.90	0.94	72876.40
發生時間	12	18	9	21	15	20		15
零點偏移(率)	-0.07 %	-0.01 %	-0.12 %	-0.02 %		-0.03		-0.20 %
全幅偏移(率)	-0.48 %	0.03 %	0.57 %	-0.25 %		-0.13		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年09月19日

報表日期: 114年09月19日

[illegible]