

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月11日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.58	1.92	50.22	3.24	17.55	10.92	1.28	72561.39
1	6.67	2.15	63.03	3.03	17.75	11.45	1.28	69649.07
2	6.73	1.83	48.95	3.14	18.62	10.51	1.27	74188.62
3	9.18	2.65	49.98	3.82	16.10	11.37	1.28	71675.69
4	9.81	4.30	51.15	4.37	14.92	11.66	1.28	69742.92
5	9.20	1.48	54.53	3.68	16.82	11.01	1.29	73449.10
6	6.27	2.04	49.14	3.51	15.77	11.49	1.29	70331.30
7	4.62	1.96	55.90	2.96	16.89	11.27	1.30	71203.46
8	9.78	2.14	50.91	3.60	17.25	10.98	1.33	72297.61
9	10.52	1.99	54.77	4.23	16.55	11.34	1.33	70656.07
10	9.24	3.57	49.14	4.80	15.32	11.42	1.33	70869.89
11	8.45	2.44	54.99	3.32	16.93	11.18	1.33	72191.58
12	9.81	2.04	50.36	3.64	16.42	11.17	1.33	72349.06
13	9.06	2.09	57.33	3.55	16.33	11.34	1.33	70879.55
14	6.77	2.18	58.32	2.86	18.60	11.14	1.32	70549.35
15	10.76	1.93	48.73	3.39	18.16	10.85	1.30	72966.12
16	7.52	2.73	67.52	2.99	17.32	11.25	1.29	71401.96
17	7.77	2.38	42.37	3.29	17.11	11.17	1.31	71731.65
18	9.74	2.78	65.39	3.30	16.96	11.26	1.31	71691.39
19	9.68	2.32	45.54	3.27	16.39	11.31	1.30	70782.72
20	13.88	2.96	49.15	4.09	16.08	11.25	1.31	71860.80
21	9.43	2.66	62.64	3.28	17.58	11.17	1.32	71912.85
22	9.78	1.99	46.10	3.27	17.65	11.03	1.31	72807.79
23	10.51	1.98	59.31	3.35	17.17	11.15	1.31	72156.94
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.91	2.35	53.56	3.50	16.93	11.20	1.31	71662.79
最大值	13.88	4.30	67.52	4.80	18.62	11.66	1.34	74188.62
發生時間	20	4	16	10	2	4		2
最小值	4.62	1.48	42.37	2.86	14.92	10.51	1.25	69649.07
發生時間	7	5	17	14	4	2		1
零點偏移(率)	-0.01 %	0.00 %	-0.01 %	-0.00 %		0.05	0.00	0.00 %
全幅偏移(率)	2.98 %	-0.08 %	0.04 %	0.02 %		-0.07	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月11日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.20	2.01	52.49	1.20	19.00	9.67	1.46	83865.05
1	1.20	4.06	45.49	0.77	21.20	9.07	1.46	82968.23
2	1.79	4.11	52.32	1.15	20.19	8.74	1.45	82599.60
3	3.12	2.28	43.78	1.59	18.14	9.37	1.43	81904.66
4	1.65	1.70	60.96	1.39	17.73	10.50	1.45	76747.71
5	2.02	2.36	55.18	1.11	19.28	9.42	1.46	85049.99
6	8.84	2.65	44.70	3.22	15.53	10.10	1.46	85629.64
7	8.23	1.11	48.44	2.11	17.52	9.62	1.46	84525.31
8	8.90	1.17	47.32	2.24	17.02	9.87	1.47	82144.27
9	9.42	1.16	52.00	2.26	17.87	9.72	1.46	81605.77
10	9.67	8.28	37.64	4.12	20.45	8.44	1.46	86945.09
11	8.88	2.45	51.09	3.08	20.13	8.27	1.46	81042.11
12	8.68	5.21	49.20	3.00	17.14	9.09	1.46	79043.54
13	6.70	2.64	54.23	1.28	20.60	9.42	1.48	84718.64
14	3.38	2.35	55.67	0.86	20.32	9.65	1.49	84827.00
15	7.13	2.20	52.75	1.58	18.18	10.18	1.49	82915.84
16	3.58	1.91	56.11	1.19	18.63	10.18	1.49	82633.64
17	7.63	2.25	52.82	1.49	19.48	9.69	1.49	84335.96
18	9.56	2.55	54.41	1.98	18.08	9.93	1.47	83227.63
19	10.21	1.65	59.80	1.90	18.30	9.84	1.47	86290.14
20	9.65	1.55	63.14	2.31	17.57	10.18	1.49	81391.73
21	9.24	1.77	49.72	1.66	20.16	9.72	1.48	84239.65
22	9.92	1.92	56.78	1.74	18.98	9.70	1.48	85020.64
23	6.19	1.64	60.80	1.27	19.54	9.69	1.49	83426.05
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.70	2.54	52.37	1.85	18.79	9.59	1.47	83212.41
最大值	10.21	8.28	63.14	4.12	21.20	10.50	1.50	86945.09
發生時間	19	10	20	10	1	4		10
最小值	1.20	1.11	37.64	0.77	15.53	8.27	1.43	76747.71
發生時間	1	7	10	1	6	11		4
零點偏移(率)	-0.02 %	-0.03 %	-0.02 %	-0.01 %		0.01	0.00	0.00 %
全幅偏移(率)	2.20 %	0.18 %	-0.22 %	0.21 %		-0.07	-0.03	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月11日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.69	4.37	54.72	2.42	17.31	10.49	1.27	84013.71
1	5.15	3.72	54.69	2.40	17.58	10.52	1.28	82900.81
2	6.37	2.17	60.17	2.73	16.48	10.88	1.27	78454.23
3	7.58	2.69	59.37	2.65	17.57	10.65	1.27	83010.52
4	6.50	4.93	50.45	2.44	18.18	10.03	1.29	87602.79
5	7.06	5.49	49.31	4.66	16.69	10.17	1.27	83142.76
6	8.77	4.65	50.42	3.58	14.74	10.54	1.25	78761.06
7	9.53	2.82	61.73	3.94	14.09	10.94	1.26	74722.72
8	10.11	8.02	50.04	4.79	14.54	10.66	1.27	77629.34
9	2.92	2.78	51.76	2.92	14.85	10.64	1.28	75281.69
10	8.92	5.63	52.10	3.39	14.88	10.50	1.28	76534.16
11	10.98	4.99	50.40	3.83	15.50	10.28	1.27	80423.61
12	9.88	9.96	50.00	3.81	14.47	10.41	1.28	76547.27
13	4.34	3.15	58.29	2.35	17.08	10.15	1.29	80277.84
14	6.05	2.65	54.27	2.60	15.68	10.79	1.29	80243.50
15	5.58	1.92	59.98	2.64	15.90	10.85	1.29	80672.40
16	6.74	2.38	54.58	2.49	16.28	10.74	1.29	80404.20
17	6.51	2.23	61.61	2.83	15.14	10.91	1.29	79696.86
18	8.16	3.97	60.72	2.87	15.76	10.92	1.29	80993.86
19	10.78	5.72	53.09	4.04	14.72	11.01	1.27	80202.38
20	9.03	3.10	61.07	3.23	16.17	10.54	1.27	81536.56
21	12.13	3.86	54.43	3.11	16.05	10.63	1.26	79693.85
22	13.07	1.71	61.94	3.15	16.23	10.60	1.26	82583.57
23	9.82	1.76	62.02	3.33	16.10	10.67	1.26	80385.09
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.03	3.94	55.72	3.18	15.92	10.60	1.27	80238.12
最大值	13.07	9.96	62.02	4.79	18.18	11.01	1.30	87602.79
發生時間	22	12	23	8	4	19		4
最小值	2.92	1.71	49.31	2.35	14.09	10.03	1.24	74722.72
發生時間	9	22	5	13	7	4		7
零點偏移(率)	-0.01 %	0.00 %	-0.15 %	-0.05 %		0.02	0.00	0.00 %
全幅偏移(率)	3.31 %	0.63 %	-0.26 %	0.42 %		0.34	0.02	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								