

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 113年12月31日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.84	2.95	60.60	0.55	17.71	10.92	1.26	85944.32
1	6.69	3.20	46.96	0.79	18.07	10.98	1.28	85406.76
2	1.69	2.78	55.92	1.11	15.97	11.63	1.30	82487.51
3	0.62	3.05	52.48	1.54	14.42	11.98	1.29	80347.87
4	1.37	2.92	49.21	1.63	14.46	12.07	1.27	79798.70
5	6.52	2.78	39.64	1.77	14.36	12.10	1.27	76087.43
6	5.37	2.59	40.43	1.74	14.26	12.05	1.27	78878.90
7	6.46	3.51	45.60	0.71	16.84	11.53	1.27	82174.77
8	4.69	3.12	41.95	1.15	15.60	11.72	1.29	80891.79
9	4.81	3.07	56.82	0.82	15.79	11.93	1.29	78992.61
10	10.36	2.96	54.02	2.25	13.94	12.06	1.29	79136.37
11	8.34	3.52	46.64	2.35	13.94	11.95	1.27	79918.83
12	2.81	3.65	48.15	2.03	13.76	12.16	1.29	75976.68
13	7.19	2.76	59.75	1.79	13.69	12.35	1.29	77444.47
14	6.06	3.91	51.03	2.83	12.74	12.35	1.29	76655.86
15	8.40	2.63	45.65	3.09	12.16	12.32	1.29	75398.38
16	11.20	4.65	48.47	2.10	12.89	12.08	1.29	78079.87
17	9.27	1.73	59.07	1.61	14.01	12.09	1.27	79756.93
18	10.63	7.32	54.81	1.66	13.43	11.85	1.26	81769.49
19	9.48	5.39	52.60	1.27	14.46	11.88	1.24	81399.39
20	8.45	3.20	54.25	0.93	14.52	12.05	1.23	79400.27
21	9.90	4.56	52.55	1.66	14.29	11.78	1.23	81045.22
22	7.43	2.86	54.56	2.01	13.91	12.26	1.23	77438.28
23	7.81	2.79	51.93	1.19	14.57	12.42	1.24	76075.51
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.81	3.41	50.96	1.61	14.57	11.94	1.27	79604.43
最大值	11.20	7.32	60.60	3.09	18.07	12.42	1.35	85944.32
發生時間	16	18	0	15	1	23		0
最小值	0.62	1.73	39.64	0.55	12.16	10.92	1.23	75398.38
發生時間	3	17	5	0	15	0		15
零點偏移(率)	-0.01 %	-0.01 %	-0.06 %	-0.01 %		-0.10		0.20 %
全幅偏移(率)	0.00 %	0.22 %	-0.16 %	-0.06 %		-0.18		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 113年12月31日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.08	7.08	46.97	1.47	15.42	10.60	1.07	82621.87
1	4.28	2.45	42.82	2.15	14.87	10.97	1.10	79688.09
2	1.39	3.55	42.04	2.34	13.56	10.98	1.09	77021.35
3	0.78	2.76	42.15	2.13	14.51	10.88	1.09	76803.39
4	1.49	1.82	43.92	1.64	14.70	11.05	1.07	75729.26
5	2.39	5.44	47.40	1.84	15.36	10.77	1.06	78224.56
6	2.16	7.41	40.50	2.73	13.35	11.01	1.06	74758.28
7	0.54	2.43	45.54	1.62	14.75	11.66	1.06	73157.86
8	0.18	2.16	50.49	2.02	14.87	11.51	1.06	77052.04
9	5.14	5.19	50.65	2.21	14.78	11.00	1.08	80291.20
10	6.16	1.51	54.43	2.03	14.32	11.20	1.06	80271.79
11	4.86	2.02	57.33	2.94	12.05	11.71	1.03	75630.77
12	6.78	4.10	61.17	2.72	12.60	11.74	1.03	77139.46
13	5.85	1.87	62.29	2.77	12.04	11.84	1.05	78024.66
14	6.55	2.43	61.19	3.64	11.55	11.60	1.06	76342.89
15	7.95	2.45	53.20	2.55	12.83	11.56	1.06	75681.33
16	8.65	1.74	52.06	1.42	13.01	11.29	1.06	80186.68
17	8.20	1.52	53.59	1.38	12.66	11.38	1.06	80511.63
18	8.93	2.84	53.68	1.67	14.22	11.17	1.04	79816.33
19	8.79	3.09	56.14	1.18	14.35	11.10	1.04	83748.58
20	8.34	2.28	52.16	1.05	14.34	11.14	1.04	83652.37
21	7.18	1.80	49.36	2.19	13.81	11.21	1.04	81561.51
22	6.38	2.16	49.58	2.39	13.28	11.49	1.03	78486.27
23	7.65	1.78	49.87	2.07	13.93	11.33	1.03	80527.41
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.36	3.00	50.77	2.09	13.80	11.26	1.06	78622.07
最大值	8.93	7.41	62.29	3.64	15.42	11.84	1.10	83748.58
發生時間	18	6	13	14	0	13		19
最小值	0.18	1.51	40.50	1.05	11.55	10.60	1.02	73157.86
發生時間	8	10	6	20	14	0		7
零點偏移(率)	-0.11 %	0.00 %	-0.09 %	-0.01 %		-0.05		0.10 %
全幅偏移(率)	0.22 %	0.10 %	0.44 %	0.14 %		-0.10		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 113年12月31日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.88	2.00	57.67	1.11	14.91	10.72	1.51	75048.04
1	6.26	1.97	60.33	2.83	15.45	10.75	1.52	76109.06
2	6.66	1.80	56.57	3.18	15.37	10.61	1.53	77711.96
3	2.25	2.96	57.07	3.19	13.93	10.66	1.51	77063.24
4	6.84	5.22	55.81	3.92	14.00	10.76	1.49	76656.61
5	5.73	2.30	52.03	3.50	13.86	10.86	1.49	76466.51
6	7.25	6.23	59.71	2.79	15.15	10.75	1.50	73007.54
7	4.70	7.64	55.37	1.60	16.77	9.87	1.49	80471.56
8	13.75	3.93	47.48	3.47	14.16	10.46	1.48	74947.89
9	7.54	1.70	46.48	2.16	14.62	10.33	1.50	73868.71
10	8.27	2.34	43.77	1.80	14.92	10.25	1.48	73720.17
11	4.53	2.40	46.60	2.34	13.30	10.64	1.48	72249.16
12	3.55	6.52	50.22	1.70	13.19	10.76	1.48	73405.16
13	6.80	4.83	51.43	2.23	12.94	10.90	1.48	72864.49
14	7.81	11.27	45.47	1.83	12.44	10.93	1.48	70673.30
15	11.70	4.77	48.37	2.95	13.26	10.71	1.47	70522.90
16	5.10	5.39	45.58	1.73	14.66	10.04	1.48	74510.99
17	8.13	3.03	49.53	2.78	13.26	10.12	1.48	72800.34
18	3.59	3.44	52.73	0.86	15.44	9.88	1.47	78686.62
19	2.46	2.98	50.36	1.97	14.24	10.06	1.48	78640.96
20	2.19	1.07	56.81	1.20	15.85	10.26	1.48	82123.38
21	7.97	1.98	58.79	1.82	14.94	10.65	1.48	82655.69
22	9.81	2.30	52.89	2.61	15.24	10.30	1.48	74642.25
23	6.91	2.60	44.55	1.30	15.78	10.01	1.47	77300.54
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.49	3.78	51.90	2.29	14.49	10.47	1.49	75672.79
最大值	13.75	11.27	60.33	3.92	16.77	10.93	1.55	82655.69
發生時間	8	14	1	4	7	14		21
最小值	2.19	1.07	43.77	0.86	12.44	9.87	1.46	70522.90
發生時間	20	20	10	18	14	7		15
零點偏移(率)	-0.02 %	0.00 %	-0.12 %	0.00 %		0.00		0.20 %
全幅偏移(率)	0.02 %	-0.35 %	0.09 %	0.06 %		0.35		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								