

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月24日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.35	10.63	46.61	1.63	16.52	11.64	1.06	80195.64
1	6.79	9.03	43.91	1.95	16.07	12.00	1.06	77217.96
2	8.56	8.72	46.00	2.79	15.35	11.66	1.06	79652.66
3	9.75	8.34	52.41	2.42	15.15	11.77	1.06	77688.02
4	8.93	8.16	56.11	2.42	14.85	11.99	1.06	76289.67
5	9.89	9.24	59.01	2.51	15.31	12.02	1.06	76000.41
6	7.84	8.20	58.42	1.84	15.66	11.85	1.06	79148.33
7	6.55	8.60	53.96	1.84	15.49	11.93	1.06	76886.10
8	7.03	8.46	48.88	1.99	15.90	11.57	1.07	78962.33
9	7.25	8.47	53.38	1.99	15.68	11.95	1.07	75199.19
10	4.11	8.74	64.84	1.44	15.80	12.45	1.08	73616.86
11	5.75	10.83	42.85	1.11	17.01	11.76	1.04	79196.27
12	6.59	8.84	41.01	1.19	17.32	11.54	1.06	80886.90
13	6.74	6.27	47.83	1.19	16.95	11.62	1.09	80748.24
14	2.89	6.01	50.48	1.02	16.87	11.44	1.09	82194.34
15	0.62	6.10	47.29	1.70	15.98	11.59	1.06	82287.46
16	2.13	4.99	47.54	1.83	16.52	11.46	1.04	82429.24
17	4.78	5.08	51.87	1.88	16.15	11.96	1.04	78431.69
18	7.76	5.45	52.48	1.75	16.65	11.56	1.04	81676.79
19	8.59	5.51	50.06	2.20	15.89	11.60	1.04	82086.05
20	4.68	6.07	59.18	2.24	15.27	12.81	1.06	71746.31
21	0.30	8.91	61.13	1.53	16.38	12.88	1.10	70290.97
22	4.29	6.31	55.90	1.26	17.68	11.54	1.06	81073.66
23	9.39	5.36	43.15	2.66	15.51	11.50	1.04	83063.81
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.32	7.60	51.43	1.85	16.08	11.84	1.06	78623.70
最 大 值	10.35	10.83	64.84	2.79	17.68	12.88	1.18	83063.81
發生時間	0	11	10	2	22	21		23
最 小 值	0.30	4.99	41.01	1.02	14.85	11.44	1.03	70290.97
發生時間	21	16	12	14	4	14		21
零點偏移(率)	-0.08 %	-0.00 %	-0.02 %	-0.01 %		-0.01		0.00 %
全幅偏移(率)	0.00 %	0.47 %	-0.26 %	0.46 %		0.11		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月24日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	10.05	2.21	61.15	2.74	16.57	10.99	1.06	80816.42
1	13.36	2.37	55.98	3.74	15.60	11.36	1.06	78686.49
2	13.49	3.90	51.91	1.99	13.80	11.65	1.06	78312.91
3	9.98	3.83	52.75	1.49	15.65	11.29	1.06	79453.45
4	9.55	4.79	48.16	1.72	14.53	11.33	1.06	79848.69
5	10.22	4.03	57.21	1.61	15.00	11.58	1.06	77774.91
6	12.61	8.09	55.39	2.36	15.06	11.37	1.09	78377.62
7	9.93	3.53	57.77	1.32	16.42	11.01	1.09	80750.55
8	9.81	3.82	50.74	1.39	15.79	11.18	1.10	79703.40
9	9.86	4.10	56.73	1.24	15.81	11.75	1.07	74855.26
10	8.91	4.73	51.30	1.33	17.68	11.12	1.09	78083.81
11	9.25	5.17	49.52	2.08	18.14	10.60	1.10	81519.01
12	8.17	5.28	40.54	2.18	16.14	11.39	1.07	76933.13
13	7.98	4.39	47.20	2.15	17.21	11.41	1.09	75712.97
14	0.90	5.75	53.57	2.20	17.04	11.56	1.08	74324.18
15	5.94	4.73	42.10	1.63	17.92	10.62	1.08	81573.60
16	9.25	5.77	40.92	1.69	18.46	10.51	1.09	81953.03
17	10.62	2.86	48.67	1.97	17.03	10.53	1.09	82919.21
18	7.99	2.37	65.20	1.55	17.14	11.28	1.10	77402.81
19	10.70	3.73	35.31	2.50	17.34	10.64	1.10	81881.31
20	8.13	3.43	45.49	0.95	19.46	10.62	1.09	80003.95
21	10.51	3.68	40.26	1.47	18.88	10.32	1.09	83140.81
22	10.79	1.80	35.37	2.45	17.30	10.40	1.07	83636.96
23	13.86	4.94	47.41	2.71	16.83	10.74	1.06	81982.44
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.66	4.14	49.61	1.94	16.70	11.05	1.08	79568.62
最 大 值	13.86	8.09	65.20	3.74	19.46	11.75	1.10	83636.96
發生時間	23	6	18	1	20	9		22
最 小 值	0.90	1.80	35.31	0.95	13.80	10.32	1.05	74324.18
發生時間	14	22	19	20	2	21		14
零點偏移(率)	-0.08 %	-0.07 %	-0.03 %	-0.01 %		-0.02		-0.10 %
全幅偏移(率)	0.14 %	0.61 %	0.06 %	0.50 %		-0.17		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 113年03月24日

報表日期: 113年03月24日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.10	8.09	53.75	1.39	15.61	11.12	1.06	77732.31
1	5.58	5.02	58.37	1.47	16.21	11.41	1.05	74742.76
2	8.67	4.76	61.02	1.92	15.12	11.20	1.04	76681.05
3	9.53	4.62	58.01	2.06	14.74	11.21	1.04	77263.94
4	9.76	4.05	60.47	2.44	14.65	11.05	1.04	78234.36
5	11.22	3.53	57.81	2.67	14.61	10.90	1.04	75781.98
6	8.95	4.59	61.57	1.69	15.63	10.69	1.04	75776.57
7	10.34	4.90	58.97	1.93	15.80	10.73	1.02	74163.73
8	11.97	3.51	58.00	2.14	16.18	10.53	1.03	78262.37
9	9.00	4.07	55.52	1.95	15.19	10.69	1.03	74792.34
10	4.75	4.95	67.43	1.31	16.55	11.63	1.03	70987.65
11	1.42	6.15	58.72	1.58	17.16	11.54	1.07	73450.98
12	2.68	4.69	37.15	1.44	17.18	10.29	1.04	81437.38
13	2.80	4.62	40.52	1.71	15.59	10.82	1.01	77256.64
14	0.32	6.40	40.49	1.91	14.93	10.73	1.04	78441.40
15	2.24	4.57	42.02	1.45	15.62	10.65	1.04	78749.92
16	6.14	3.67	43.09	1.71	15.45	10.66	1.03	79367.12
17	3.57	3.80	62.80	1.49	15.57	10.87	1.00	79155.27
18	5.06	4.34	57.78	1.97	15.18	10.94	0.99	79440.11
19	4.71	3.87	61.78	1.30	16.15	10.69	0.99	79417.71
20	3.26	4.03	58.11	0.80	18.47	10.78	1.01	76762.14
21	3.92	5.66	55.70	1.04	17.64	10.68	1.03	79070.86
22	8.05	3.22	49.48	1.29	17.33	10.24	0.99	82494.35
23	10.23	4.31	48.49	1.87	15.62	10.60	0.99	79190.09
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.26	4.64	54.46	1.69	15.92	10.86	1.03	77443.88
最 大 值	11.97	8.09	67.43	2.67	18.47	11.63	1.09	82494.35
發生時間	8	0	10	5	20	10		22
最 小 值	0.32	3.22	37.15	0.80	14.61	10.24	0.99	70987.65
發生時間	14	22	12	20	5	22		10
零點偏移(率)	-0.13 %	0.00 %	-0.03 %	0.00 %		-0.03		-0.10 %
全幅偏移(率)	0.02 %	0.16 %	-0.32 %	0.22 %		-0.09		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								