

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月03日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.37	13.36	42.33	1.72	19.43	10.90	1.29	83343.99
1	8.27	13.32	55.05	1.77	18.68	11.46	1.25	79843.42
2	9.41	12.84	57.60	1.49	20.56	10.69	1.27	84236.42
3	11.35	13.00	49.28	1.76	20.66	10.16	1.29	88582.77
4	9.51	12.47	57.56	1.93	19.20	10.46	1.29	87251.88
5	2.90	12.90	44.53	3.19	20.58	10.56	1.27	82667.94
6	10.36	13.26	46.29	3.31	19.84	10.26	1.27	89190.97
7	8.54	13.30	50.87	2.31	18.30	10.97	1.26	84323.75
8	10.20	12.95	46.83	2.14	18.38	11.25	1.25	81307.81
9	8.85	12.88	42.79	2.33	17.46	11.30	1.25	82085.61
10	10.34	13.18	55.32	2.24	17.22	11.56	1.25	79709.92
11	12.22	12.26	53.67	2.35	17.82	10.77	1.25	85453.04
12	6.32	12.58	42.82	2.30	16.70	11.18	1.25	83286.49
13	10.08	12.57	42.51	1.21	16.52	11.21	1.25	82910.64
14	9.52	12.62	50.59	1.81	16.85	11.22	1.25	83192.05
15	13.24	12.54	55.14	1.78	17.72	11.04	1.25	83704.06
16	6.74	12.72	51.37	1.75	17.95	10.84	1.25	84927.59
17	8.96	13.00	52.54	2.67	16.04	11.27	1.25	83421.92
18	8.66	13.77	57.23	3.06	15.69	11.84	1.25	78548.55
19	11.19	13.04	47.24	2.37	17.17	11.10	1.25	84067.78
20	12.04	13.08	58.27	2.64	15.83	11.32	1.25	82438.80
21	10.59	13.53	56.66	2.71	14.48	11.72	1.25	78639.55
22	8.71	13.53	53.37	3.13	17.66	11.34	1.25	81449.33
23	8.31	14.01	56.24	2.86	18.05	11.61	1.25	78499.08
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.36	13.03	51.09	2.28	17.87	11.08	1.26	83045.14
最大值	13.24	14.01	58.27	3.31	20.66	11.84	1.29	89190.97
發生時間	15	23	20	6	3	18		6
最小值	2.90	12.26	42.33	1.21	14.48	10.16	1.25	78499.08
發生時間	5	11	0	13	21	3		23
零點偏移(率)	-0.06 %	-0.01 %	-0.14 %	-0.01 %		-0.05	-0.01	0.40 %
全幅偏移(率)	-0.87 %	-1.92 %	-0.59 %	-0.58 %		0.15	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月03日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.42	11.64	50.11	0.68	19.19	10.13	1.03	80311.90
1	9.32	11.60	55.15	0.76	19.41	10.08	1.02	84135.97
2	11.03	12.16	54.61	1.48	19.18	10.28	1.00	81431.63
3	6.50	11.75	61.98	0.90	18.75	10.31	1.01	82158.82
4	12.17	11.73	63.57	1.37	18.48	10.30	1.02	84031.02
5	6.79	11.90	62.67	1.46	17.61	10.61	1.02	80162.64
6	10.96	11.33	46.86	1.68	18.23	10.38	1.02	80574.82
7	9.89	12.10	53.05	2.45	16.21	10.84	1.02	79594.29
8	6.31	12.06	52.02	2.43	15.67	10.83	1.02	78127.50
9	8.75	12.99	53.28	3.28	15.45	10.87	1.00	77968.69
10	8.39	11.82	50.23	1.52	16.62	10.69	1.01	77391.13
11	10.88	11.92	54.55	1.43	17.59	10.63	1.01	79448.13
12	11.04	11.95	52.86	2.06	16.35	10.80	1.02	79814.28
13	3.70	12.14	51.15	1.82	15.29	11.11	1.02	76742.33
14	12.08	12.34	52.38	2.09	15.44	11.23	1.02	77592.31
15	6.19	12.40	58.75	1.50	17.10	11.01	1.02	77465.06
16	10.14	12.18	56.43	1.97	16.99	10.77	1.02	82077.76
17	11.33	12.87	59.40	3.25	14.98	11.16	1.02	79684.49
18	11.26	12.33	61.24	1.34	18.73	10.35	1.02	84271.96
19	8.23	11.93	54.88	1.05	18.24	10.28	1.02	84823.63
20	10.11	12.14	54.98	1.75	16.24	10.73	1.02	78836.29
21	9.92	11.96	54.44	1.03	17.32	10.41	1.02	80998.24
22	8.41	12.10	56.59	0.84	17.69	10.57	1.02	81089.42
23	7.89	11.66	54.01	0.81	20.11	9.81	1.02	84129.12
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.03	12.04	55.22	1.62	17.37	10.59	1.02	80535.89
最大值	12.17	12.99	63.57	3.28	20.11	11.23	1.03	84823.63
發生時間	4	9	4	9	23	14		19
最小值	3.70	11.33	46.86	0.68	14.98	9.81	0.99	76742.33
發生時間	13	6	6	0	17	23		13
零點偏移(率)	-0.02 %	-0.01 %	-0.06 %	-0.01 %		-0.05	-0.01	0.10 %
全幅偏移(率)	0.89 %	-0.79 %	-0.75 %	-0.02 %		-0.01	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月03日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.32	11.88	47.96	3.10	19.90	9.65	1.38	81216.11
1	8.35	11.87	45.03	3.08	20.03	9.37	1.36	79266.13
2	8.23	12.32	52.95	3.15	20.14	9.63	1.37	76023.47
3	7.66	11.58	59.49	3.04	18.10	9.78	1.37	76474.35
4	7.70	11.81	61.03	2.94	18.15	9.66	1.39	76726.86
5	7.47	12.43	56.97	3.10	16.47	9.81	1.38	74087.57
6	7.29	11.58	53.43	2.91	16.40	9.97	1.37	73798.53
7	1.75	12.74	43.74	2.75	15.54	9.92	1.36	71207.61
8	1.84	12.17	53.13	3.05	16.02	10.54	1.37	71960.12
9	2.19	11.42	43.53	2.50	15.74	10.06	1.34	74516.39
10	5.60	11.97	48.07	2.95	15.52	10.32	1.35	72722.49
11	7.10	11.29	44.97	2.79	15.44	10.15	1.35	74699.66
12	5.83	11.16	45.46	2.88	15.18	10.22	1.36	74361.77
13	6.96	11.63	48.13	3.01	15.43	10.23	1.36	74732.50
14	9.89	11.35	53.19	2.97	15.96	10.26	1.36	75867.21
15	9.60	11.34	51.56	2.75	16.44	10.23	1.36	74772.62
16	7.47	11.80	54.92	2.61	16.66	10.38	1.36	74588.09
17	7.63	11.69	61.49	2.50	16.51	10.54	1.36	75101.93
18	8.42	11.78	56.31	2.79	18.29	9.81	1.36	77618.85
19	10.31	11.41	51.90	2.61	17.95	9.75	1.36	75952.57
20	11.43	12.39	53.01	3.07	16.00	10.16	1.36	75337.73
21	8.80	13.66	59.11	2.21	14.37	10.79	1.36	70816.42
22	8.89	11.37	57.21	2.48	17.17	9.92	1.36	76545.23
23	7.17	11.26	59.05	2.52	17.42	9.90	1.37	75836.78
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.33	11.83	52.57	2.82	16.87	10.04	1.36	75176.29
最大值	11.43	13.66	61.49	3.15	20.14	10.79	1.42	81216.11
發生時間	20	21	17	2	2	21		0
最小值	1.75	11.16	43.53	2.21	14.37	9.37	1.34	70816.42
發生時間	7	12	9	21	21	1		21
零點偏移(率)	-0.13 %	0.01 %	-0.10 %	-0.01 %		-0.06	-0.01	0.00 %
全幅偏移(率)	0.11 %	0.52 %	0.03 %	-0.07 %		0.05	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								