

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年01月10日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.27	9.92	31.46	1.37	15.32	11.95	1.03	80389.89
1	7.78	12.26	36.62	1.35	16.37	12.18	1.04	76895.35
2	9.49	8.36	38.55	1.15	18.70	10.60	1.03	88968.86
3	9.16	2.12	33.58	1.77	15.84	11.94	1.02	80265.38
4	6.27	7.91	53.27	1.58	15.03	13.53	1.10	67200.88
5	10.58	7.07	57.15	0.95	17.63	11.16	1.00	79558.28
6	9.23	6.58	49.01	1.67	15.66	11.77	0.98	82120.97
7	9.61	8.75	46.68	2.48	15.39	11.74	0.97	82539.04
8	9.49	5.31	57.39	1.40	16.03	11.68	0.97	82796.96
9	8.23	6.75	58.00	1.03	16.21	11.86	0.97	80644.70
10	9.37	9.33	52.43	1.21	16.27	11.57	0.99	83179.26
11	9.51	8.74	59.91	0.91	16.66	11.49	0.97	83668.16
12	9.75	10.08	50.17	1.83	14.71	11.89	0.98	82077.32
13	8.59	10.41	45.39	2.33	14.19	11.97	0.98	81661.15
14	10.56	11.20	48.00	2.78	13.31	12.18	0.99	81098.49
15	8.61	10.35	49.53	3.31	12.61	12.46	0.97	78344.43
16	9.68	8.55	49.42	2.65	13.37	12.33	0.98	79314.41
17	10.05	8.92	49.00	2.68	13.34	12.18	1.02	80775.18
18	9.39	8.79	58.28	1.99	14.07	11.97	1.01	81688.20
19	8.65	7.92	49.89	2.73	12.88	12.20	0.98	80831.21
20	9.75	8.31	55.22	2.25	14.36	11.82	0.97	83414.82
21	8.86	7.93	61.45	2.00	14.68	11.89	0.99	82044.61
22	8.73	6.07	63.55	1.14	15.93	11.94	1.02	80312.05
23	9.53	6.14	50.31	0.59	17.10	11.14	1.03	86189.81
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.17	8.24	50.18	1.80	15.24	11.89	1.00	81082.48
最 大 值	10.58	12.26	63.55	3.31	18.70	13.53	1.34	88968.86
發生時間	5	1	22	15	2	4		2
最 小 值	6.27	2.12	31.46	0.59	12.61	10.60	0.97	67200.88
發生時間	4	3	0	23	15	2		4
零點偏移(率)	0.00 %	-0.00 %	-0.03 %	0.00 %		-0.03		0.10 %
全幅偏移(率)	0.02 %	0.15 %	0.10 %	0.10 %		-0.07		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年01月10日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	3.29	2.68	38.68	1.22	15.57	9.73	1.04	72441.29
1	3.59	4.75	37.33	1.32	16.37	9.73	1.02	72523.27
2	5.30	4.25	37.57	1.14	19.17	8.86	1.04	79382.05
3	10.39	2.84	44.00	1.60	16.99	9.54	1.04	77235.21
4	9.20	2.12	43.48	1.24	18.19	9.08	1.04	79164.08
5	5.64	2.13	49.45	1.36	19.47	8.89	1.04	80341.77
6	5.91	3.84	45.59	1.31	17.73	9.23	1.04	81318.80
7	0.86	11.93	41.68	0.48	16.23	10.49	1.03	70961.05
8	2.11	3.18	53.84	0.88	16.45	10.41	1.04	79538.43
9	1.53	3.10	53.20	0.95	15.81	10.43	1.04	80555.60
10	1.28	4.11	52.92	1.06	15.42	10.89	1.04	76408.46
11	1.64	5.25	52.09	1.19	16.36	10.25	1.05	78559.80
12	3.47	5.26	52.51	1.79	14.11	10.72	1.05	75614.80
13	6.80	8.64	53.32	3.24	12.34	11.18	1.05	72940.50
14	3.95	5.47	49.01	2.69	13.01	10.73	1.04	70663.23
15	9.31	5.96	42.47	3.12	12.34	10.74	1.04	72419.31
16	5.36	2.47	54.90	3.47	11.55	11.36	1.04	74336.57
17	0.36	4.73	57.94	2.08	12.80	11.05	1.04	77162.89
18	4.77	7.19	50.34	2.21	13.03	10.47	1.04	76712.30
19	9.45	4.62	48.06	3.51	13.05	10.27	1.04	74687.14
20	6.51	2.94	45.97	2.19	14.12	9.94	1.04	76774.29
21	8.99	3.40	45.46	1.58	15.70	9.85	1.05	78755.89
22	7.20	5.33	49.81	2.35	16.24	9.73	1.06	79946.51
23	13.43	5.81	58.82	2.07	18.53	9.26	1.08	84626.16
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.43	4.67	48.27	1.84	15.44	10.12	1.04	76794.56
最 大 值	13.43	11.93	58.82	3.51	19.47	11.36	1.09	84626.16
發生時間	23	7	23	19	5	16		23
最 小 值	0.36	2.12	37.33	0.48	11.55	8.86	1.02	70663.23
發生時間	17	4	1	7	16	2		14
零點偏移(率)	-0.01 %	-0.02 %	-0.02 %	-0.01 %		0.03		0.20 %
全幅偏移(率)	0.03 %	-0.58 %	-0.29 %	-0.02 %		-0.04		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								