

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月15日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.48	10.48	57.11	0.94	17.40	12.20	1.05	72260.58
1	5.54	6.84	59.53	1.12	17.94	11.99	1.04	73818.46
2	7.82	6.19	50.81	1.81	18.15	11.39	1.02	78350.38
3	6.09	8.81	56.91	1.28	17.95	11.33	1.02	78563.95
4	8.85	7.87	46.22	1.91	16.03	11.62	1.02	74879.92
5	10.01	13.46	49.34	2.65	16.47	11.21	1.05	73996.31
6	9.34	6.90	49.71	2.69	16.54	11.36	1.05	76270.82
7	7.02	5.68	56.20	1.91	16.46	11.45	1.05	75378.41
8	3.45	5.70	54.63	1.08	17.65	11.38	1.03	75736.38
9	6.07	5.36	58.01	1.50	16.54	11.80	1.06	74304.68
10	9.38	6.01	54.56	2.39	16.12	12.05	1.06	72879.71
11	8.06	10.41	47.03	2.83	15.38	11.99	1.02	74164.12
12	6.83	6.39	51.75	1.87	16.42	11.58	1.04	73590.96
13	3.48	8.34	49.46	1.58	15.66	11.77	1.05	72927.35
14	2.98	7.30	58.85	1.32	16.77	11.88	1.04	73032.49
15	3.93	6.99	60.79	0.82	18.04	11.40	1.03	77304.47
16	3.79	9.29	49.91	2.12	15.23	12.02	1.02	73329.87
17	3.15	15.14	49.67	3.22	14.46	11.97	1.03	70895.94
18	1.99	7.39	44.28	1.85	15.76	11.15	1.02	70956.84
19	3.03	8.92	61.85	1.12	18.03	11.12	1.05	75775.69
20	4.58	12.01	50.33	2.06	15.41	11.48	1.04	74357.30
21	1.08	4.36	50.04	2.42	14.55	11.92	1.03	71706.13
22	5.28	13.27	57.29	1.85	16.14	11.66	1.04	73424.22
23	8.92	10.71	62.77	1.74	15.83	11.92	1.05	72035.06
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.63	8.49	53.63	1.84	16.46	11.65	1.04	74164.17
最大值	10.01	15.14	62.77	3.22	18.15	12.20	1.07	78563.95
發生時間	5	17	23	17	2	0		3
最小值	1.08	4.36	44.28	0.82	14.46	11.12	1.01	70895.94
發生時間	21	21	18	15	17	19		17
零點偏移(率)	-0.01 %	-0.01 %	-0.01 %	-0.00 %		0.00		0.00 %
全幅偏移(率)	0.02 %	0.31 %	-0.18 %	0.27 %		-0.12		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月15日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.73	5.43	65.66	1.12	19.06	10.28	1.09	82290.14
1	0.89	8.40	53.34	1.32	20.20	9.99	1.08	83787.59
2	2.29	4.16	53.38	1.43	19.40	9.83	1.07	85970.91
3	9.71	6.55	44.68	1.63	19.00	9.25	1.07	90459.42
4	10.08	6.02	46.33	2.44	16.81	10.03	1.06	83796.09
5	9.15	4.78	54.71	2.48	16.39	10.62	1.07	81649.59
6	7.21	6.44	50.50	1.98	17.69	10.06	1.09	76529.88
7	4.97	11.63	59.08	2.68	16.20	10.73	1.08	80742.67
8	6.88	6.81	52.22	2.30	17.76	10.05	1.09	86058.99
9	7.89	4.75	52.55	3.05	15.78	10.94	1.09	80116.58
10	6.90	10.85	61.33	2.60	16.00	10.90	1.10	79475.37
11	2.57	15.94	53.76	3.33	14.38	11.34	1.10	78208.30
12	4.09	3.40	68.87	3.01	15.21	11.16	1.09	78887.36
13	5.74	3.55	53.33	2.51	16.33	10.83	1.08	80591.62
14	4.64	3.33	48.27	2.27	17.26	10.44	1.13	83002.17
15	4.14	10.08	52.40	2.42	16.54	10.76	1.52	80754.04
16	9.86	6.56	60.03	2.61	15.99	10.76	1.14	81309.50
17	4.87	2.53	60.08	2.31	16.38	10.70	1.13	81275.92
18	2.62	5.36	68.55	1.62	17.67	10.69	1.10	80354.36
19	2.25	6.56	57.35	1.79	17.66	10.35	1.13	83203.73
20	6.05	10.90	56.64	2.51	16.16	10.66	1.13	80630.36
21	8.06	10.47	64.33	2.01	17.10	10.76	1.11	80486.88
22	7.67	8.25	57.33	1.91	17.27	10.60	1.10	81523.12
23	6.13	7.44	58.23	1.40	17.78	10.69	1.08	79857.43
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.68	7.09	56.37	2.20	17.08	10.52	1.11	81706.75
最大值	10.08	15.94	68.87	3.33	20.20	11.34	2.22	90459.42
發生時間	4	11	12	11	1	11		3
最小值	0.89	2.53	44.68	1.12	14.38	9.25	1.05	76529.88
發生時間	1	17	3	0	11	3		6
零點偏移(率)	-0.42 %	-0.01 %	-0.03 %	-0.00 %		0.06		0.00 %
全幅偏移(率)	0.04 %	-0.99 %	-0.18 %	-0.45 %		-0.46		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月15日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.35	10.10	58.02	1.67	15.43	12.18	1.01	70498.90
1	2.54	5.12	51.19	1.14	17.50	10.53	1.02	84548.19
2	2.95	5.84	54.66	1.19	17.15	10.81	1.05	78970.50
3	6.35	9.63	49.75	1.84	15.38	10.74	1.05	77435.21
4	10.22	7.08	51.91	2.06	15.48	10.76	1.03	77771.34
5	8.55	5.26	51.89	2.12	15.18	11.00	0.99	76556.80
6	6.60	6.40	53.11	1.83	15.65	10.81	0.99	79034.72
7	8.62	6.62	55.10	2.47	14.22	11.41	1.04	73337.95
8	6.63	9.98	58.63	1.91	15.71	11.18	0.99	83378.85
9	4.13	5.07	56.32	2.65	14.34	11.97	1.02	75341.74
10	4.38	4.67	62.49	2.07	15.29	11.88	1.02	78638.24
11	5.61	6.21	57.62	2.08	15.38	11.85	0.98	78619.71
12	4.41	8.33	57.24	2.56	14.24	12.14	0.98	75389.45
13	8.43	6.85	62.65	2.47	15.22	11.57	1.02	80457.02
14	6.50	6.76	62.94	2.84	14.03	12.24	1.02	72544.21
15	5.05	6.15	59.07	2.09	15.31	11.84	1.02	79332.33
16	6.84	6.19	54.30	2.11	15.35	11.70	0.99	78514.75
17	7.46	5.82	60.81	2.17	15.01	11.53	1.00	75360.82
18	1.33	8.40	56.40	2.13	14.30	11.58	1.02	72244.83
19	0.80	13.91	53.85	1.90	14.74	10.89	1.07	76888.17
20	3.81	10.76	54.98	3.27	12.10	11.25	0.99	72675.24
21	6.18	5.24	47.00	2.41	14.32	10.76	1.20	72729.76
22	7.70	10.08	46.75	2.23	14.60	10.83	1.05	71395.38
23	4.66	7.08	55.76	1.64	15.99	10.89	1.05	72498.26
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.46	7.40	55.52	2.12	15.08	11.35	1.02	76423.43
最大值	10.22	13.91	62.94	3.27	17.50	12.24	1.82	84548.19
發生時間	4	19	14	20	1	14		1
最小值	0.80	4.67	46.75	1.14	12.10	10.53	0.97	70498.90
發生時間	19	10	22	1	20	1		0
零點偏移(率)	-0.31 %	0.00 %	-0.28 %	-0.08 %		0.00		0.00 %
全幅偏移(率)	0.02 %	-0.82 %	0.84 %	-2.40 %		0.06		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								