

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月27日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.22	3.64	39.62	3.11	16.21	12.35	1.40	70916.62
1	8.10	3.38	46.93	2.73	17.01	12.22	1.39	71896.60
2	10.41	3.26	56.51	2.41	18.03	11.48	1.39	75065.62
3	8.81	3.54	53.60	2.69	16.09	12.13	1.40	71269.20
4	9.42	4.81	56.33	2.82	15.73	11.88	1.40	73268.74
5	8.61	6.00	63.04	2.31	16.73	12.75	1.43	65359.28
6	8.68	3.67	65.89	2.12	18.03	11.96	1.44	71265.07
7	10.11	2.94	49.41	2.41	17.55	11.59	1.43	74549.54
8	9.58	5.24	56.51	2.01	18.55	11.33	1.43	76243.72
9	10.38	3.27	51.14	2.60	16.51	11.70	1.42	75120.84
10	10.88	6.75	47.62	2.49	17.12	11.73	1.41	73889.29
11	9.97	3.44	55.75	2.51	16.44	11.92	1.39	72664.10
12	9.29	4.78	48.09	2.76	15.89	11.96	1.39	72263.76
13	9.62	3.68	47.34	2.99	15.67	12.13	1.41	71124.52
14	5.48	3.52	65.84	2.34	16.31	12.52	1.41	68141.60
15	3.33	3.32	53.25	1.96	16.89	11.92	1.39	72514.68
16	3.88	3.30	51.24	1.96	16.78	11.84	1.38	73096.85
17	2.20	3.34	62.64	1.81	17.14	11.84	1.42	73212.43
18	5.42	3.60	53.42	1.95	17.58	11.65	1.43	73511.09
19	3.37	3.48	58.50	1.59	18.56	11.63	1.42	73001.33
20	7.96	3.59	50.10	2.02	17.24	11.89	1.41	72168.20
21	7.52	4.11	56.26	2.54	15.83	12.50	1.42	68290.34
22	4.58	3.56	65.60	1.83	17.33	12.18	1.41	70281.99
23	1.01	4.72	62.06	2.24	16.48	13.00	1.44	64200.27
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.49	3.96	54.86	2.34	16.90	12.00	1.41	71804.82
最大值	11.22	6.75	65.89	3.11	18.56	13.00	1.46	76243.72
發生時間	0	10	6	0	19	23		8
最小值	1.01	2.94	39.62	1.59	15.67	11.33	1.37	64200.27
發生時間	23	7	0	19	13	8		23
零點偏移(率)	-0.23 %	-0.02 %	-0.01 %	-0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	0.20 %	0.56 %	-0.42 %	0.05 %		0.33	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月27日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.94	4.35	59.16	2.63	17.88	10.28	1.48	85191.28
1	8.92	4.41	59.66	2.26	18.19	10.60	1.49	85837.39
2	10.88	4.57	53.58	3.25	17.69	10.77	1.49	85000.61
3	11.29	3.61	63.97	2.68	19.27	10.04	1.47	88358.12
4	9.77	3.58	55.88	3.00	16.94	10.66	1.46	82542.57
5	11.07	5.05	59.02	2.89	18.88	10.07	1.47	87304.36
6	12.20	4.47	54.10	3.20	17.83	10.45	1.45	84310.38
7	10.49	3.14	51.84	2.55	18.86	10.13	1.47	86338.94
8	10.50	4.42	36.94	3.08	17.62	10.16	1.46	81822.67
9	9.89	2.99	56.61	2.98	17.12	10.30	1.44	84248.22
10	9.70	3.58	68.21	2.66	16.18	10.49	1.43	81994.75
11	9.20	2.98	48.02	2.40	16.56	10.45	1.43	82239.77
12	6.97	3.41	45.53	2.47	16.25	10.32	1.45	79597.48
13	5.18	4.75	46.88	2.11	16.26	10.47	1.45	81113.12
14	6.64	3.12	48.14	2.22	16.47	10.39	1.45	81551.69
15	9.21	3.87	47.27	2.68	16.10	10.52	1.45	81234.32
16	8.42	3.93	56.28	2.50	16.59	10.17	1.46	83501.72
17	9.85	3.95	55.12	2.51	17.15	10.47	1.44	83196.57
18	7.74	3.19	50.58	2.44	15.96	10.74	1.44	80392.19
19	8.97	3.09	49.11	2.45	16.45	10.40	1.48	81405.79
20	10.57	3.04	55.33	2.66	16.42	10.40	1.49	81683.75
21	8.74	3.17	54.39	2.17	16.69	10.50	1.49	79286.97
22	8.52	3.29	51.20	1.57	18.86	9.94	1.50	84198.33
23	6.00	3.55	49.17	1.88	17.25	10.23	1.46	81586.31
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.28	3.73	53.17	2.55	17.23	10.37	1.46	83080.72
最大值	12.20	5.05	68.21	3.25	19.27	10.77	1.50	88358.12
發生時間	6	5	10	2	3	2		3
最小值	5.18	2.98	36.94	1.57	15.96	9.94	1.42	79286.97
發生時間	13	11	8	22	18	22		21
零點偏移(率)	-0.20 %	-0.01 %	-0.08 %	0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	2.42 %	-0.36 %	-0.32 %	0.16 %		0.15	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月27日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.83	4.33	50.08	2.53	16.41	10.55	1.42	88007.71
1	12.33	2.37	59.42	2.67	15.70	10.98	1.42	84363.43
2	8.75	3.12	52.82	2.30	16.69	10.76	1.41	87241.73
3	11.04	3.44	53.81	2.90	15.35	10.73	1.41	86141.76
4	10.79	2.98	59.32	2.80	15.85	10.79	1.40	86175.10
5	10.12	2.27	54.04	2.57	15.97	10.80	1.40	84658.13
6	8.80	3.23	57.05	2.30	16.99	10.46	1.40	87083.85
7	9.46	5.88	53.43	2.14	17.48	10.45	1.43	86386.95
8	8.22	4.11	57.25	1.93	17.10	10.51	1.43	83391.55
9	9.65	4.43	55.28	2.34	16.75	10.38	1.41	81885.19
10	10.23	3.90	61.09	2.36	16.23	10.84	1.41	82551.07
11	9.41	6.85	57.56	2.46	15.17	11.09	1.43	82913.68
12	9.21	3.52	58.62	2.37	15.31	11.01	1.42	80239.40
13	9.88	3.60	58.17	2.75	14.21	11.19	1.41	79511.01
14	9.98	4.05	59.25	2.56	14.93	11.05	1.42	80674.54
15	9.86	4.85	64.01	2.80	14.52	11.16	1.42	81124.17
16	9.50	4.07	57.43	2.50	14.48	11.11	1.41	82228.20
17	7.56	4.66	63.07	2.54	14.75	11.28	1.42	80893.40
18	7.45	5.19	61.58	1.81	16.66	10.72	1.44	85419.55
19	6.60	7.08	50.23	1.80	15.88	10.60	1.43	83297.01
20	8.20	10.02	59.54	3.08	14.10	11.16	1.43	80796.03
21	9.41	1.35	61.55	2.29	16.26	10.76	1.43	83738.12
22	9.58	2.53	57.60	1.80	16.13	10.76	1.43	83161.81
23	7.61	5.01	63.63	1.76	16.55	10.85	1.43	84550.44
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.35	4.28	57.74	2.39	15.81	10.83	1.42	83601.41
最大值	12.33	10.02	64.01	3.08	17.48	11.28	1.46	88007.71
發生時間	1	20	15	20	7	17		0
最小值	6.60	1.35	50.08	1.76	14.10	10.38	1.38	79511.01
發生時間	19	21	0	23	20	9		13
零點偏移(率)	-0.01 %	0.00 %	-0.02 %	0.00 %		0.03	0.00	0.00 %
全幅偏移(率)	0.16 %	0.45 %	-0.41 %	0.15 %		0.33	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								