

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月23日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.13	7.39	55.99	3.59	14.00	12.48	1.49	70410.80
1	8.45	11.47	51.24	3.56	13.82	12.62	1.49	69317.32
2	7.45	6.39	58.23	3.27	14.71	12.44	1.49	70120.59
3	7.12	6.02	55.39	3.09	14.58	12.25	1.48	71498.25
4	8.00	9.36	50.49	3.82	13.12	12.63	1.48	69617.74
5	9.73	5.12	52.00	3.08	15.20	11.78	1.47	76075.69
6	10.01	4.85	60.13	3.61	14.47	12.45	1.46	69761.63
7	7.96	4.46	56.72	4.03	13.41	12.61	1.46	69389.98
8	8.94	6.95	51.10	4.16	13.36	12.65	1.44	69028.78
9	9.92	5.59	56.53	4.37	13.03	12.84	1.41	67095.71
10	7.75	4.89	57.62	4.23	13.12	12.82	1.41	67615.65
11	7.02	4.48	62.89	4.08	13.43	12.86	1.43	67318.17
12	6.54	6.38	47.04	4.07	13.24	12.67	1.46	68333.34
13	5.35	8.59	57.04	4.39	12.85	13.05	1.48	65551.03
14	5.22	5.83	57.40	3.68	13.72	12.49	1.49	68937.53
15	7.89	8.17	44.44	4.12	13.65	12.75	1.48	67315.01
16	6.83	5.28	61.52	3.41	14.34	12.47	1.48	69604.26
17	8.60	6.38	48.00	4.01	13.53	12.59	1.46	69229.09
18	10.63	6.16	58.46	4.01	13.59	12.58	1.46	69119.81
19	5.25	6.92	63.17	3.88	13.71	12.95	1.46	65995.10
20	1.56	7.75	62.85	3.49	14.52	13.19	1.47	63546.54
21	7.24	5.70	48.69	3.19	14.79	11.94	1.46	73352.16
22	8.07	5.72	59.28	3.31	14.53	12.34	1.46	69661.78
23	7.44	6.58	57.05	3.79	13.97	12.68	1.46	67579.05
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.63	6.52	55.55	3.76	13.86	12.59	1.46	68978.13
最大值	10.63	11.47	63.17	4.39	15.20	13.19	1.53	76075.69
發生時間	18	1	19	13	5	20		5
最小值	1.56	4.46	44.44	3.08	12.85	11.78	1.41	63546.54
發生時間	20	7	15	5	13	5		20
零點偏移(率)	0.00 %	-0.03 %	-0.02 %	0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	2.97 %	0.65 %	-0.82 %	0.27 %		0.16	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月23日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.12	5.72	58.06	1.64	18.25	10.39	1.44	84340.82
1	8.64	7.47	46.63	1.71	18.79	10.17	1.44	84923.61
2	9.90	6.44	54.49	2.30	18.10	10.61	1.41	83709.99
3	10.56	6.45	44.31	2.70	17.64	10.28	1.40	85278.94
4	10.31	5.66	54.93	2.50	17.34	10.36	1.41	83125.96
5	9.46	7.20	55.59	2.26	17.16	10.43	1.41	83413.36
6	10.04	5.87	48.43	1.91	17.85	10.30	1.37	82956.36
7	9.39	6.27	55.12	2.00	17.22	10.76	1.35	80566.31
8	9.47	6.11	58.45	1.94	18.10	10.30	1.33	83231.70
9	11.61	5.76	51.31	2.29	17.62	10.46	1.34	85135.01
10	8.41	8.61	42.38	2.46	15.87	10.36	1.35	80970.80
11	10.29	2.37	49.05	2.55	16.88	9.98	1.37	86326.17
12	10.28	4.51	50.59	2.54	15.88	10.49	1.38	84239.24
13	10.51	2.93	54.86	2.06	17.72	10.13	1.37	87639.61
14	13.05	3.66	50.05	3.37	16.05	10.57	1.36	83908.77
15	10.46	7.27	60.48	2.40	16.73	10.89	1.37	80364.63
16	10.28	6.90	52.98	2.41	15.97	10.90	1.38	84160.20
17	10.42	8.87	54.63	2.78	14.65	11.26	1.38	79870.72
18	10.11	6.51	61.45	2.08	17.44	10.79	1.38	80269.09
19	10.27	6.77	47.27	2.28	17.60	10.65	1.38	80878.21
20	11.46	8.62	42.78	3.10	16.33	10.67	1.38	80133.23
21	9.86	5.84	61.20	2.24	17.43	10.66	1.38	82885.25
22	10.22	6.36	56.07	2.00	17.34	10.63	1.38	83632.59
23	9.07	7.56	54.42	1.95	17.12	10.91	1.38	80409.24
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.13	6.24	52.73	2.31	17.13	10.54	1.38	83015.41
最大值	13.05	8.87	61.45	3.37	18.79	11.26	1.44	87639.61
發生時間	14	17	18	14	1	17		13
最小值	8.41	2.37	42.38	1.64	14.65	9.98	1.33	79870.72
發生時間	10	11	10	0	17	11		17
零點偏移(率)	-0.01 %	-0.02 %	-0.02 %	-0.05 %		-0.05	0.00	0.00 %
全幅偏移(率)	1.71 %	0.70 %	-0.52 %	0.28 %		0.04	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月23日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.88	4.05	57.99	1.33	17.28	10.28	1.74	82341.74
1	3.90	3.35	51.28	1.44	16.30	10.73	1.76	79331.42
2	4.00	3.54	54.85	1.61	16.84	10.65	1.75	80758.52
3	9.44	3.14	55.31	2.28	16.06	10.50	1.74	80883.56
4	8.82	4.23	51.50	2.16	15.70	10.60	1.73	81146.28
5	7.47	3.67	58.98	1.46	17.64	10.46	1.75	80466.06
6	7.81	6.85	49.05	3.09	15.96	10.82	1.74	81941.46
7	5.17	5.21	56.53	1.81	17.67	9.67	1.72	79479.25
8	9.81	9.72	59.29	2.60	14.88	10.95	1.72	81661.02
9	9.56	3.10	55.17	2.48	14.79	10.88	1.73	81146.98
10	8.65	4.58	53.89	3.04	13.30	11.25	1.75	79724.79
11	5.15	2.21	60.71	2.01	15.12	10.82	1.74	79082.61
12	4.48	2.72	53.41	1.82	15.66	10.83	1.74	79024.27
13	5.93	2.22	60.63	2.16	15.02	10.86	1.74	80490.03
14	3.43	1.65	61.45	1.83	15.75	10.92	1.76	79989.47
15	1.36	5.50	58.75	2.42	13.84	11.34	1.75	79602.51
16	5.88	6.02	64.40	2.40	14.83	11.22	1.74	81028.82
17	6.22	5.74	64.22	2.27	15.25	11.22	1.75	79677.81
18	9.15	6.56	57.56	2.11	15.88	10.89	1.74	81671.17
19	8.19	6.84	67.92	1.92	16.71	11.31	1.75	79137.66
20	9.11	6.50	57.84	2.14	15.67	10.98	1.75	82411.69
21	12.90	10.40	56.49	2.55	14.90	10.78	1.74	84904.11
22	10.98	4.34	60.10	2.31	15.06	11.00	1.76	83266.80
23	3.76	6.39	65.22	2.24	15.06	11.35	1.77	81184.76
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.92	4.94	58.02	2.15	15.63	10.85	1.75	80848.03
最大值	12.90	10.40	67.92	3.09	17.67	11.35	1.79	84904.11
發生時間	21	21	19	6	7	23		21
最小值	1.36	1.65	49.05	1.33	13.30	9.67	1.72	79024.27
發生時間	15	14	6	0	10	7		12
零點偏移(率)	-0.06 %	0.00 %	-0.02 %	-0.03 %		-0.01	0.00	0.00 %
全幅偏移(率)	2.52 %	0.42 %	-0.96 %	0.13 %		0.02	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								