

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月27日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.12	9.29	44.41	1.64	19.05	10.98	1.07	75477.53
1	9.62	9.45	48.66	1.19	20.54	10.79	1.06	76388.47
2	9.67	8.19	43.94	1.70	17.48	11.27	1.06	75156.11
3	8.73	10.29	44.96	1.27	18.28	11.28	1.06	75522.84
4	9.13	8.59	50.76	1.54	17.79	11.52	1.05	73513.49
5	11.44	16.34	48.88	1.47	18.30	11.41	1.04	69611.06
6	10.11	6.07	37.19	1.58	16.82	11.50	1.03	74181.31
7	8.44	8.20	58.99	1.00	18.45	11.62	1.05	72553.26
8	9.73	8.11	42.39	1.21	19.00	10.93	1.05	77137.33
9	9.67	8.82	45.51	1.36	17.86	11.35	1.07	74884.99
10	8.57	11.05	53.86	1.38	16.94	11.99	1.04	70978.49
11	8.80	10.53	49.25	1.59	16.44	11.97	1.03	71158.26
12	9.63	6.42	61.58	1.04	17.60	11.76	1.05	72025.16
13	8.15	6.80	58.78	0.97	17.48	11.61	1.05	72214.08
14	9.79	8.48	47.74	1.26	16.47	11.26	1.05	75249.60
15	9.68	8.41	48.16	1.82	16.70	11.41	1.05	74647.58
16	7.13	6.03	55.91	1.23	17.04	11.91	1.03	70126.25
17	9.53	5.99	35.71	1.37	18.05	10.94	1.03	76996.51
18	7.54	6.34	48.69	0.96	17.86	11.50	1.07	73134.60
19	7.50	6.40	42.40	0.73	19.56	10.61	1.08	79186.90
20	9.41	6.32	55.58	1.10	19.16	10.94	1.05	77322.67
21	7.90	6.26	54.15	1.13	18.61	11.14	1.05	75595.13
22	8.08	6.25	43.62	1.17	18.97	10.85	1.05	77648.46
23	5.45	8.14	54.07	0.80	18.20	12.11	1.06	69098.82
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.87	8.20	48.97	1.27	18.03	11.36	1.05	74158.70
最大值	11.44	16.34	61.58	1.82	20.54	12.11	1.11	79186.90
發生時間	5	5	12	15	1	23		19
最小值	5.45	5.99	35.71	0.73	16.44	10.61	1.02	69098.82
發生時間	23	17	17	19	11	19		23
零點偏移(率)	-0.06 %	-0.01 %	-0.01 %	0.00 %		-0.14		0.00 %
全幅偏移(率)	0.02 %	1.01 %	-0.66 %	0.86 %		-0.05		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月27日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.45	9.39	41.92	1.99	16.87	10.08	1.05	86122.40
1	8.88	2.22	62.68	1.25	17.29	9.87	1.05	87434.24
2	9.79	3.79	63.36	1.50	16.90	9.82	1.06	88334.14
3	9.08	6.23	56.42	1.43	16.92	10.22	1.05	85522.13
4	8.86	4.99	53.35	1.94	15.14	10.78	1.05	82712.17
5	9.89	7.90	52.56	1.64	17.06	10.41	1.05	83750.18
6	8.65	8.27	49.76	1.95	15.73	10.38	1.02	87689.72
7	9.21	4.10	59.60	1.31	17.23	10.30	1.03	84757.02
8	3.66	3.69	56.50	1.19	16.40	10.29	1.05	85336.79
9	10.63	4.67	46.79	1.61	15.99	10.49	1.05	83801.20
10	7.89	3.71	55.11	1.19	16.72	10.19	1.01	86716.85
11	8.42	5.56	51.60	2.01	15.05	10.86	1.00	82865.03
12	9.46	4.33	54.42	1.75	15.44	10.79	1.02	82977.03
13	6.83	4.37	53.58	1.64	15.31	10.70	1.03	82654.32
14	4.94	4.54	54.12	1.56	15.31	10.56	1.05	84061.48
15	10.49	5.12	55.41	1.88	15.22	10.53	1.05	84239.81
16	7.85	4.24	63.69	1.73	15.29	10.94	1.04	80834.61
17	2.72	4.99	51.44	0.95	16.64	10.95	1.03	79656.81
18	5.44	4.37	44.80	1.07	18.74	10.06	1.03	84364.62
19	1.43	4.96	33.79	1.14	18.15	9.95	1.05	85687.68
20	0.75	7.18	52.89	1.47	15.58	12.00	1.04	71984.57
21	0.08	5.53	34.21	1.79	16.07	11.53	1.06	75146.14
22	0.10	5.13	29.05	2.25	15.21	10.90	1.03	81214.81
23	0.12	2.12	36.84	1.75	16.18	11.48	1.04	75545.97
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.40	5.06	50.58	1.58	16.27	10.59	1.04	83058.74
最大值	10.63	9.39	63.69	2.25	18.74	12.00	1.09	88334.14
發生時間	9	0	16	22	18	20		2
最小值	0.08	2.12	29.05	0.95	15.05	9.82	0.99	71984.57
發生時間	21	23	22	17	11	2		20
零點偏移(率)	-0.04 %	-0.03 %	-0.02 %	-0.01 %		0.03		-0.20 %
全幅偏移(率)	0.77 %	0.67 %	0.40 %	0.64 %		-0.10		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月27日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.02	10.74	47.82	1.92	15.79	10.77	0.97	81524.25
1	9.22	8.47	47.52	1.97	14.96	11.10	0.95	76126.33
2	8.85	8.91	65.04	1.46	17.27	10.08	0.97	83575.46
3	9.15	4.55	46.22	1.91	16.22	10.26	0.96	80959.31
4	10.50	8.05	57.70	2.25	15.69	10.22	0.95	79033.52
5	9.42	4.05	59.91	2.20	15.09	10.15	0.95	81675.39
6	9.10	8.20	48.01	2.11	14.07	10.80	0.95	74008.08
7	11.23	8.36	51.27	1.92	15.28	10.77	0.98	70990.19
8	8.70	5.86	42.83	1.60	15.07	10.73	0.97	75067.83
9	8.04	2.16	56.72	1.41	16.04	10.22	0.97	75633.57
10	10.06	3.13	53.40	2.05	14.70	10.45	0.97	74898.81
11	7.25	4.69	54.41	1.47	14.95	10.88	0.97	72364.37
12	9.06	7.66	48.06	1.84	14.45	10.87	0.96	73012.18
13	6.03	2.61	61.86	1.27	15.69	10.56	0.96	75617.24
14	9.75	5.81	54.59	2.12	13.94	10.77	0.96	76015.51
15	9.46	4.46	50.08	2.11	13.91	10.91	0.97	74334.66
16	8.25	8.09	53.31	2.06	14.47	10.62	0.97	74381.03
17	7.86	4.56	35.19	1.73	15.19	10.82	0.97	73821.96
18	6.52	7.60	43.18	1.52	15.60	10.51	0.96	75845.07
19	4.30	7.26	46.67	1.52	15.16	10.73	0.95	74446.22
20	4.67	5.51	57.40	1.35	15.89	10.88	0.97	73687.32
21	7.16	7.48	57.19	2.14	14.05	11.47	0.97	73133.51
22	5.28	1.90	54.75	1.31	16.53	10.96	0.97	77507.27
23	5.51	6.78	40.60	1.36	15.76	11.04	0.97	77665.82
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.14	6.12	51.41	1.78	15.24	10.69	0.96	76055.20
最大值	11.23	10.74	65.04	2.25	17.27	11.47	0.99	83575.46
發生時間	7	0	2	4	2	21		2
最小值	4.30	1.90	35.19	1.27	13.91	10.08	0.94	70990.19
發生時間	19	22	17	13	15	2		7
零點偏移(率)	-0.01 %	0.00 %	-0.02 %	-0.02 %		0.03		0.00 %
全幅偏移(率)	0.00 %	0.50 %	-0.32 %	0.15 %		-0.02		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								