

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月11日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.49	6.88	49.15	2.48	17.14	11.65	0.99	76241.38
1	4.62	6.62	55.77	1.52	18.18	11.92	0.98	74282.91
2	7.35	8.65	42.27	1.34	19.28	10.81	0.99	82336.99
3	7.73	9.30	45.09	2.06	16.36	11.82	1.01	76720.95
4	9.38	6.36	39.94	2.20	17.17	11.79	1.00	76706.62
5	13.23	7.52	49.80	2.37	16.21	12.16	1.05	75698.18
6	8.62	6.08	59.27	1.07	19.03	11.49	1.05	77022.04
7	7.98	6.54	51.45	1.87	17.42	11.76	1.07	76184.40
8	9.30	6.00	45.10	2.18	18.06	11.47	1.05	78128.97
9	5.89	6.16	49.43	1.12	18.83	11.52	1.06	76794.32
10	0.68	8.12	52.68	0.73	18.33	12.11	1.06	72551.85
11	2.53	7.19	55.99	0.75	18.73	11.36	1.07	78306.65
12	3.19	6.89	44.58	1.37	17.26	11.66	1.06	76956.37
13	2.63	5.98	52.08	1.54	16.84	11.86	1.07	75723.14
14	0.22	7.32	63.38	0.51	18.11	11.02	1.06	71907.29
15	2.20	4.88	56.34	0.94	17.46	10.71	1.05	79138.05
16	7.24	6.45	48.03	1.54	17.11	11.03	1.05	82027.05
17	7.85	4.22	45.04	2.63	16.18	11.71	1.04	75375.98
18	9.52	8.94	52.10	2.28	16.62	11.67	1.06	77794.22
19	7.95	6.31	51.03	1.90	16.54	11.53	1.05	78602.16
20	8.73	7.43	51.72	1.65	16.56	11.72	1.05	76444.65
21	6.62	7.24	60.18	1.09	17.41	11.75	1.03	76528.36
22	2.87	9.00	57.08	0.84	17.46	11.82	1.02	75752.95
23	2.82	8.50	53.42	0.81	17.89	11.35	1.05	79377.15
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.03	7.02	51.29	1.53	17.51	11.57	1.04	76941.78
最大值	13.23	9.30	63.38	2.63	19.28	12.16	1.09	82336.99
發生時間	5	3	14	17	2	5		2
最小值	0.22	4.22	39.94	0.51	16.18	10.71	0.98	71907.29
發生時間	14	17	4	14	17	15		14
零點偏移(率)	-0.05 %	-0.01 %	-0.01 %	0.00 %		0.00		0.00 %
全幅偏移(率)	0.02 %	1.21 %	-0.01 %	0.46 %		-0.08		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月11日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.73	6.51	39.86	1.59	17.42	10.05	0.97	86146.18
1	5.74	6.46	43.26	1.88	19.50	9.93	0.97	85716.93
2	8.66	3.58	57.02	1.99	18.80	9.79	0.96	88473.79
3	8.15	2.52	48.70	2.49	16.09	10.78	0.94	83925.05
4	5.00	5.34	42.71	2.32	16.98	10.81	0.94	80620.73
5	3.25	2.96	55.68	1.15	18.01	10.52	0.95	83553.37
6	8.08	7.71	48.31	2.36	17.11	9.95	0.97	86681.10
7	8.23	5.77	42.76	2.29	16.81	10.49	0.97	83576.08
8	5.79	6.18	54.05	1.52	19.18	10.19	1.00	85028.70
9	1.55	3.13	45.87	1.22	19.58	9.76	1.01	87633.75
10	2.70	3.73	45.72	2.43	17.88	10.32	1.00	85290.16
11	1.38	3.47	40.79	1.42	17.62	10.61	0.99	83351.57
12	0.57	4.30	46.74	1.27	17.96	10.39	0.99	84820.08
13	2.93	4.38	41.26	1.32	18.60	10.10	1.02	86165.34
14	4.23	3.78	44.54	1.39	18.90	10.45	1.02	83129.02
15	4.52	4.61	37.76	1.40	19.00	10.29	1.02	83930.47
16	4.80	4.92	41.82	2.22	17.48	10.39	1.00	84812.62
17	4.65	5.18	46.86	2.26	17.55	10.58	0.99	83455.77
18	5.43	4.59	39.58	1.80	18.47	9.95	0.99	85633.58
19	3.53	8.60	39.01	1.10	19.40	10.02	0.99	85557.63
20	3.17	9.48	39.76	1.68	19.00	9.95	0.99	86730.08
21	3.31	4.77	48.27	1.64	19.29	9.89	0.99	86803.98
22	1.06	5.19	39.78	1.43	19.05	10.06	0.99	85940.28
23	0.29	9.85	41.23	1.18	18.64	10.56	1.01	82506.16
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.11	5.29	44.64	1.72	18.26	10.24	0.99	84978.43
最大值	8.66	9.85	57.02	2.49	19.58	10.81	1.02	88473.79
發生時間	2	23	2	3	9	4		2
最小值	0.29	2.52	37.76	1.10	16.09	9.76	0.94	80620.73
發生時間	23	3	15	19	3	9		4
零點偏移(率)	-0.08 %	-0.09 %	-0.03 %	-0.01 %		0.02		-0.20 %
全幅偏移(率)	0.04 %	0.10 %	-0.31 %	0.29 %		-0.24		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月11日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.91	4.28	52.30	2.01	16.35	10.09	1.02	80919.74
1	7.89	6.17	43.27	1.60	17.25	10.53	1.02	74674.23
2	5.08	26.91	22.69	5.56	18.52	8.64	1.02	82754.01
3	7.34	2.18	52.51	2.48	16.11	9.99	1.02	73086.47
4	6.24	3.31	50.72	2.46	16.15	10.13	1.02	71132.00
5	5.05	6.08	38.82	2.41	14.74	10.46	1.00	69570.66
6	4.16	3.06	48.79	1.62	15.37	10.99	1.01	73320.60
7	11.01	5.32	64.82	3.39	17.59	9.54	1.02	82188.61
8	8.43	5.37	57.53	2.42	16.46	9.97	1.01	74765.94
9	4.52	10.22	52.30	1.75	18.11	9.12	0.99	76609.79
10	2.65	1.64	53.56	1.52	16.97	9.76	1.02	75344.28
11	0.84	7.16	34.12	0.63	17.63	9.39	1.02	75776.77
12	1.79	5.25	44.97	1.79	14.21	10.46	1.00	75239.08
13	3.56	8.31	35.39	2.49	13.51	10.69	1.03	73195.24
14	6.55	1.94	45.62	1.50	15.47	11.15	1.05	74510.35
15	9.63	6.78	38.08	2.37	15.60	10.72	1.04	75681.16
16	7.22	3.01	47.96	1.62	16.05	10.77	1.02	73910.46
17	6.43	8.18	40.99	2.06	13.70	11.07	0.99	73230.30
18	7.09	9.79	44.02	1.26	15.75	10.69	1.02	75279.04
19	7.73	11.71	41.72	2.03	15.12	10.66	1.02	77334.80
20	7.93	6.55	40.27	2.42	14.63	11.15	0.98	73494.57
21	10.54	7.23	39.15	1.81	14.84	11.06	0.99	77990.96
22	8.34	6.86	53.41	1.71	14.96	11.16	1.00	76156.83
23	9.80	9.61	49.03	1.30	16.20	10.60	1.00	78712.63
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.61	6.96	45.50	2.09	15.89	10.37	1.01	75619.94
最大值	11.01	26.91	64.82	5.56	18.52	11.16	1.05	82754.01
發生時間	7	2	7	2	2	22		2
最小值	0.84	1.64	22.69	0.63	13.51	8.64	0.97	69570.66
發生時間	11	10	2	11	13	2		5
零點偏移(率)	-0.01 %	0.00 %	-0.00 %	-0.01 %		-0.01		0.00 %
全幅偏移(率)	-0.69 %	0.57 %	-0.35 %	0.14 %		0.29		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								