

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年07月05日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.49	3.89	54.15	2.23	16.43	11.92	0.99	78736.95
1	7.27	4.76	55.45	2.28	17.07	11.88	0.98	78399.50
2	8.95	3.80	55.52	2.28	16.59	11.84	0.97	78432.30
3	8.43	3.11	55.47	2.37	16.51	11.79	0.97	79706.07
4	7.93	4.17	54.93	2.19	16.97	11.70	0.97	80694.35
5	6.39	2.51	48.48	2.39	16.96	11.63	0.97	82091.29
6	8.85	3.73	48.93	2.92	16.49	11.72	0.97	80712.15
7	9.63	4.25	56.58	1.96	18.43	11.33	0.97	82142.67
8	7.88	3.02	55.69	1.58	17.97	11.55	1.00	81828.42
9	9.19	2.92	66.87	2.21	18.25	11.73	0.97	82017.44
10	5.65	5.51	61.95	1.11	19.36	11.88	0.99	80149.38
11	6.78	3.08	50.31	1.03	20.01	11.16	0.97	85920.09
12	9.13	13.84	48.52	2.00	18.61	11.37	0.97	85434.79
13	5.90	16.18	46.33	3.10	16.09	12.35	0.97	77988.71
14	9.41	5.43	54.48	3.06	16.24	12.12	0.97	80021.90
15	10.92	3.70	63.37	2.00	18.40	11.56	0.98	81314.18
16	11.30	3.56	53.14	2.01	19.24	11.10	1.00	83782.80
17	9.01	3.38	49.55	1.86	18.77	11.27	1.02	82776.89
18	9.23	3.43	49.96	2.44	17.03	11.51	1.02	82467.09
19	9.45	3.69	53.73	2.18	17.84	11.47	1.02	81778.86
20	10.52	3.59	58.23	1.86	19.13	11.07	1.02	83902.92
21	11.52	4.72	44.00	3.57	16.97	11.40	1.01	82205.83
22	14.04	4.92	45.07	3.06	15.85	11.88	0.97	75779.09
23	8.07	3.70	60.46	2.07	17.17	11.90	0.98	78029.53
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.83	4.79	53.80	2.24	17.60	11.63	0.99	81096.38
最 大 值	14.04	16.18	66.87	3.57	20.01	12.35	1.03	85920.09
發生時間	22	13	9	21	11	13		11
最 小 值	5.65	2.51	44.00	1.03	15.85	11.07	0.97	75779.09
發生時間	10	5	21	11	22	20		22
零點偏移(率)	0.00 %	-0.00 %	-0.06 %	0.00 %		-0.08		0.00 %
全幅偏移(率)	0.00 %	-0.07 %	0.21 %	0.23 %		0.03		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

報表日期: 113年07月05日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.91	2.66	52.38	1.93	16.57	11.47	0.94	78030.96
1	5.21	2.47	51.29	2.47	16.07	11.80	0.94	75437.09
2	2.51	2.21	56.72	2.03	17.21	11.49	0.94	77598.44
3	6.01	2.19	48.43	1.95	16.96	11.05	0.94	81008.39
4	3.91	4.60	49.02	2.11	16.17	11.26	0.94	79756.50
5	2.57	2.61	47.85	2.07	15.35	11.42	0.94	79662.50
6	1.98	1.78	52.65	1.59	16.23	11.43	0.98	76490.06
7	1.14	1.97	59.44	0.91	18.51	11.15	0.98	78503.15
8	4.90	2.12	46.39	2.05	16.62	11.02	0.95	81327.65
9	6.04	1.74	48.73	2.02	17.19	11.00	0.97	80319.69
10	1.49	1.71	61.12	1.07	16.78	11.66	0.99	76159.09
11	0.92	3.64	45.85	1.66	16.97	11.04	0.98	80396.03
12	1.50	6.74	49.32	3.20	14.39	11.61	0.97	78226.84
13	1.37	2.28	51.68	2.78	14.94	11.66	0.98	77505.66
14	5.39	3.86	48.37	3.21	15.05	11.32	0.97	80128.90
15	6.98	1.04	48.48	2.42	16.06	11.33	0.97	79993.38
16	8.86	1.29	52.67	2.07	17.31	10.90	0.98	81917.40
17	2.61	7.96	55.51	1.91	16.95	11.25	0.98	79780.60
18	7.04	3.23	45.50	2.00	17.55	10.52	0.99	84085.13
19	5.63	4.34	44.79	2.45	16.53	10.80	0.99	83344.80
20	8.67	1.72	42.89	2.49	16.09	11.05	0.98	81513.67
21	7.92	5.15	43.70	2.63	15.09	11.39	0.97	79449.90
22	8.11	2.31	55.55	1.52	16.96	11.37	0.96	78481.17
23	8.12	3.58	49.15	1.74	17.02	11.27	0.97	78820.19
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.70	3.05	50.31	2.10	16.44	11.26	0.97	79497.38
最 大 值	8.86	7.96	61.12	3.21	18.51	11.80	1.01	84085.13
發生時間	16	17	10	14	7	1		18
最 小 值	0.92	1.04	42.89	0.91	14.39	10.52	0.94	75437.09
發生時間	11	15	20	7	12	18		1
零點偏移(率)	-0.01 %	0.00 %	-0.09 %	-0.02 %		-0.06		0.00 %
全幅偏移(率)	0.13 %	0.00 %	0.15 %	0.34 %		-0.06		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年07月05日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	1.78	2.28	62.88	1.35	17.71	10.83	0.95	77796.27
1	1.16	2.42	56.48	1.32	18.73	10.38	0.98	80711.83
2	1.23	2.80	53.51	1.36	17.65	10.83	1.01	77236.30
3	1.17	3.96	55.67	1.30	17.55	10.57	0.99	77964.32
4	1.21	2.42	55.49	1.50	16.36	10.97	0.99	78322.37
5	1.29	2.71	54.58	1.94	15.29	11.09	0.98	77563.42
6	1.23	2.65	57.01	2.11	14.62	11.43	0.98	76063.39
7	1.22	4.28	54.18	1.31	16.51	10.81	0.96	78004.88
8	1.23	2.99	57.36	1.41	16.22	11.02	0.97	77973.24
9	1.24	2.70	56.82	1.33	16.57	10.92	0.92	78350.01
10	0.11	3.09	54.00	1.30	16.33	11.01	0.97	77840.68
11	0.78	2.91	54.96	1.71	15.31	11.11	0.97	78701.48
12	1.71	3.63	50.26	2.05	14.80	11.19	0.93	77346.06
13	1.22	2.95	55.30	1.86	15.16	11.30	0.95	75102.93
14	2.82	3.81	55.68	1.81	15.47	11.01	0.93	78582.43
15	1.54	6.70	53.83	2.33	14.26	11.12	0.95	75673.84
16	1.21	3.01	52.48	1.66	15.34	10.98	0.99	76028.95
17	1.21	2.17	54.22	1.48	16.02	10.74	0.99	79140.40
18	2.12	2.04	61.72	1.50	16.59	10.89	0.98	77948.36
19	4.73	1.86	53.40	1.79	15.44	10.89	0.95	77994.19
20	2.36	2.21	51.38	1.47	16.27	10.78	0.93	77712.56
21	6.42	3.61	49.36	2.29	15.25	10.94	0.93	77285.29
22	2.47	3.47	53.84	2.07	14.82	11.34	0.98	75300.76
23	3.98	3.57	59.96	1.67	16.50	10.94	0.99	78733.04
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	1.89	3.09	55.18	1.66	16.03	10.96	0.96	77640.71
最 大 值	6.42	6.70	62.88	2.33	18.73	11.43	1.02	80711.83
發生時間	21	15	0	15	1	6		1
最 小 值	0.11	1.86	49.36	1.30	14.26	10.38	0.92	75102.93
發生時間	10	19	21	3	15	1		13
零點偏移(率)	-0.08 %	0.00 %	-0.03 %	-0.03 %		-0.02		0.00 %
全幅偏移(率)	0.02 %	0.11 %	-0.70 %	0.10 %		0.46		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								