

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月15日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.09	14.47	54.05	0.42	17.17	11.33	0.99	81987.78
1	6.21	14.80	61.87	0.51	18.51	11.12	1.00	82237.01
2	6.78	7.27	50.32	1.12	16.43	11.39	0.99	81232.47
3	2.88	11.24	56.41	0.34	17.36	11.21	0.99	83541.95
4	3.65	13.20	50.18	0.43	17.13	11.43	0.99	80227.44
5	9.57	14.57	57.62	0.85	16.17	11.45	0.99	87905.07
6	7.65	9.17	48.21	0.61	17.02	11.35	0.97	79476.37
7	6.01	6.49	47.49	0.74	16.77	11.42	0.99	81381.58
8	9.95	9.22	57.96	0.88	17.33	11.51	0.99	79409.56
9	9.74	8.91	46.52	0.92	17.22	10.90	0.97	83549.28
10	9.27	8.53	52.94	1.02	16.54	11.65	0.99	79200.75
11	8.79	8.75	51.68	0.59	16.90	11.11	0.98	80647.12
12	6.80	12.72	52.36	1.03	15.78	11.85	0.97	75124.79
13	5.30	9.15	56.82	0.65	17.51	11.57	0.97	78804.83
14	8.27	11.30	53.50	0.33	18.16	10.93	0.97	81802.66
15	9.86	11.18	46.03	0.75	16.95	11.29	0.98	79592.49
16	8.20	4.78	51.40	0.39	17.49	11.28	0.99	80376.82
17	8.47	9.13	49.81	0.85	15.93	11.65	0.99	78018.69
18	5.80	5.67	59.48	0.36	17.37	11.43	0.99	79857.59
19	6.87	6.33	52.87	0.62	16.99	11.55	0.99	79776.11
20	3.09	6.17	60.67	0.26	18.78	11.15	0.98	81549.26
21	7.08	6.45	48.52	0.56	17.13	11.25	0.97	81734.43
22	10.25	12.90	60.35	0.85	17.33	11.34	0.97	81276.36
23	9.48	10.46	50.96	0.49	18.19	10.95	0.97	83274.13
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.42	9.70	53.25	0.65	17.17	11.34	0.98	80916.02
最大值	10.25	14.80	61.87	1.12	18.78	11.85	1.01	87905.07
發生時間	22	1	1	2	20	12		5
最小值	2.88	4.78	46.03	0.26	15.78	10.90	0.96	75124.79
發生時間	3	16	15	20	12	9		12
零點偏移(率)	-0.01 %	0.00 %	-0.00 %	-0.00 %		0.00		0.00 %
全幅偏移(率)	0.01 %	-0.47 %	0.01 %	0.00 %		-0.01		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月15日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.90	7.54	47.85	0.91	17.58	9.62	1.10	77918.48
1	3.53	13.25	47.02	0.72	19.12	9.29	1.10	82254.53
2	7.35	11.89	52.44	1.69	15.62	10.20	1.10	77149.22
3	2.47	16.07	54.53	0.47	17.99	9.85	1.10	77376.66
4	3.87	7.46	58.05	0.83	16.27	9.94	1.10	78986.51
5	7.34	14.23	56.89	0.44	18.80	9.44	1.10	78729.99
6	2.67	7.87	54.55	0.15	19.55	9.31	1.06	79003.55
7	5.50	11.69	45.16	0.51	18.51	9.03	1.06	80334.28
8	9.43	10.25	40.25	0.56	19.59	8.84	1.06	81822.74
9	8.42	3.34	61.74	0.37	20.29	9.32	1.09	80860.46
10	8.41	13.07	39.45	0.64	18.96	9.16	1.07	81186.89
11	9.76	4.45	42.98	1.36	16.38	9.73	1.07	79296.19
12	10.38	6.53	66.95	1.20	16.57	10.09	1.07	82029.09
13	5.38	6.45	63.41	0.45	19.35	9.69	1.07	79744.67
14	8.98	6.59	44.74	0.69	17.70	9.72	1.07	79246.27
15	9.56	11.76	48.56	0.88	16.89	9.80	1.07	72245.68
16	8.43	7.21	47.29	0.97	16.15	9.91	1.07	78005.97
17	9.36	7.62	49.24	0.88	17.19	9.82	1.08	79962.80
18	9.30	3.89	54.39	0.93	16.80	9.92	1.08	78855.60
19	6.85	3.26	46.95	0.54	17.92	9.76	1.08	81798.47
20	2.65	11.49	52.05	0.60	18.49	9.66	1.09	81224.09
21	6.08	3.71	53.29	0.97	16.61	10.17	1.07	81039.76
22	7.35	6.40	57.57	0.65	17.82	9.79	1.07	83065.97
23	6.97	4.67	51.50	0.60	17.68	10.02	1.07	83461.13
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.04	8.36	51.54	0.75	17.83	9.67	1.08	79816.63
最大值	10.38	16.07	66.95	1.69	20.29	10.20	1.11	83461.13
發生時間	12	3	12	2	9	2		23
最小值	2.47	3.26	39.45	0.15	15.62	8.84	1.05	72245.68
發生時間	3	19	10	6	2	8		15
零點偏移(率)	-0.49 %	-0.03 %	-0.09 %	-0.04 %		-0.08		0.00 %
全幅偏移(率)	0.04 %	-0.03 %	-1.00 %	0.37 %		-0.09		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月15日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.33	8.79	55.28	1.89	14.93	11.50	0.98	76239.45
1	3.30	6.19	51.03	1.52	17.32	10.70	1.00	82438.43
2	4.50	9.73	51.82	1.97	15.87	10.93	1.02	81542.54
3	4.30	10.10	55.59	1.89	15.73	11.01	1.02	83227.66
4	7.87	11.20	50.67	2.21	15.37	11.11	0.99	79067.22
5	6.63	16.61	49.50	1.60	17.35	10.65	0.98	80034.44
6	8.43	9.67	43.05	1.67	17.76	10.10	0.99	79670.12
7	7.13	11.19	39.10	1.80	15.80	10.57	0.98	72911.79
8	6.51	8.65	38.77	1.66	15.80	10.54	0.98	74765.54
9	6.60	7.52	46.38	1.60	16.42	10.77	0.99	72759.89
10	7.78	9.58	45.51	1.94	15.86	10.67	0.95	74861.38
11	4.50	6.39	40.81	1.83	14.89	10.71	0.98	74488.63
12	2.39	7.28	52.45	2.63	13.74	11.50	0.99	73852.52
13	6.24	4.99	53.98	2.30	14.68	11.29	0.99	74682.56
14	3.69	11.05	46.54	2.26	15.70	10.98	0.99	76586.29
15	3.11	4.65	52.67	1.75	15.97	11.10	0.97	77796.26
16	5.97	4.99	53.57	1.82	16.45	10.93	0.96	79169.86
17	4.43	4.98	54.13	1.97	15.21	11.17	0.99	78646.35
18	1.47	4.97	55.30	1.46	16.09	10.99	1.00	80489.20
19	1.19	5.37	54.27	1.27	16.84	10.89	1.00	81137.18
20	1.33	5.88	56.72	1.32	16.84	10.92	0.99	82254.27
21	2.56	7.33	51.94	1.62	15.91	11.02	0.97	82245.11
22	2.71	7.05	59.68	1.70	15.67	11.30	0.97	79995.05
23	2.52	7.86	51.30	1.37	16.35	10.92	0.94	80628.95
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.56	8.00	50.42	1.79	15.94	10.93	0.98	78312.11
最大值	8.43	16.61	59.68	2.63	17.76	11.50	1.02	83227.66
發生時間	6	5	22	12	6	0		3
最小值	1.19	4.65	38.77	1.27	13.74	10.10	0.94	72759.89
發生時間	19	15	8	19	12	6		9
零點偏移(率)	-0.25 %	-0.01 %	-0.17 %	-0.02 %		0.00		0.00 %
全幅偏移(率)	-0.56 %	0.63 %	-0.81 %	0.27 %		0.09		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

