

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月04日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.54	3.21	60.65	3.06	14.23	12.41	1.45	69612.34
1	3.77	3.10	64.35	3.27	14.83	12.70	1.46	66834.85
2	1.69	3.49	61.64	3.11	14.25	12.63	1.46	67860.23
3	8.87	3.59	58.08	4.06	13.24	12.81	1.46	67880.04
4	11.56	7.41	64.84	5.16	13.58	12.47	1.46	69822.15
5	7.82	8.98	66.88	4.68	12.36	13.03	1.43	67254.69
6	7.70	6.44	56.46	5.08	11.87	13.24	1.43	66237.00
7	6.75	2.91	56.51	4.77	12.75	13.29	1.40	66428.23
8	5.58	4.22	61.85	4.13	12.92	12.89	1.41	67326.20
9	8.85	4.41	60.97	4.37	12.65	12.85	1.44	67134.73
10	9.30	4.85	54.58	4.11	13.39	12.69	1.44	67914.38
11	10.15	1.91	57.23	3.67	14.19	12.65	1.40	68315.12
12	3.04	1.77	68.36	3.17	14.43	12.90	1.40	66035.69
13	2.06	3.14	45.64	3.71	13.93	12.98	1.40	66817.39
14	6.63	4.98	42.70	3.69	14.09	12.50	1.38	67711.74
15	2.42	9.36	37.16	3.88	12.97	12.57	1.38	67283.83
16	7.23	4.83	57.07	4.33	12.90	12.82	1.39	66483.10
17	2.66	1.44	64.50	3.06	14.38	12.31	1.40	70919.01
18	0.91	5.02	57.29	3.35	13.69	12.44	1.40	69775.55
19	2.31	7.68	59.25	3.85	12.87	12.56	1.41	69045.54
20	2.21	4.44	55.13	3.40	13.59	12.44	1.43	69557.61
21	0.58	5.10	60.12	3.23	13.91	12.51	1.46	68957.98
22	0.21	7.70	70.22	3.18	14.36	12.75	1.46	67335.19
23	0.42	12.23	53.97	3.39	13.71	12.53	1.45	69330.97
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.80	5.09	58.14	3.82	13.55	12.71	1.43	67994.73
最大值	11.56	12.23	70.22	5.16	14.83	13.29	1.47	70919.01
發生時間	4	23	22	4	1	7		17
最小值	0.21	1.44	37.16	3.06	11.87	12.31	1.38	66035.69
發生時間	22	17	15	0	6	17		12
零點偏移(率)	-0.02 %	0.00 %	-0.01 %	-0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	1.81 %	0.19 %	-0.45 %	0.20 %		0.16	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月04日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.66	1.73	60.32	1.49	17.47	10.01	1.44	62169.70
1	4.98	1.61	58.90	1.12	19.05	10.06	1.45	63423.70
2	1.54	1.73	65.16	1.21	18.03	10.99	1.45	59270.34
3	1.04	2.53	67.01	1.49	17.25	11.68	1.45	55952.60
4	4.40	2.40	43.23	1.41	18.07	9.93	1.45	65086.70
5	7.19	5.51	53.23	1.91	16.01	10.34	1.45	63676.23
6	12.09	1.42	65.68	1.90	17.52	10.10	1.45	64785.66
7	8.02	0.71	64.36	1.38	18.90	9.92	1.44	64106.31
8	7.22	6.68	43.88	1.79	17.36	10.00	1.43	60091.31
9	5.06	7.64	49.46	1.38	18.52	9.61	1.43	63236.97
10	6.81	2.92	47.45	1.99	16.08	10.66	1.39	58960.27
11	3.31	1.15	54.21	1.45	17.38	10.36	1.38	60089.04
12	8.96	0.86	62.14	1.53	18.10	11.03	1.38	58008.84
13	9.73	3.94	41.90	2.06	19.04	9.80	1.38	63223.02
14	11.67	7.74	37.12	2.78	16.29	10.21	1.38	61125.30
15	9.01	6.24	44.62	2.19	16.43	10.42	1.38	60408.69
16	3.38	5.03	60.94	1.38	17.94	10.32	1.38	55860.35
17	7.07	5.96	47.54	1.48	18.68	9.52	1.38	64098.54
18	6.47	4.27	51.55	1.64	16.98	9.93	1.37	60235.74
19	3.46	4.60	42.10	1.67	16.10	10.02	1.38	60136.65
20	3.54	8.78	39.55	1.69	17.07	10.32	1.38	62461.50
21	2.63	2.31	40.87	1.27	18.07	9.56	1.39	61009.93
22	0.41	1.58	52.11	0.81	19.43	9.82	1.40	60038.79
23	0.31	6.77	46.70	0.83	19.29	9.43	1.38	61610.95
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.58	3.92	51.67	1.58	17.71	10.17	1.41	61211.13
最大值	12.09	8.78	67.01	2.78	19.43	11.68	1.46	65086.70
發生時間	6	20	3	14	22	3		4
最小值	0.31	0.71	37.12	0.81	16.01	9.43	1.36	55860.35
發生時間	23	7	14	22	5	23		16
零點偏移(率)	-0.02 %	0.00 %	0.00 %	-0.01 %		-0.08	0.00	0.00 %
全幅偏移(率)	0.24 %	0.57 %	0.02 %	0.35 %		-0.03	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

