

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年08月30日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	5.45	4.90	50.94	1.46	17.83	11.51	0.96	82518.99
1	3.66	5.00	54.18	1.59	19.56	11.12	0.97	83778.23
2	4.11	4.71	56.93	1.77	18.57	11.24	0.97	84331.98
3	7.80	4.59	57.93	2.12	18.58	11.17	0.97	84545.49
4	8.28	5.14	59.20	2.40	17.77	11.50	0.97	82608.38
5	6.94	3.95	51.12	1.63	18.87	11.17	0.96	84819.41
6	6.66	3.82	52.59	2.05	18.46	11.52	0.97	81801.28
7	2.87	3.80	62.32	1.74	18.30	11.75	0.97	79552.25
8	3.96	3.76	53.38	1.77	19.30	11.12	0.98	83777.04
9	2.65	3.95	49.24	1.72	19.55	11.09	0.97	83697.11
10	4.51	3.81	43.14	2.48	17.80	11.74	0.97	80082.71
11	8.53	3.52	46.16	2.86	16.88	12.02	0.97	78096.16
12	5.84	3.25	46.88	2.21	17.01	12.02	0.96	78023.53
13	7.89	3.57	43.60	2.44	17.93	12.12	0.97	77093.63
14	8.22	3.48	44.75	2.48	17.95	11.88	0.97	78452.47
15	7.04	3.42	55.71	1.93	19.05	11.97	0.97	77956.14
16	9.05	5.95	48.45	1.13	21.51	10.55	0.96	86300.97
17	8.49	3.54	45.57	1.61	20.02	10.97	0.97	83854.35
18	8.00	4.55	46.77	2.42	18.02	11.64	0.97	79458.16
19	9.27	4.94	54.64	2.59	18.24	11.63	0.97	78642.11
20	7.23	3.50	48.63	1.94	18.55	11.16	0.96	83866.79
21	5.41	3.23	47.45	1.93	18.71	11.13	0.96	84128.44
22	3.01	3.69	49.24	3.32	16.74	11.86	0.97	79793.45
23	8.17	3.80	49.99	1.48	16.49	12.05	0.97	79182.59
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.38	4.08	50.78	2.04	18.40	11.50	0.97	81515.07
最 大 值	9.27	5.95	62.32	3.32	21.51	12.12	0.99	86300.97
發生時間	19	16	7	22	16	13		16
最 小 值	2.65	3.23	43.14	1.13	16.49	10.55	0.94	77093.63
發生時間	9	21	10	16	23	16		13
零點偏移(率)	-0.01 %	-0.00 %	-0.01 %	-0.01 %		-0.08		0.00 %
全幅偏移(率)	0.00 %	0.18 %	0.19 %	0.31 %		-0.02		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年08月30日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.16	1.45	57.62	2.29	15.47	11.48	0.85	79338.03
1	9.40	1.95	58.43	2.47	17.18	11.00	0.85	82182.76
2	9.17	1.25	65.21	1.47	17.61	10.86	0.87	83753.42
3	11.04	3.06	46.56	2.16	17.07	10.85	0.85	83341.41
4	6.86	3.00	53.97	1.80	16.90	11.75	0.87	76351.52
5	10.14	2.80	55.99	1.34	18.43	10.47	0.87	85137.68
6	5.97	2.54	59.39	1.92	16.86	11.50	0.88	85177.59
7	9.54	1.95	45.01	2.32	16.79	11.00	0.88	82219.14
8	9.29	2.48	51.11	2.23	17.48	10.92	0.88	81426.96
9	8.31	1.99	51.10	2.84	16.54	11.19	0.88	80096.01
10	11.66	3.11	45.62	3.86	15.20	11.57	0.87	78216.44
11	9.68	4.53	50.94	3.58	14.55	11.70	0.88	78161.76
12	10.51	5.17	52.53	3.23	14.08	11.73	0.88	76368.53
13	11.85	1.21	59.75	2.41	17.43	11.29	0.86	79877.67
14	11.76	1.01	58.46	2.24	17.94	10.77	0.85	82831.66
15	10.60	1.32	49.90	2.57	16.84	11.83	0.85	76393.34
16	10.98	0.96	50.41	1.84	17.95	10.48	0.85	85468.16
17	11.85	1.05	55.53	2.58	17.14	10.70	0.87	83760.26
18	11.86	6.32	43.99	3.24	14.93	11.10	0.86	77628.31
19	8.93	3.75	55.18	2.37	15.32	11.21	0.84	79883.75
20	8.67	1.90	57.36	2.04	15.56	11.22	0.85	81524.77
21	8.65	2.28	58.98	2.08	16.16	10.82	0.88	84329.09
22	9.39	2.32	59.59	1.60	15.23	11.35	0.85	80052.17
23	10.11	2.19	61.49	1.88	15.31	11.50	0.84	81769.55
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.85	2.48	54.34	2.35	16.42	11.18	0.86	81053.75
最 大 值	11.86	6.32	65.21	3.86	18.43	11.83	0.88	85468.16
發生時間	18	18	2	10	5	15		16
最 小 值	5.97	0.96	43.99	1.34	14.08	10.47	0.83	76351.52
發生時間	6	16	18	5	12	5		4
零點偏移(率)	-0.02 %	-0.00 %	-0.32 %	-0.04 %		-0.07		-0.10 %
全幅偏移(率)	0.13 %	0.23 %	0.10 %	0.05 %		-0.19		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

