

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年01月30日

報表日期: 113年01月30日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.21	6.96	58.60	1.14	14.98	13.18	1.05	68440.03
1	5.84	7.50	56.73	1.62	15.67	13.00	1.04	70581.20
2	7.63	6.17	56.47	1.07	15.81	12.77	1.04	72051.70
3	6.90	5.62	60.93	0.59	16.19	12.34	1.06	76414.93
4	9.79	6.42	28.83	1.24	15.78	11.55	1.06	83312.60
5	12.26	5.48	46.62	2.96	15.10	12.01	1.04	72058.82
6	8.71	4.03	50.45	3.09	14.18	12.16	1.04	79011.38
7	9.38	3.46	56.18	2.85	13.72	12.32	1.04	78202.65
8	9.54	3.23	52.62	2.26	13.78	12.23	1.05	78795.60
9	9.10	3.12	52.93	2.19	13.70	12.29	1.06	78102.20
10	9.36	8.07	50.94	1.68	14.89	12.02	1.05	80408.37
11	9.76	3.24	49.02	2.02	14.41	12.18	1.05	78969.07
12	8.92	4.35	49.18	2.76	13.36	12.37	1.06	77377.58
13	9.81	4.96	54.78	1.47	15.00	11.81	1.09	81508.46
14	9.05	6.48	52.92	3.04	12.57	12.34	1.09	78241.16
15	10.10	11.78	46.75	3.30	13.32	12.50	1.06	75773.95
16	10.90	3.13	46.30	2.00	14.59	11.89	1.06	81167.90
17	9.10	5.06	44.81	2.76	13.05	12.19	1.06	78844.96
18	9.77	5.52	55.69	2.47	13.85	12.46	1.05	75767.00
19	7.56	7.68	54.80	2.10	13.53	12.78	1.05	72570.96
20	9.55	8.99	65.65	1.64	14.21	12.30	1.08	76529.63
21	12.40	9.86	48.22	2.24	14.18	11.80	1.09	82296.52
22	9.23	9.70	49.61	2.41	13.40	12.19	1.09	76612.07
23	10.29	8.89	46.16	2.54	13.27	12.25	1.10	76060.59
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.34	6.24	51.47	2.14	14.27	12.29	1.06	77045.81
最 大 值	12.40	11.78	65.65	3.30	16.19	13.18	1.11	83312.60
發生時間	21	15	20	15	3	0		4
最 小 值	5.84	3.12	28.83	0.59	12.57	11.55	1.02	68440.03
發生時間	1	9	4	3	14	4		0
零點偏移(率)	0.00 %	-0.12 %	-0.03 %	-0.01 %		-0.02		0.20 %
全幅偏移(率)	0.02 %	0.38 %	-0.49 %	0.17 %		0.00		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年01月30日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.42	6.90	44.38	1.81	15.68	11.17	1.04	78674.89
1	7.19	6.19	42.35	2.24	15.49	11.50	1.02	76521.81
2	8.08	5.97	48.36	2.20	15.16	11.54	1.03	77836.35
3	8.14	6.13	41.94	2.01	15.93	11.33	1.05	78568.93
4	6.94	9.73	47.88	2.79	14.68	11.93	1.04	74459.13
5	6.55	5.08	48.40	3.25	14.65	11.72	1.04	76443.24
6	6.91	7.39	50.39	3.22	14.97	11.43	1.03	80403.24
7	9.36	5.69	41.75	2.65	15.61	11.20	1.03	79187.82
8	8.98	3.69	41.98	2.47	14.41	11.31	1.04	79333.10
9	7.55	2.80	52.48	1.41	16.60	11.07	1.04	79659.78
10	7.39	4.44	43.23	2.40	14.38	11.54	1.04	77416.31
11	7.77	2.02	46.42	2.92	13.12	11.88	1.03	76144.54
12	9.53	2.02	44.32	3.14	13.18	11.69	1.04	77847.21
13	8.09	2.72	47.15	2.92	12.81	11.85	1.07	76504.78
14	8.75	3.33	45.57	3.03	12.87	11.81	1.03	76683.45
15	8.05	2.58	43.47	2.74	13.61	11.68	1.02	77155.29
16	6.27	2.03	45.42	2.51	13.16	11.95	1.04	75089.93
17	7.38	2.74	48.87	2.73	13.49	11.86	1.04	75746.45
18	9.02	1.92	49.02	2.42	14.21	11.55	1.03	77901.14
19	6.65	4.54	49.29	2.50	13.67	11.96	1.02	75117.18
20	7.69	3.65	46.89	2.91	13.84	11.51	1.02	78956.80
21	10.03	4.50	46.14	3.63	12.77	11.96	1.03	74926.49
22	7.10	3.74	45.50	2.97	13.21	12.31	1.03	75275.99
23	6.50	3.91	46.97	2.60	13.02	12.58	1.03	73017.78
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.89	4.32	46.17	2.64	14.19	11.68	1.03	77036.32
最 大 值	10.03	9.73	52.48	3.63	16.60	12.58	1.09	80403.24
發生時間	21	4	9	21	9	23		6
最 小 值	6.27	1.92	41.75	1.41	12.77	11.07	1.02	73017.78
發生時間	16	18	7	9	21	9		23
零點偏移(率)	0.00 %	-0.02 %	-0.05 %	-0.01 %		-0.01		0.00 %
全幅偏移(率)	0.02 %	1.25 %	-0.90 %	0.35 %		-0.20		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年01月30日

[illegible]