

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年06月05日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	8.45	3.30	56.21	2.41	14.77	12.25	0.97	78419.32
1	10.83	3.74	51.60	2.16	16.92	11.29	0.97	84566.77
2	4.89	3.49	52.87	1.24	17.39	11.20	0.97	81581.10
3	6.08	3.92	47.24	1.83	17.75	10.90	0.97	84650.18
4	3.36	4.36	53.77	1.73	17.60	11.08	0.97	82199.45
5	3.75	4.82	43.21	1.77	17.02	11.20	0.97	86127.11
6	1.43	4.24	47.51	1.18	17.53	11.23	0.97	81395.57
7	0.56	5.37	47.26	1.38	17.32	11.12	0.97	81828.03
8	0.99	4.50	47.22	1.59	16.96	11.23	0.97	80844.56
9	2.57	2.88	52.27	1.33	17.98	11.07	0.97	83023.14
10	2.87	2.76	51.12	1.17	18.05	11.02	0.97	82424.21
11	0.64	2.83	50.74	0.75	18.30	10.97	0.97	84478.68
12	0.14	2.91	46.43	0.68	18.06	11.20	0.97	82345.83
13	0.17	3.15	48.54	1.08	17.64	11.25	0.97	82529.20
14	0.31	3.24	46.95	0.84	17.61	11.02	0.97	83107.38
15	7.36	5.94	47.75	2.70	17.10	11.14	0.97	81639.96
16	12.51	6.11	53.09	3.53	18.98	10.68	0.98	86506.62
17	14.49	2.24	44.72	3.43	17.06	10.94	0.98	83847.10
18	9.98	2.86	34.49	3.05	16.89	10.59	0.97	79579.70
19	6.44	2.17	42.25	2.89	16.35	10.92	0.97	78424.79
20	12.03	2.93	49.56	1.50	18.58	10.36	0.97	83094.75
21	10.58	4.31	55.79	1.56	17.62	11.40	0.98	78708.61
22	5.16	3.32	41.81	0.66	18.47	12.11	0.98	75563.88
23	13.34	5.37	24.87	1.84	19.09	10.21	0.97	84378.31
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.79	3.78	47.39	1.76	17.54	11.10	0.97	82136.01
最 大 值	14.49	6.11	56.21	3.53	19.09	12.25	1.02	86506.62
發生時間	17	16	0	16	23	0		16
最 小 值	0.14	2.17	24.87	0.66	14.77	10.21	0.95	75563.88
發生時間	12	19	23	22	0	23		22
零點偏移(率)	-0.02 %	0.00 %	-0.01 %	-0.01 %		-0.11		0.20 %
全幅偏移(率)	0.00 %	-0.15 %	-0.05 %	0.00 %		0.16		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年06月05日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.35	2.00	55.86	1.24	17.32	11.01	0.96	80504.58
1	5.43	5.05	48.17	2.72	16.50	11.04	0.94	81882.12
2	8.08	4.22	58.11	2.57	16.79	10.91	0.95	82621.37
3	9.71	2.41	52.38	2.80	16.13	10.89	0.98	83530.53
4	9.73	2.19	54.39	2.44	16.52	10.75	0.98	84019.21
5	9.06	1.92	57.28	2.21	16.84	10.84	0.98	83204.51
6	4.72	3.33	53.32	3.28	16.49	10.67	0.99	84839.00
7	3.71	3.25	54.25	2.40	16.34	11.02	1.01	81744.83
8	5.50	2.78	57.16	2.39	15.69	11.59	1.00	77615.47
9	8.53	1.83	49.54	1.19	16.35	10.79	0.98	84150.17
10	7.80	1.94	51.84	0.85	16.92	10.82	0.98	82963.60
11	8.80	2.02	53.64	0.90	17.10	10.91	0.99	81701.74
12	5.34	1.76	57.75	0.84	17.24	11.13	1.02	80723.37
13	8.73	8.62	53.89	1.26	15.94	10.86	1.02	83779.69
14	9.02	2.97	50.63	1.27	15.63	11.25	1.02	81204.94
15	9.83	1.95	50.01	2.93	16.20	11.25	1.02	79863.26
16	9.69	1.99	48.01	2.31	16.75	10.73	1.02	83885.24
17	10.16	4.90	52.75	2.54	16.10	11.12	1.01	81163.67
18	13.66	3.23	53.13	2.56	16.30	10.66	1.02	84888.98
19	10.23	1.77	57.09	1.79	16.66	10.97	1.01	82666.25
20	8.59	1.70	59.32	1.32	18.84	10.41	1.00	83836.36
21	10.65	4.89	41.38	2.24	18.75	10.08	1.00	86419.08
22	10.45	1.11	39.79	2.28	16.73	10.82	1.00	83435.20
23	7.90	4.66	50.42	1.45	17.81	10.93	1.02	81484.11
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.44	3.02	52.50	1.99	16.75	10.89	1.00	82588.64
最 大 值	13.66	8.62	59.32	3.28	18.84	11.59	1.03	86419.08
發生時間	18	13	20	6	20	8		21
最 小 值	3.71	1.11	39.79	0.84	15.63	10.08	0.94	77615.47
發生時間	7	22	22	12	14	21		8
零點偏移(率)	0.00 %	-0.00 %	-0.03 %	-0.06 %		-0.08		-0.10 %
全幅偏移(率)	-0.05 %	0.39 %	-0.57 %	0.24 %		0.14		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年06月05日

[illegible]