

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年08月03日

報表日期: 113年08月03日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.91	2.95	51.25	1.60	17.60	11.58	1.04	81658.85
1	4.91	3.04	57.25	1.27	19.40	11.37	1.05	81877.83
2	5.77	3.27	52.05	2.56	17.47	11.71	1.06	80309.62
3	10.53	3.77	50.19	2.21	17.73	11.43	1.06	81080.04
4	8.75	4.17	48.06	2.52	16.48	11.79	1.04	80056.22
5	5.74	3.86	59.41	1.96	17.59	11.72	0.99	83515.10
6	6.47	5.31	55.27	2.25	16.99	11.49	0.99	81332.27
7	7.94	5.64	55.81	2.27	17.12	11.74	1.02	79299.45
8	8.99	4.60	57.86	2.17	17.46	11.46	1.01	81784.39
9	7.76	4.20	57.49	1.99	17.47	11.52	1.00	81915.17
10	7.45	4.18	61.00	1.61	18.43	11.33	1.02	82477.18
11	12.61	5.45	44.33	2.79	17.36	11.60	0.99	81000.66
12	5.97	4.61	39.40	2.35	16.34	11.72	1.01	80087.00
13	3.23	4.65	48.10	1.39	18.11	11.54	1.01	80833.29
14	8.38	8.20	40.57	2.61	16.11	11.86	1.01	78909.43
15	4.79	2.49	41.75	1.49	17.73	11.37	0.99	79501.88
16	6.70	2.64	43.46	2.03	17.26	11.64	1.00	79166.21
17	4.86	6.02	64.39	1.21	18.10	12.78	1.03	70303.66
18	0.12	6.46	55.97	0.96	17.32	12.77	1.14	71070.23
19	0.30	2.56	48.42	0.78	18.61	11.51	0.98	80758.16
20	3.94	2.77	40.79	1.73	17.45	11.51	0.99	81326.49
21	3.67	2.96	37.58	2.40	16.38	11.67	0.99	79722.53
22	6.81	2.58	42.91	1.99	17.52	11.58	1.00	79906.97
23	8.16	3.95	43.95	1.56	17.96	11.51	0.99	80850.03
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.37	4.18	49.89	1.90	17.50	11.67	1.02	79947.61
最 大 值	12.61	8.20	64.39	2.79	19.40	12.78	1.68	83515.10
發生時間	11	14	17	11	1	17		5
最 小 值	0.12	2.49	37.58	0.78	16.11	11.33	0.97	70303.66
發生時間	18	15	21	19	14	10		17
零點偏移(率)	-0.01 %	-0.00 %	-0.01 %	-0.01 %		-0.06		0.00 %
全幅偏移(率)	0.00 %	0.08 %	-0.16 %	-0.12 %		0.15		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

