

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月03日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.65	6.84	64.38	2.84	14.82	12.79	1.39	66776.35
1	1.55	3.68	58.48	2.33	15.63	12.36	1.38	69528.95
2	3.53	3.24	52.94	2.75	14.78	12.21	1.37	71884.56
3	3.85	3.18	53.83	3.52	13.53	12.51	1.38	71346.79
4	5.53	7.46	56.98	3.56	13.61	12.54	1.38	70228.04
5	7.60	5.32	54.91	3.87	13.13	12.78	1.36	70336.24
6	7.39	5.74	55.59	3.20	14.01	12.47	1.34	70710.22
7	9.86	3.31	57.98	2.64	15.20	12.05	1.34	72801.09
8	8.49	3.99	44.36	3.10	13.91	12.27	1.34	71896.45
9	6.89	4.26	53.16	3.25	13.75	12.51	1.39	69933.93
10	7.46	3.35	64.86	2.99	14.48	12.37	1.37	70478.16
11	9.46	3.88	50.82	3.66	13.38	12.59	1.35	69177.98
12	5.93	3.94	54.73	3.26	13.65	12.46	1.38	69847.92
13	4.84	6.28	48.64	3.56	13.15	12.53	1.39	69245.78
14	9.12	6.20	54.74	3.91	13.28	12.74	1.38	67565.47
15	6.03	3.67	58.06	3.26	13.89	12.71	1.37	67886.58
16	9.22	3.94	54.39	3.36	14.15	12.39	1.34	70021.92
17	2.82	3.45	62.53	2.80	14.15	12.57	1.34	68530.71
18	4.55	3.88	51.14	3.33	13.31	12.51	1.37	69574.56
19	6.18	3.56	61.55	3.10	13.79	12.65	1.40	68817.77
20	3.45	4.39	57.25	2.67	14.46	12.28	1.41	70614.19
21	7.49	3.90	52.33	3.09	14.07	12.38	1.39	70251.22
22	6.88	3.65	57.15	2.65	14.62	12.32	1.40	70071.53
23	10.44	5.94	53.70	3.10	14.37	12.37	1.40	70285.88
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.26	4.46	55.60	3.16	14.05	12.47	1.37	69908.85
最大值	10.44	7.46	64.86	3.91	15.63	12.79	1.41	72801.09
發生時間	23	4	10	14	1	0		7
最小值	1.55	3.18	44.36	2.33	13.13	12.05	1.33	66776.35
發生時間	1	3	8	1	5	7		0
零點偏移(率)	-0.05 %	-0.00 %	-0.01 %	-0.00 %		0.01	0.00	0.00 %
全幅偏移(率)	0.21 %	-0.21 %	0.09 %	-0.01 %		0.40	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月03日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.13	3.22	54.17	1.50	18.65	10.35	1.33	85703.76
1	7.19	2.17	44.94	1.98	18.26	10.43	1.33	83263.40
2	8.47	2.33	52.34	2.54	16.86	10.43	1.33	84397.88
3	9.42	2.07	55.43	2.50	16.41	10.60	1.33	84371.57
4	10.01	2.64	57.75	3.02	16.26	10.65	1.33	84010.67
5	9.30	3.80	67.50	2.10	18.06	10.22	1.33	86544.45
6	10.00	6.92	42.67	2.47	16.73	10.39	1.33	79779.69
7	7.91	3.38	45.57	2.30	16.19	10.55	1.33	82998.69
8	7.88	3.11	58.39	2.14	16.47	10.83	1.34	83038.21
9	10.28	3.32	56.78	2.70	15.56	11.04	1.38	81764.26
10	9.96	3.85	57.62	2.47	15.88	10.91	1.35	81045.29
11	4.66	3.31	57.14	1.58	17.32	10.70	1.34	80972.50
12	8.98	5.51	53.49	2.41	14.69	11.06	1.36	81183.45
13	9.35	8.42	53.51	2.75	14.57	10.76	1.35	81398.52
14	7.55	3.36	56.71	2.20	16.22	10.30	1.36	82347.39
15	10.10	4.74	49.14	2.66	14.82	10.51	1.33	83584.72
16	8.55	3.48	56.47	2.54	14.56	10.66	1.33	79679.33
17	6.51	2.20	42.48	2.14	16.63	10.01	1.32	80436.33
18	8.69	3.05	41.92	2.21	17.39	9.81	1.34	82433.43
19	10.29	3.62	37.43	2.45	17.05	9.71	1.36	81239.72
20	10.35	6.00	49.27	4.76	15.44	10.18	1.38	79999.29
21	9.52	1.72	48.86	1.97	18.08	9.94	1.38	81989.39
22	11.18	1.83	39.65	2.20	17.12	10.08	1.38	80934.66
23	9.98	1.54	47.71	1.93	18.05	10.01	1.38	83329.57
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.80	3.57	51.12	2.40	16.55	10.42	1.35	82351.92
最大值	11.18	8.42	67.50	4.76	18.65	11.06	1.38	86544.45
發生時間	22	13	5	20	0	12		5
最小值	4.66	1.54	37.43	1.50	14.56	9.71	1.30	79679.33
發生時間	11	23	19	0	16	19		16
零點偏移(率)	0.00 %	-0.00 %	-0.03 %	-0.01 %		0.00	0.00	0.00 %
全幅偏移(率)	0.30 %	0.06 %	0.27 %	0.07 %		0.38	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月03日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.66	2.81	58.97	1.17	17.65	10.38	1.80	85990.31
1	2.89	2.88	62.06	1.27	16.98	10.91	1.80	83879.13
2	5.67	3.36	56.53	1.67	16.39	10.70	1.80	86034.26
3	6.02	2.95	63.50	1.96	14.97	11.02	1.80	84073.12
4	6.03	3.28	61.07	1.82	15.36	10.94	1.80	84609.61
5	5.07	3.02	57.06	1.57	16.31	10.62	1.80	85420.69
6	1.51	5.27	62.84	1.54	15.17	11.25	1.80	82518.85
7	3.73	5.67	54.16	1.47	15.57	10.84	1.75	89842.19
8	4.73	3.57	57.44	1.53	15.34	10.73	1.78	82893.22
9	3.14	3.23	60.22	1.70	14.68	11.20	1.80	79931.45
10	6.34	3.39	62.82	2.01	14.29	11.31	1.78	81123.99
11	6.60	3.37	61.94	1.75	14.76	11.17	1.79	81860.51
12	7.28	3.92	59.78	2.15	13.93	11.34	1.79	81170.05
13	9.82	5.39	60.02	2.77	13.07	11.49	1.79	80123.89
14	5.38	3.31	59.76	2.25	13.88	11.33	1.80	79469.88
15	8.71	4.22	57.17	2.23	14.36	11.09	1.78	80520.12
16	6.24	8.54	56.63	2.22	14.14	11.07	1.78	80645.60
17	7.01	4.20	57.34	2.46	13.48	11.17	1.77	81342.07
18	7.14	2.68	63.03	1.61	15.46	10.94	1.76	83443.69
19	8.51	2.47	61.79	1.88	15.55	10.95	1.77	83526.69
20	9.04	4.15	57.59	2.20	14.63	10.99	1.77	84178.48
21	8.41	2.45	60.37	1.77	15.62	10.84	1.78	83140.83
22	9.38	3.17	60.47	1.84	15.44	11.23	1.79	79535.37
23	5.79	2.76	57.72	1.72	15.64	11.11	1.77	80400.66
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.21	3.75	59.59	1.86	15.11	11.03	1.79	82736.44
最大值	9.82	8.54	63.50	2.77	17.65	11.49	1.81	89842.19
發生時間	13	16	3	13	0	13		7
最小值	1.51	2.45	54.16	1.17	13.07	10.38	1.73	79469.88
發生時間	6	21	7	0	13	0		14
零點偏移(率)	-0.03 %	-0.00 %	-0.02 %	-0.01 %		0.04	0.00	0.00 %
全幅偏移(率)	0.29 %	-0.51 %	-0.30 %	0.02 %		0.35	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								