

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月20日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.43	12.01	53.47	1.88	18.81	11.05	1.19	82143.49
1	9.03	11.70	65.31	1.22	20.94	10.96	1.20	80532.23
2	12.73	11.20	57.32	1.88	19.58	10.50	1.19	85927.60
3	7.09	11.19	52.58	1.87	18.32	10.86	1.18	84603.86
4	8.67	11.16	58.57	1.65	19.17	10.74	1.18	84235.24
5	1.16	12.50	60.33	1.28	18.94	10.87	1.24	80454.96
6	9.30	12.36	53.80	1.75	19.02	10.66	1.25	85036.72
7	11.94	12.46	53.21	2.14	18.43	10.72	1.26	84873.16
8	7.24	12.65	52.62	2.14	17.73	10.93	1.26	84048.32
9	10.45	12.86	53.62	2.41	16.74	11.35	1.25	81410.66
10	7.83	12.84	52.20	2.27	16.45	11.39	1.25	81574.94
11	9.71	12.88	53.97	1.95	16.75	11.42	1.25	80841.07
12	7.69	12.95	51.65	2.41	15.55	11.47	1.25	81095.40
13	10.75	12.94	55.70	1.97	17.44	11.39	1.25	80320.38
14	8.83	12.52	55.65	1.78	17.73	11.01	1.25	83294.09
15	8.09	12.90	56.67	1.74	17.47	11.36	1.25	80855.15
16	11.46	12.66	57.69	1.71	17.91	11.12	1.25	81450.77
17	8.65	12.44	54.55	2.06	17.25	11.00	1.25	81291.32
18	10.13	12.30	61.71	2.85	19.20	10.58	1.25	83028.61
19	10.05	12.14	56.36	2.10	18.56	10.23	1.25	86108.31
20	7.10	13.08	60.42	1.74	19.03	11.19	1.25	81041.42
21	10.32	12.82	47.35	1.86	18.32	11.15	1.23	81791.83
22	8.46	12.76	56.85	1.40	18.84	11.05	1.25	82420.65
23	14.85	12.48	51.82	1.50	19.61	10.70	1.25	83973.42
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.12	12.41	55.56	1.90	18.24	10.99	1.24	82598.07
最大值	14.85	13.08	65.31	2.85	20.94	11.47	1.28	86108.31
發生時間	23	20	1	18	1	12		19
最小值	1.16	11.16	47.35	1.22	15.55	10.23	1.15	80320.38
發生時間	5	4	21	1	12	19		13
零點偏移(率)	-0.02 %	0.00 %	-0.17 %	-0.00 %		-0.01	-0.01	0.20 %
全幅偏移(率)	-0.95 %	-0.61 %	-0.21 %	-0.16 %		-0.01	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月20日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.16	12.78	34.27	0.73	20.98	10.45	0.99	83266.95
1	5.81	12.49	40.13	1.04	21.10	10.40	0.97	83784.12
2	14.34	12.91	62.68	1.59	21.10	10.06	0.97	86371.37
3	7.26	12.42	56.60	1.49	20.39	10.15	0.97	86815.02
4	10.59	12.27	52.84	1.40	19.96	10.40	0.96	84830.58
5	6.38	12.83	58.26	1.51	19.76	10.42	0.97	84856.66
6	12.09	12.96	48.43	1.69	19.37	10.94	1.01	82264.49
7	9.77	12.48	45.49	1.81	18.93	10.79	1.01	83346.96
8	13.50	12.81	53.24	2.64	18.84	10.78	1.02	82889.21
9	7.55	12.67	53.38	2.33	19.01	10.48	1.02	85307.50
10	11.05	11.76	54.10	2.27	19.22	10.25	1.02	86413.38
11	9.13	12.21	59.58	1.84	18.28	10.34	1.02	86176.31
12	15.62	12.48	56.25	1.99	17.37	11.14	1.02	80728.33
13	13.76	12.64	51.86	1.87	17.04	11.29	1.01	80798.14
14	10.80	12.35	53.43	1.48	18.01	10.96	1.00	83010.74
15	5.95	12.19	40.99	0.98	18.55	10.73	1.00	83671.80
16	8.64	12.10	43.10	0.85	19.36	10.55	1.00	84251.24
17	9.40	13.32	49.62	0.76	20.39	10.27	1.02	85391.42
18	10.01	12.28	34.67	1.06	19.69	10.47	1.01	83749.07
19	9.47	12.38	29.11	1.42	18.56	10.51	1.00	82765.99
20	9.25	12.22	59.78	1.03	18.89	10.66	1.02	81347.51
21	7.03	13.34	34.50	1.80	18.11	11.42	1.01	76962.15
22	12.42	10.67	51.65	1.80	20.62	9.89	1.02	86998.81
23	11.39	12.35	53.41	0.74	20.65	10.35	1.02	84560.28
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.06	12.45	49.06	1.50	19.34	10.57	1.00	83773.25
最大值	15.62	13.34	62.68	2.64	21.10	11.42	1.02	86998.81
發生時間	12	21	2	8	1	21		22
最小值	5.81	10.67	29.11	0.73	17.04	9.89	0.95	76962.15
發生時間	1	22	19	0	13	22		21
零點偏移(率)	-0.06 %	-0.00 %	-0.03 %	-0.00 %		0.00	-0.01	-0.10 %
全幅偏移(率)	-0.74 %	-1.47 %	1.83 %	0.49 %		-0.02	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月20日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.67	11.17	55.29	2.43	18.70	9.19	1.30	75194.02
1	7.27	10.98	53.63	1.61	20.09	9.11	1.32	76667.31
2	14.24	11.13	58.10	1.87	17.66	9.50	1.36	73833.66
3	7.66	10.89	58.85	1.62	18.64	9.43	1.36	72614.38
4	9.80	11.47	58.97	1.72	19.12	9.36	1.36	76558.43
5	8.32	10.92	57.58	1.64	18.92	9.39	1.36	74762.71
6	9.81	10.87	51.81	1.78	19.68	9.11	1.37	75250.45
7	12.72	11.91	48.41	2.06	18.23	9.40	1.32	74701.90
8	9.31	11.37	57.80	1.74	17.77	9.57	1.34	74446.70
9	8.10	10.99	59.99	1.47	17.08	9.79	1.31	72036.68
10	8.93	10.59	54.92	1.52	18.02	9.31	1.35	72830.05
11	9.54	11.43	55.27	2.98	18.57	9.07	1.34	75911.91
12	6.42	11.67	63.19	2.92	18.40	10.21	1.30	65960.51
13	8.62	11.47	47.38	3.17	19.89	8.58	1.31	76038.62
14	10.18	11.11	46.57	3.38	18.48	8.86	1.31	74275.97
15	9.29	11.19	43.64	3.02	18.65	8.87	1.29	74315.86
16	8.58	10.87	48.19	2.98	18.37	9.10	1.28	73193.98
17	9.38	10.93	45.08	3.43	20.44	8.71	1.29	74598.96
18	8.23	11.83	39.74	3.48	19.88	8.17	1.30	74500.98
19	8.45	11.51	43.85	3.32	19.95	8.75	1.33	69406.65
20	7.90	12.47	33.66	2.98	20.58	8.28	1.30	72272.47
21	10.86	11.50	36.87	3.49	19.66	8.20	1.29	76902.68
22	8.63	11.26	37.26	3.20	20.48	8.34	1.32	73328.57
23	9.71	11.35	42.57	3.36	19.46	8.67	1.32	75790.19
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.28	11.29	49.94	2.55	19.03	9.04	1.32	73974.74
最大值	14.24	12.47	63.19	3.49	20.58	10.21	1.39	76902.68
發生時間	2	20	12	21	20	12		21
最小值	6.42	10.59	33.66	1.47	17.08	8.17	1.27	65960.51
發生時間	12	10	20	9	9	18		12
零點偏移(率)	-0.07 %	0.01 %	-0.14 %	-0.03 %		-0.02	-0.01	-0.20 %
全幅偏移(率)	-2.51 %	-0.10 %	0.59 %	0.18 %		0.33	0.04	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								