

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月13日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.63	11.50	52.21	2.20	19.96	10.24	1.33	87238.32
1	9.37	11.62	56.79	2.51	19.75	10.78	1.33	83870.37
2	8.01	12.45	59.25	3.15	17.26	11.88	1.34	77254.61
3	9.34	11.84	47.73	3.56	16.65	11.20	1.32	82576.24
4	9.68	11.72	52.66	2.55	16.93	11.36	1.32	82356.87
5	7.88	11.86	52.84	2.24	17.40	11.39	1.30	80340.45
6	11.97	11.73	45.23	2.91	16.47	11.38	1.29	81481.03
7	9.73	11.68	53.57	2.70	16.83	11.34	1.29	81969.65
8	8.97	11.64	54.33	2.61	15.74	11.49	1.32	82353.66
9	9.37	11.82	50.33	2.41	16.54	11.14	1.33	82140.53
10	6.21	12.25	50.39	2.20	16.88	11.03	1.28	82723.00
11	10.25	11.83	53.33	2.61	15.91	11.39	1.28	79973.86
12	9.94	11.99	56.15	2.58	14.79	11.69	1.29	78660.47
13	12.43	12.41	55.60	2.73	14.75	11.68	1.31	77448.00
14	9.67	12.03	47.89	3.40	15.50	11.56	1.31	78003.36
15	13.49	12.47	47.15	3.20	15.24	11.43	1.30	78819.85
16	16.73	11.97	65.81	3.65	15.37	11.62	1.29	79535.13
17	5.74	11.84	55.03	3.32	16.46	11.34	1.29	82483.53
18	7.46	12.02	52.44	2.46	15.67	11.62	1.29	79800.14
19	10.89	11.86	53.28	1.59	17.21	11.20	1.30	83016.80
20	9.63	11.94	56.26	1.89	16.93	11.20	1.31	83175.27
21	10.71	12.27	56.44	2.52	14.30	11.81	1.31	80891.39
22	8.02	12.08	59.05	1.57	15.65	11.67	1.31	80964.62
23	9.46	12.03	51.55	1.90	16.93	11.35	1.30	81644.87
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.77	11.95	53.55	2.60	16.46	11.37	1.31	81196.75
最大值	16.73	12.47	65.81	3.65	19.96	11.88	1.34	87238.32
發生時間	16	15	16	16	0	2		0
最小值	5.74	11.50	45.23	1.57	14.30	10.24	1.27	77254.61
發生時間	17	0	6	22	21	0		2
零點偏移(率)	-0.07 %	-0.01 %	-0.10 %	-0.04 %		-0.05	-0.01	0.40 %
全幅偏移(率)	-2.18 %	-1.80 %	0.89 %	-0.06 %		0.32	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月13日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.58	11.84	52.49	0.72	20.20	10.03	1.04	85062.79
1	9.37	11.84	49.89	1.76	18.85	10.27	1.04	81262.73
2	10.20	11.70	49.85	1.83	17.98	10.28	1.04	80059.60
3	7.86	11.47	45.60	2.23	17.02	10.17	1.03	79482.57
4	8.45	12.62	54.55	1.65	17.49	10.53	1.03	77111.64
5	10.66	11.98	49.57	2.25	16.19	10.73	1.02	76246.25
6	4.37	11.58	39.81	2.39	16.38	10.25	1.02	80395.83
7	11.10	11.72	40.70	2.35	15.88	10.55	1.03	78595.64
8	8.47	12.27	54.54	2.48	15.20	11.16	1.05	79943.64
9	8.91	12.33	49.84	1.72	16.37	11.01	1.02	80110.58
10	10.74	12.21	47.91	1.81	16.87	10.86	1.01	81200.16
11	8.51	12.38	53.09	1.35	17.16	10.99	1.02	80281.98
12	9.67	12.49	51.61	1.93	16.18	11.16	1.02	79514.40
13	11.27	12.58	52.41	2.83	14.88	11.27	1.02	77246.77
14	10.62	12.30	54.92	2.41	15.59	11.02	1.02	79028.46
15	7.73	12.73	53.44	2.32	15.37	10.99	1.02	79390.14
16	10.10	12.14	50.77	1.70	15.50	11.00	1.01	79263.46
17	9.58	12.12	56.80	1.51	16.35	10.89	0.99	78076.55
18	8.72	11.86	47.16	2.13	16.72	10.13	0.98	81066.11
19	9.57	12.34	52.06	2.28	15.28	11.06	1.01	78798.33
20	12.84	14.30	65.95	3.24	14.40	11.07	1.00	78413.92
21	13.46	14.01	59.92	4.09	13.97	11.22	1.01	79962.71
22	11.69	12.83	59.87	2.72	14.55	11.71	1.02	80672.25
23	9.80	12.73	62.17	1.50	16.67	11.37	1.02	81705.22
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.68	12.35	52.29	2.13	16.29	10.82	1.02	79703.82
最大值	13.46	14.30	65.95	4.09	20.20	11.71	1.06	85062.79
發生時間	21	20	20	21	0	22		0
最小值	4.37	11.47	39.81	0.72	13.97	10.03	0.97	76246.25
發生時間	6	3	6	0	21	0		5
零點偏移(率)	-0.02 %	-0.02 %	-0.01 %	-0.00 %		-0.04	-0.01	0.00 %
全幅偏移(率)	1.00 %	-1.31 %	0.50 %	-0.31 %		0.10	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月13日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.83	12.87	60.27	2.80	18.05	9.86	1.39	80201.75
1	4.12	12.46	65.28	2.95	18.48	10.00	1.39	78396.87
2	3.47	12.16	56.77	2.80	17.76	9.81	1.39	79167.96
3	3.36	12.50	57.02	2.69	16.05	10.28	1.39	75937.39
4	3.09	12.52	60.79	2.69	16.70	10.24	1.38	76484.97
5	2.46	12.55	55.81	2.62	16.14	10.06	1.36	76628.52
6	2.63	12.35	57.53	2.67	15.86	10.14	1.36	75670.27
7	4.27	10.75	55.87	2.18	15.39	10.16	1.37	80944.01
8	6.69	11.83	59.87	2.59	16.00	9.97	1.40	76030.41
9	8.35	11.55	61.62	2.60	15.86	9.89	1.39	74914.83
10	9.98	11.64	59.33	2.15	16.37	9.69	1.40	75551.20
11	10.02	11.20	53.79	1.32	16.97	9.66	1.41	75903.62
12	9.09	11.30	56.96	1.30	16.62	9.83	1.41	75144.14
13	9.31	11.64	56.41	1.47	15.01	10.16	1.39	72954.09
14	9.37	11.46	56.41	1.33	16.03	9.94	1.40	74538.86
15	7.58	11.32	50.25	1.85	16.01	9.80	1.39	74045.93
16	8.86	11.04	53.00	2.48	17.33	9.74	1.41	77219.18
17	11.00	11.24	60.26	3.00	15.66	10.13	1.41	75512.58
18	10.16	11.82	59.24	3.08	15.01	10.17	1.41	75411.86
19	7.46	11.66	54.13	2.65	15.44	10.15	1.36	74822.42
20	9.17	12.24	56.81	3.20	14.57	10.24	1.37	75769.73
21	8.10	14.39	53.95	4.54	14.67	9.94	1.36	73607.61
22	10.19	11.27	55.30	2.15	16.37	9.83	1.37	74551.02
23	7.33	10.93	55.83	2.53	18.03	9.45	1.38	77114.50
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.04	11.86	57.19	2.48	16.27	9.96	1.39	76105.16
最大值	11.00	14.39	65.28	4.54	18.48	10.28	1.44	80944.01
發生時間	17	21	1	21	1	3		7
最小值	2.46	10.75	50.25	1.30	14.57	9.45	1.36	72954.09
發生時間	5	7	15	12	20	23		13
零點偏移(率)	-0.44 %	0.00 %	-0.01 %	-0.00 %		-0.06	-0.01	0.10 %
全幅偏移(率)	-1.00 %	0.08 %	1.84 %	0.32 %		0.31	0.04	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								