

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月25日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.81	13.44	57.58	1.49	17.11	12.14	1.31	73493.74
1	10.89	12.54	49.15	1.78	18.83	11.34	1.30	79140.56
2	9.11	13.16	58.77	2.00	16.79	12.14	1.30	74411.04
3	10.23	12.93	56.00	1.67	17.09	11.51	1.31	79785.55
4	9.91	12.38	54.33	1.69	16.95	11.36	1.29	79851.50
5	10.90	12.59	52.50	2.48	14.99	12.20	1.25	73646.34
6	7.44	13.03	53.69	3.29	16.13	12.34	1.26	72704.84
7	12.53	11.82	50.65	2.84	17.53	11.35	1.27	81137.44
8	9.15	11.60	51.41	3.05	16.39	11.33	1.28	80449.05
9	8.65	11.79	51.46	2.58	16.25	11.56	1.28	77932.90
10	10.31	11.88	50.28	2.66	16.10	11.59	1.26	76732.57
11	9.72	11.93	46.28	2.44	16.00	11.67	1.26	76153.44
12	9.34	11.79	47.37	1.86	16.99	11.43	1.26	77430.35
13	9.62	11.79	56.71	2.45	16.65	11.06	1.26	82103.59
14	8.91	12.48	40.38	2.63	15.42	11.63	1.25	77355.58
15	0.60	11.64	51.86	1.78	17.83	11.23	1.26	78897.17
16	4.39	12.43	39.73	3.14	16.14	11.04	1.25	79949.85
17	9.07	12.26	52.37	3.22	17.79	10.97	1.25	80979.30
18	7.01	11.69	48.27	3.10	15.25	11.46	1.25	79727.32
19	9.13	11.68	44.80	1.85	16.46	11.30	1.28	80686.26
20	10.41	11.62	42.27	2.50	15.43	11.41	1.27	79605.45
21	9.30	11.69	42.00	2.14	15.75	11.38	1.27	79883.33
22	9.78	12.00	40.15	2.65	16.01	11.42	1.27	82118.88
23	4.52	12.17	43.33	2.87	16.00	11.78	1.26	76482.51
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.70	12.18	49.22	2.42	16.50	11.53	1.27	78360.77
最大值	12.53	13.44	58.77	3.29	18.83	12.34	1.33	82118.88
發生時間	7	0	2	6	1	6		22
最小值	0.60	11.60	39.73	1.49	14.99	10.97	1.25	72704.84
發生時間	15	8	16	0	5	17		6
零點偏移(率)	-0.09 %	-0.01 %	-0.04 %	0.01 %		-0.05	-0.01	0.30 %
全幅偏移(率)	0.00 %	0.00 %	0.00 %	0.00 %		0.01	0.10	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月25日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.23	12.19	53.47	0.99	18.31	10.51	1.02	79057.08
1	8.93	12.44	48.34	1.35	18.42	10.68	1.02	80088.36
2	11.76	12.78	58.54	1.98	16.22	11.07	1.00	77934.12
3	8.60	12.36	59.75	1.44	16.95	10.91	1.02	78759.35
4	8.72	12.24	55.28	1.57	16.49	10.78	1.02	78196.73
5	9.03	12.78	47.45	1.43	17.82	9.87	0.98	76395.78
6	12.53	12.14	50.11	2.69	16.66	10.85	0.97	79498.50
7	9.91	12.01	49.35	2.02	17.16	10.70	0.98	78641.98
8	8.63	12.03	51.69	2.65	17.27	10.70	0.99	78968.23
9	9.67	12.00	52.73	2.00	16.96	10.74	1.00	78211.67
10	7.60	12.00	53.07	1.27	17.34	10.69	0.99	78634.09
11	9.27	13.28	52.77	2.04	17.13	10.62	0.99	78383.89
12	8.90	11.77	51.92	2.17	16.57	10.03	0.98	74653.24
13	8.67	11.84	63.23	2.88	15.90	10.37	0.98	75484.45
14	12.15	11.87	66.14	3.31	14.68	10.85	0.99	74717.95
15	6.22	11.80	55.15	2.27	15.34	10.76	0.98	74807.00
16	10.09	11.19	41.82	1.98	17.02	10.08	0.98	77071.67
17	10.85	11.48	46.44	2.20	17.51	9.69	0.99	77066.81
18	11.07	11.81	48.82	3.41	16.09	9.97	0.99	77082.96
19	12.27	11.76	50.99	0.92	15.97	10.40	1.01	75865.78
20	7.26	11.57	56.40	1.41	15.59	10.49	1.01	77197.90
21	9.51	11.56	58.43	1.37	15.88	10.55	1.01	77270.41
22	10.94	11.70	63.44	1.27	15.55	10.73	1.01	77969.96
23	8.07	11.93	49.25	1.53	15.89	10.79	1.00	77488.69
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.54	12.02	53.52	1.92	16.61	10.53	1.00	77476.94
最大值	12.53	13.28	66.14	3.41	18.42	11.07	1.02	80088.36
發生時間	6	11	14	18	1	2		1
最小值	6.22	11.19	41.82	0.92	14.68	9.69	0.97	74653.24
發生時間	15	16	16	19	14	17		12
零點偏移(率)	-0.15 %	-0.02 %	-0.06 %	-0.01 %		-0.09	-0.01	0.10 %
全幅偏移(率)	-0.30 %	-0.33 %	0.66 %	-0.50 %		-0.09	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月25日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.37	11.85	56.81	2.12	18.96	10.04	1.40	73479.71
1	11.44	11.94	49.66	2.51	18.29	10.10	1.41	73929.51
2	10.58	12.19	52.95	2.14	17.46	10.23	1.38	72784.01
3	6.85	12.03	45.55	2.05	19.21	9.46	1.37	74940.36
4	9.27	12.05	47.90	2.25	18.41	9.85	1.38	73265.63
5	12.27	13.43	46.66	2.88	16.63	9.85	1.38	73682.46
6	7.87	11.37	48.30	2.28	16.58	10.11	1.40	73080.51
7	3.07	11.61	47.06	2.12	15.64	10.07	1.43	78345.15
8	6.66	11.61	53.80	2.23	16.10	10.41	1.43	71919.82
9	12.35	11.32	52.54	2.48	17.25	10.08	1.46	75262.44
10	8.39	11.59	54.77	2.17	16.86	10.24	1.44	73932.78
11	8.84	11.86	43.97	2.18	17.64	9.43	1.43	74099.97
12	6.40	11.86	50.34	2.34	16.64	9.45	1.43	70298.42
13	11.48	11.51	48.95	1.58	17.16	9.20	1.43	72066.88
14	10.17	11.55	51.83	1.48	16.01	9.49	1.43	69832.14
15	7.61	12.18	55.74	2.58	15.32	9.68	1.43	69879.28
16	6.31	11.15	58.06	0.86	16.08	9.87	1.43	73276.86
17	11.14	11.22	56.45	0.95	17.10	9.71	1.43	72808.78
18	9.22	11.31	56.63	1.07	16.32	9.86	1.43	73641.04
19	11.13	11.57	60.19	1.17	16.18	9.96	1.43	72385.95
20	10.20	11.16	54.21	1.26	17.25	9.23	1.43	74369.96
21	8.67	11.11	55.33	1.24	16.98	9.39	1.43	73038.66
22	7.90	10.77	50.72	0.92	17.49	9.21	1.43	73642.80
23	7.02	12.71	35.80	3.50	16.91	9.13	1.43	72798.92
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.84	11.71	51.43	1.93	17.02	9.75	1.42	73198.42
最大值	12.35	13.43	60.19	3.50	19.21	10.41	1.46	78345.15
發生時間	9	5	19	23	3	8		7
最小值	3.07	10.77	35.80	0.86	15.32	9.13	1.36	69832.14
發生時間	7	22	23	16	15	23		14
零點偏移(率)	-0.05 %	0.01 %	-0.03 %	-0.01 %		-0.20	-0.01	0.00 %
全幅偏移(率)	2.80 %	-0.78 %	1.33 %	0.47 %		0.14	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								