

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月17日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.00	10.23	58.43	1.14	17.10	11.89	1.07	71113.70
1	2.32	11.48	54.65	0.57	20.15	10.70	1.07	77517.44
2	3.85	12.16	55.60	0.80	18.78	10.85	1.07	77368.89
3	8.87	11.56	54.78	1.02	18.71	10.86	1.07	77773.29
4	9.15	11.71	55.39	0.87	18.81	10.91	1.06	77389.63
5	7.59	10.45	50.08	0.95	19.10	10.79	1.05	77161.54
6	8.41	9.89	40.86	1.48	17.32	11.07	1.05	75237.64
7	8.08	8.76	55.32	1.34	17.75	11.34	1.06	74045.05
8	3.01	10.03	62.68	0.93	17.84	11.87	1.07	71065.99
9	2.92	9.41	57.59	0.66	19.01	11.39	1.10	73054.64
10	5.21	10.00	51.74	1.02	18.43	10.89	1.10	77297.23
11	8.61	11.25	52.28	1.28	18.39	11.06	1.07	75791.36
12	9.39	14.81	45.42	1.89	16.89	11.37	1.09	73876.46
13	8.92	9.22	39.99	2.44	16.79	11.04	1.10	74131.20
14	8.25	8.94	43.87	1.68	17.26	11.24	1.10	72923.02
15	2.05	8.72	67.83	0.52	18.01	12.04	1.09	69533.07
16	0.34	8.53	55.24	0.53	18.52	11.48	1.07	73590.88
17	3.31	7.35	51.29	0.81	18.61	10.95	1.07	77180.48
18	7.62	7.39	51.28	1.12	18.87	10.78	1.10	77780.80
19	7.92	7.37	51.35	1.17	18.09	11.10	1.10	75866.04
20	6.36	7.63	57.55	1.03	17.81	11.42	1.10	73816.21
21	0.20	10.34	64.37	0.67	18.96	11.69	1.12	70982.23
22	3.34	8.66	54.63	0.78	19.03	11.07	1.10	75230.39
23	7.64	10.55	56.87	0.65	19.70	10.79	1.10	76950.05
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.72	9.85	53.71	1.06	18.33	11.19	1.08	74861.55
最大值	9.39	14.81	67.83	2.44	20.15	12.04	1.19	77780.80
發生時間	12	12	15	13	1	15		18
最小值	0.20	7.35	39.99	0.52	16.79	10.70	1.05	69533.07
發生時間	21	17	13	15	13	1		15
零點偏移(率)	-0.11 %	-0.02 %	-0.02 %	-0.00 %		0.00		0.00 %
全幅偏移(率)	-0.41 %	-0.76 %	-0.04 %	-0.15 %		0.14		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月17日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.96	7.91	43.22	1.55	18.52	9.81	1.06	86963.05
1	0.35	7.33	46.71	1.46	19.44	9.60	1.05	87578.99
2	1.57	6.64	57.98	1.17	17.33	10.60	1.06	82586.05
3	1.59	7.68	53.58	1.45	17.45	10.30	1.06	84689.32
4	2.29	7.15	59.28	1.34	17.35	10.33	1.05	84624.69
5	1.76	6.59	57.71	1.42	17.23	10.28	1.05	85212.17
6	2.26	7.48	52.87	0.58	17.97	11.45	1.09	78573.46
7	2.10	5.27	52.75	0.92	19.52	9.45	1.07	89147.29
8	7.31	5.02	40.28	1.46	17.99	9.43	1.07	91099.53
9	7.95	5.12	49.81	2.00	16.82	10.09	1.07	86339.85
10	9.00	5.46	52.72	2.80	15.88	10.35	1.05	85839.80
11	3.35	4.96	62.34	2.88	14.41	10.98	1.06	81824.19
12	1.99	6.98	61.97	2.44	14.96	10.80	1.07	83220.93
13	8.01	13.31	52.22	2.81	15.41	10.36	1.06	85908.81
14	4.52	2.25	65.53	1.48	16.76	10.54	1.06	82523.18
15	1.44	6.90	62.16	2.74	19.57	9.23	1.07	90831.76
16	1.20	10.90	56.68	1.82	17.18	9.99	1.05	86837.73
17	7.20	12.07	54.10	2.21	16.60	10.10	1.05	86938.70
18	3.75	1.86	58.51	2.09	16.43	10.21	1.05	86381.18
19	3.96	10.32	56.52	2.77	15.89	10.30	1.05	86182.58
20	4.22	4.88	59.32	1.78	16.90	10.31	1.05	85386.02
21	8.41	7.34	47.31	1.65	17.79	9.81	1.05	87953.30
22	7.35	6.80	52.86	2.11	16.84	10.22	1.05	85626.24
23	6.66	6.53	58.76	1.28	18.10	9.80	1.05	87261.78
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.22	6.95	54.80	1.84	17.18	10.18	1.06	85813.78
最大值	9.00	13.31	65.53	2.88	19.57	11.45	1.14	91099.53
發生時間	10	13	14	11	15	6		8
最小值	0.35	1.86	40.28	0.58	14.41	9.23	1.04	78573.46
發生時間	1	18	8	6	11	15		6
零點偏移(率)	-0.08 %	0.00 %	-0.34 %	-0.04 %		0.03		-0.10 %
全幅偏移(率)	0.04 %	-0.57 %	-0.17 %	-0.05 %		0.02		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月17日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.67	6.18	60.16	1.02	14.81	11.59	0.99	76302.07
1	2.89	7.64	58.82	0.85	16.51	11.34	1.00	80415.05
2	6.28	7.24	56.25	0.98	15.76	11.26	1.00	81026.29
3	5.22	8.38	56.58	0.93	16.05	10.55	1.00	81503.64
4	5.44	10.85	54.25	1.28	15.08	10.94	0.99	79710.71
5	7.38	5.96	45.99	1.68	15.02	10.43	0.99	81332.33
6	4.57	4.49	53.56	1.27	15.03	10.84	0.99	77740.23
7	9.82	9.24	46.73	2.38	13.89	10.95	1.02	81979.78
8	4.22	7.33	51.34	1.21	15.34	10.76	1.02	75370.91
9	4.30	3.56	52.43	0.90	15.92	10.81	1.02	80748.52
10	6.51	5.60	57.75	1.61	14.55	10.82	1.04	77588.02
11	1.82	5.34	47.70	1.64	13.49	10.85	1.01	73623.63
12	3.94	6.98	47.33	1.75	13.52	10.75	0.99	75298.54
13	6.24	6.40	53.14	1.73	14.20	10.85	0.99	74964.52
14	5.24	4.36	54.97	1.39	14.43	10.84	0.99	74292.73
15	9.52	4.26	63.39	0.86	16.35	10.80	1.01	83102.99
16	8.04	4.38	59.22	0.88	16.74	10.60	1.02	86632.59
17	6.84	6.49	55.28	1.24	15.06	11.09	1.02	80960.45
18	6.44	6.63	51.58	1.28	15.05	10.97	1.03	78934.40
19	3.17	5.51	47.19	1.27	14.96	11.03	1.03	79402.88
20	2.78	8.73	53.26	1.06	15.47	11.16	1.04	79758.17
21	2.11	4.52	56.33	0.65	16.50	10.89	1.05	80241.92
22	2.00	4.72	57.91	0.55	16.95	10.84	1.05	79547.20
23	2.16	5.71	46.25	0.72	16.36	10.97	1.05	80787.05
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.98	6.27	53.64	1.21	15.29	10.91	1.01	79219.36
最大值	9.82	10.85	63.39	2.38	16.95	11.59	1.05	86632.59
發生時間	7	4	15	7	22	0		16
最小值	1.82	3.56	45.99	0.55	13.49	10.43	0.99	73623.63
發生時間	11	9	5	22	11	5		11
零點偏移(率)	-0.10 %	0.00 %	-0.06 %	-0.01 %		0.00		0.00 %
全幅偏移(率)	0.98 %	-0.83 %	0.05 %	0.07 %		0.50		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								