

報表日期: 113年10月05日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.59	3.74	44.19	0.40	20.38	10.79	1.06	85507.29
1	6.02	4.04	46.90	0.70	20.82	10.67	1.06	86020.14
2	7.14	3.30	43.24	0.61	18.79	10.96	1.05	85727.13
3	6.34	2.87	42.30	1.00	18.08	11.68	1.05	80410.09
4	7.16	4.51	48.25	0.53	19.54	10.95	1.06	84927.92
5	4.57	3.55	52.49	0.71	18.82	10.91	1.08	84837.35
6	7.98	2.62	54.87	0.89	18.74	11.35	1.09	82090.74
7	8.24	2.60	58.47	0.50	20.01	10.79	1.08	85663.95
8	7.70	2.61	63.68	0.74	20.08	10.86	1.09	85308.03
9	4.95	2.75	61.15	0.69	18.52	11.57	1.09	80333.36
10	1.94	3.09	58.35	0.52	18.93	11.46	1.06	81159.22
11	4.71	2.75	51.93	0.63	19.02	11.11	1.09	83738.33
12	10.22	2.69	53.30	1.11	17.07	11.54	1.09	82591.60
13	10.28	2.95	49.62	1.32	17.08	11.72	1.07	80686.94
14	8.52	2.81	56.26	0.77	17.48	11.74	1.06	80154.47
15	10.04	3.09	50.05	1.55	16.31	11.89	1.06	79856.82
16	8.91	3.30	56.65	0.90	17.93	11.60	1.08	80942.45
17	7.91	2.66	64.28	0.50	19.66	11.09	1.09	84014.05
18	4.48	3.61	67.64	0.69	18.40	12.42	1.09	73708.94
19	2.51	2.96	33.09	0.42	18.10	12.52	1.10	73570.27
20	3.94	2.78	45.41	0.44	18.39	11.46	1.08	82348.75
21	8.99	3.21	33.01	1.26	17.39	11.44	1.06	83041.30
22	10.00	3.62	40.60	0.97	17.92	11.33	1.06	83025.81
23	10.76	6.49	41.62	1.39	16.44	11.64	1.06	81838.77
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.04	3.27	50.72	0.80	18.50	11.40	1.07	82145.99
最 大 值	10.76	6.49	67.64	1.55	20.82	12.52	1.13	86020.14
發生時間	23	23	18	15	1	19		1
最 小 值	1.94	2.60	33.01	0.40	16.31	10.67	1.04	73570.27
發生時間	10	7	21	0	15	1		19
零點偏移(率)	-0.05 %	0.00 %	-0.10 %	0.00 %		-0.06		0.00 %
全幅偏移(率)	0.00 %	-0.69 %	0.13 %	0.32 %		0.21		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 113年10月05日

報表日期: 113年10月05日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.38	1.87	46.41	1.51	17.04	10.35	1.69	78321.49
1	9.30	1.55	54.19	1.47	16.58	10.62	1.69	77015.78
2	11.43	1.98	52.21	1.44	16.58	10.80	1.70	76235.21
3	8.47	1.89	55.50	1.21	18.14	10.56	1.70	78320.20
4	9.22	1.83	55.58	1.40	17.63	10.59	1.70	78460.04
5	8.97	1.85	55.52	1.90	18.38	10.43	1.71	79413.65
6	3.43	1.90	55.40	1.87	18.56	10.58	1.70	80268.43
7	10.71	3.79	56.02	0.97	17.88	10.74	1.69	78941.86
8	7.44	2.16	65.01	1.61	18.21	10.78	1.69	80014.07
9	4.35	2.20	62.36	2.06	18.24	10.48	1.68	82024.19
10	6.77	2.12	61.17	1.63	18.16	10.70	1.70	80622.87
11	13.04	2.14	55.17	1.16	17.23	11.10	1.70	77647.78
12	10.54	2.16	57.22	1.07	16.96	11.17	1.67	77693.20
13	10.09	2.45	57.96	1.49	16.13	11.26	1.70	77212.23
14	12.17	2.18	54.90	1.31	16.70	11.16	1.71	77382.70
15	9.73	2.92	59.99	1.58	16.37	11.73	1.71	72835.33
16	9.93	2.89	57.66	1.14	17.01	11.44	1.69	73834.81
17	11.25	2.68	57.47	1.05	18.11	10.92	1.66	77557.43
18	9.76	2.31	55.08	0.96	17.81	10.84	1.70	77501.37
19	10.66	2.32	63.87	1.13	17.21	11.00	1.71	76084.49
20	9.05	3.32	56.03	1.38	15.88	11.27	1.70	73949.74
21	9.01	2.35	51.46	0.98	16.85	11.06	1.68	74779.27
22	12.92	3.67	50.59	1.54	15.94	11.30	1.69	75760.06
23	11.78	6.90	52.03	1.27	16.51	11.28	1.69	75660.35
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.60	2.56	56.20	1.38	17.25	10.92	1.69	77397.36
最 大 值	13.04	6.90	65.01	2.06	18.56	11.73	1.74	82024.19
發生時間	11	23	8	9	6	15		9
最 小 值	3.43	1.55	46.41	0.96	15.88	10.35	1.64	72835.33
發生時間	6	1	0	18	20	0		15
零點偏移(率)	-0.05 %	-0.04 %	-0.01 %	0.00 %		0.00		-0.10 %
全幅偏移(率)	0.02 %	-0.03 %	-0.21 %	0.19 %		0.42		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								