

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年12月01日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	遺失	遺失	遺失	遺失	遺失	遺失	1.05	遺失
1	7.88	7.54	53.52	1.04	19.03	11.50	1.03	73486.93
2	9.57	7.62	55.22	1.32	17.67	11.26	1.02	75976.70
3	8.45	8.99	51.98	1.23	17.67	11.54	1.02	74209.88
4	4.25	11.58	64.37	1.01	17.71	12.50	1.05	66879.06
5	9.03	5.98	48.35	0.84	18.36	11.14	0.99	78993.18
6	9.39	6.07	52.99	0.84	19.70	10.70	0.99	78755.85
7	8.74	6.92	56.46	1.16	18.52	11.41	0.98	74469.19
8	8.92	7.43	52.45	1.41	17.86	11.42	0.97	75032.90
9	8.79	8.24	54.77	1.08	18.61	11.13	0.97	77272.57
10	8.38	8.48	47.32	1.62	16.93	11.53	0.97	75812.46
11	4.83	11.86	46.88	1.69	15.72	11.84	0.98	73094.78
12	4.18	10.15	51.74	1.15	17.30	11.49	0.98	74518.80
13	7.20	7.26	68.59	1.06	18.23	11.31	0.98	75384.50
14	8.84	7.12	55.31	1.13	18.11	11.24	1.00	76417.50
15	9.16	7.20	59.77	1.40	18.38	11.15	1.02	76734.20
16	9.01	9.11	50.56	1.64	17.15	11.44	1.03	75834.39
17	9.21	7.09	51.29	1.80	17.95	11.16	1.03	77783.70
18	10.13	8.04	54.98	1.72	18.04	11.26	1.02	76860.77
19	8.91	7.24	42.65	1.45	19.12	10.78	1.02	79311.74
20	10.55	7.38	37.27	1.61	18.87	10.80	1.02	79077.91
21	9.70	7.76	42.13	1.67	18.19	11.29	1.02	76215.42
22	8.69	6.92	64.88	1.19	18.66	11.27	1.02	76130.00
23	7.73	6.57	51.45	0.93	18.96	11.21	1.02	76330.97
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	23	23	23	23	23	23	24	23
平均值	8.33	7.94	52.82	1.30	18.12	11.32	1.01	75851.45
最大值	10.55	11.86	68.59	1.80	19.70	12.50	1.17	79311.74
發生時間	20	11	13	17	6	4		19
最小值	4.18	5.98	37.27	0.84	15.72	10.70	0.97	66879.06
發生時間	12	5	20	5	11	6		4
零點偏移(率)	-0.11 %	0.01 %	-0.05 %	-0.01 %		-0.02		0.20 %
全幅偏移(率)	0.02 %	-0.38 %	-0.21 %	-1.58 %		0.21		0.20 %
有效比率	95.83 %	95.83 %	95.83 %	95.83 %	95.83 %	95.83 %	100.00 %	95.83 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年12月01日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	遺失	遺失	遺失	遺失	遺失	遺失	1.06	遺失
1	6.19	5.34	55.96	2.33	19.22	9.78	1.06	86369.11
2	6.68	4.19	48.35	1.78	19.29	9.41	1.06	89083.68
3	5.67	2.38	57.25	1.75	18.32	9.92	1.06	86440.64
4	8.28	2.37	38.08	2.34	18.15	9.82	1.06	87355.30
5	5.62	5.25	54.82	2.96	16.74	10.01	1.05	87091.54
6	5.74	3.91	45.14	2.56	18.47	9.54	1.06	88001.97
7	8.89	4.51	57.12	2.44	17.88	9.80	1.06	88155.86
8	9.02	8.29	59.17	2.45	17.05	10.15	1.05	85981.16
9	7.49	3.86	51.70	1.61	17.67	9.91	1.05	86896.59
10	2.56	6.29	60.26	2.63	15.03	10.54	1.05	85057.91
11	1.85	9.16	55.94	2.75	15.11	10.66	1.05	84047.72
12	1.87	4.66	58.01	3.01	15.79	10.40	1.04	84994.71
13	2.31	7.72	62.37	3.03	15.62	10.38	1.04	85359.13
14	6.19	2.67	55.80	2.85	16.10	10.43	1.04	84614.48
15	9.36	2.19	64.75	1.80	17.30	10.19	1.05	85511.48
16	9.19	4.33	54.50	2.08	16.30	10.14	1.05	86904.68
17	5.60	2.16	54.07	2.73	16.08	10.21	1.06	86406.15
18	4.59	3.03	52.48	1.50	18.63	9.54	1.08	89633.07
19	6.42	7.81	55.41	2.75	15.55	10.16	1.07	86639.00
20	9.72	2.65	51.95	3.04	15.32	10.55	1.09	84766.65
21	9.46	4.41	52.35	2.41	16.44	10.18	1.08	86619.10
22	8.39	4.31	61.06	2.34	16.29	10.67	1.07	82318.70
23	9.56	5.20	51.72	2.39	16.76	10.33	1.08	84796.72
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	23	23	23	23	23	23	24	23
平均值	6.55	4.64	54.71	2.41	16.92	10.12	1.06	86219.36
最大值	9.72	9.16	64.75	3.04	19.29	10.67	1.09	89633.07
發生時間	20	11	15	20	2	22		18
最小值	1.85	2.16	38.08	1.50	15.03	9.41	1.03	82318.70
發生時間	11	17	4	18	10	2		22
零點偏移(率)	-0.07 %	-0.04 %	-0.01 %	-0.01 %		0.02		-0.20 %
全幅偏移(率)	0.02 %	-0.17 %	-0.13 %	0.02 %		0.03		-0.20 %
有效比率	95.83 %	95.83 %	95.83 %	95.83 %	95.83 %	95.83 %	100.00 %	95.83 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年12月01日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	遺失	遺失	遺失	遺失	遺失	遺失	0.99	遺失
1	8.60	6.56	50.94	1.18	18.94	10.26	0.99	82249.94
2	8.63	4.48	43.94	1.48	16.90	10.19	0.99	81863.47
3	8.62	3.25	53.49	1.46	16.47	10.80	0.98	77532.76
4	8.23	3.41	53.78	1.70	15.89	10.66	0.97	79144.62
5	9.05	6.52	53.32	2.05	14.77	10.95	0.97	77925.08
6	8.02	6.67	58.04	2.47	13.60	11.17	0.97	76217.16
7	9.16	4.93	50.19	1.46	16.28	10.69	1.00	76707.63
8	6.95	10.02	51.27	1.21	16.36	10.86	0.99	77872.73
9	6.57	4.02	42.14	1.30	16.50	10.24	0.99	78165.82
10	9.19	8.57	49.31	2.18	14.72	10.61	1.00	81449.48
11	4.51	4.23	56.95	1.98	13.84	11.18	1.00	73626.80
12	4.65	3.91	60.80	1.17	16.00	10.69	0.99	78855.66
13	5.26	7.94	60.58	1.06	15.63	10.87	0.99	78407.33
14	8.27	7.90	56.13	1.58	14.86	11.07	1.01	77961.19
15	5.78	2.99	57.35	1.02	16.28	10.94	1.02	78508.19
16	5.82	7.00	51.33	1.19	15.53	10.84	1.01	79809.28
17	8.43	14.07	53.91	2.61	13.71	11.21	1.01	76796.65
18	8.39	5.99	54.52	1.75	14.98	11.01	1.02	77134.90
19	9.92	2.91	58.40	1.28	16.58	10.69	1.04	81604.57
20	10.46	10.47	51.54	2.11	14.87	10.95	1.02	79189.12
21	7.63	1.69	53.61	1.58	15.34	10.91	1.02	77646.27
22	7.47	9.41	56.50	1.18	16.63	10.57	1.03	80221.64
23	9.64	4.92	48.95	1.45	16.12	10.78	1.04	81782.86
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	23	23	23	23	23	23	24	23
平均值	7.79	6.17	53.35	1.58	15.69	10.79	1.00	78724.92
最大值	10.46	14.07	60.80	2.61	18.94	11.21	1.04	82249.94
發生時間	20	17	12	17	1	17		1
最小值	4.51	1.69	42.14	1.02	13.60	10.19	0.95	73626.80
發生時間	11	21	9	15	6	2		11
零點偏移(率)	-0.02 %	0.01 %	-0.02 %	0.00 %		0.01		0.20 %
全幅偏移(率)	0.02 %	0.03 %	-0.12 %	0.03 %		0.14		0.20 %
有效比率	95.83 %	95.83 %	95.83 %	95.83 %	95.83 %	95.83 %	100.00 %	95.83 %
備註								