

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年01月21日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.08	2.88	64.81	1.16	15.45	11.62	1.26	82567.10
1	9.22	2.71	51.01	1.41	16.24	11.62	1.25	81397.01
2	8.89	2.80	50.53	1.44	17.13	11.27	1.24	83817.41
3	10.33	2.69	53.56	1.45	15.38	11.79	1.24	81171.33
4	10.06	2.73	50.00	1.84	15.22	11.59	1.23	82963.10
5	7.56	3.08	61.07	1.46	16.02	11.73	1.23	80815.93
6	8.98	4.34	61.88	1.18	16.88	11.16	1.23	85092.55
7	10.34	7.06	57.09	1.92	15.51	11.32	1.23	84918.87
8	8.48	7.93	55.33	1.94	14.72	11.81	1.24	81493.64
9	10.69	6.33	54.15	2.41	14.83	11.86	1.27	81078.54
10	7.38	6.57	67.26	0.93	16.77	11.58	1.25	81551.10
11	7.60	6.68	46.84	1.71	15.58	11.62	1.24	82137.17
12	9.53	6.51	44.17	2.34	14.34	11.83	1.26	81343.79
13	9.08	6.81	43.04	2.91	13.71	12.02	1.22	80210.00
14	9.56	6.90	45.70	2.27	14.42	11.74	1.22	82484.33
15	7.37	6.12	46.12	2.13	14.61	11.79	1.23	81677.50
16	7.58	6.60	52.60	1.68	15.32	11.58	1.27	82933.25
17	8.85	6.90	49.24	1.83	15.54	11.32	1.24	84632.17
18	11.01	6.41	52.90	1.82	15.15	11.43	1.23	84085.50
19	10.92	6.43	48.41	2.07	14.60	11.63	1.23	83249.73
20	10.53	7.89	49.70	2.89	13.66	11.78	1.23	82776.54
21	14.73	6.62	50.21	2.61	14.03	11.75	1.23	82268.95
22	10.08	2.76	55.27	3.05	13.70	11.95	1.23	81390.40
23	11.92	2.92	64.96	1.73	15.74	11.87	1.23	80263.39
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.57	5.36	53.16	1.92	15.19	11.65	1.24	82346.64
最 大 值	14.73	7.93	67.26	3.05	17.13	12.02	1.28	85092.55
發生時間	21	8	10	22	2	13		6
最 小 值	7.37	2.69	43.04	0.93	13.66	11.16	1.20	80210.00
發生時間	15	3	13	10	20	6		13
零點偏移(率)	-0.01 %	-0.05 %	-0.03 %	0.00 %		-0.01		0.30 %
全幅偏移(率)	0.00 %	0.86 %	-0.11 %	0.09 %		-0.02		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

