

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月05日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.33	2.55	51.37	2.83	14.15	12.44	1.34	70380.74
1	8.09	3.42	55.17	3.01	14.15	12.39	1.33	70370.86
2	10.09	6.30	57.29	3.54	13.54	12.39	1.33	70785.45
3	9.12	10.22	46.70	4.35	12.32	12.70	1.33	68967.79
4	9.93	3.29	58.90	4.30	12.72	12.53	1.33	70694.01
5	12.36	3.42	54.97	4.28	13.33	12.41	1.37	71350.94
6	6.24	3.40	55.87	2.92	14.50	12.26	1.38	70750.11
7	6.43	3.58	56.11	2.83	14.41	12.37	1.40	70253.73
8	3.34	6.21	66.88	3.00	14.01	13.30	1.40	62649.94
9	5.24	3.70	49.65	2.73	14.38	12.32	1.43	70673.46
10	8.52	3.98	55.01	3.37	13.26	12.31	1.40	71734.02
11	9.82	7.12	59.60	3.91	13.01	12.46	1.44	70507.23
12	8.86	3.15	61.60	2.76	14.96	12.09	1.45	71698.11
13	6.37	3.23	53.70	2.67	14.94	12.03	1.40	72388.80
14	4.20	7.27	67.64	3.26	13.75	13.12	1.40	64432.91
15	5.20	8.37	62.81	3.53	13.44	13.08	1.41	64991.55
16	2.71	3.69	59.70	2.81	13.95	12.63	1.45	68023.63
17	6.95	5.63	50.91	3.41	13.10	12.40	1.44	70788.19
18	10.58	4.78	61.78	4.69	12.31	12.67	1.40	69432.09
19	5.04	2.69	56.99	4.10	11.98	12.82	1.38	68340.89
20	7.56	2.12	53.43	3.24	13.70	12.38	1.41	70400.23
21	5.58	1.76	55.77	3.10	14.08	12.43	1.43	69869.64
22	9.42	2.29	52.16	4.76	13.29	12.58	1.41	69292.52
23	8.36	1.86	47.73	3.56	14.17	12.22	1.40	71868.57
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.26	4.33	56.32	3.46	13.64	12.51	1.39	69610.23
最大值	12.36	10.22	67.64	4.76	14.96	13.30	1.46	72388.80
發生時間	5	3	14	22	12	8		13
最小值	2.71	1.76	46.70	2.67	11.98	12.03	1.33	62649.94
發生時間	16	21	3	13	19	13		8
零點偏移(率)	0.00 %	0.00 %	-0.01 %	-0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	0.45 %	0.17 %	-0.41 %	0.01 %		0.39	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月05日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.58	3.76	46.59	1.46	18.70	9.88	1.37	87673.72
1	10.08	4.06	52.94	1.74	17.16	10.41	1.36	87049.85
2	8.55	5.88	60.77	2.18	16.02	10.99	1.35	83166.58
3	7.56	10.47	52.57	5.90	14.96	11.04	1.33	83761.33
4	9.40	5.61	56.80	3.38	14.62	10.98	1.34	82651.28
5	10.30	6.45	56.30	3.48	13.74	11.02	1.33	80751.36
6	5.82	16.94	51.33	2.32	14.25	10.82	1.37	77222.97
7	11.43	4.14	52.51	2.94	15.21	10.61	1.38	80965.25
8	9.51	7.08	44.75	2.67	14.87	10.54	1.41	79909.46
9	9.23	4.81	49.74	2.48	16.15	10.33	1.40	81074.87
10	7.34	7.68	38.54	2.22	16.33	9.97	1.39	80738.13
11	10.17	4.38	57.01	2.40	17.58	9.68	1.42	86374.55
12	10.29	3.78	44.20	2.53	17.10	10.14	1.37	80461.66
13	10.33	6.27	49.94	2.73	16.44	9.99	1.35	83236.57
14	7.80	4.02	37.33	2.22	17.70	10.15	1.34	81532.52
15	10.28	4.48	52.29	2.36	16.73	10.42	1.35	84517.86
16	5.49	3.68	64.74	1.65	17.28	11.20	1.39	77853.04
17	8.16	6.27	44.12	1.94	16.54	10.38	1.40	88484.58
18	8.95	5.04	49.83	3.56	15.45	10.64	1.38	84784.64
19	10.24	3.63	50.21	2.51	15.53	10.61	1.37	82495.94
20	9.62	2.37	57.89	2.44	16.68	10.55	1.37	83613.48
21	9.80	2.28	45.89	2.72	17.54	10.24	1.39	86836.35
22	9.67	2.82	49.13	3.18	17.35	10.28	1.43	83781.28
23	8.06	3.00	40.89	2.47	17.09	10.21	1.41	84732.26
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.94	5.37	50.26	2.64	16.29	10.46	1.37	83069.56
最大值	11.43	16.94	64.74	5.90	18.70	11.20	1.45	88484.58
發生時間	7	6	16	3	0	16		17
最小值	5.49	2.28	37.33	1.46	13.74	9.68	1.33	77222.97
發生時間	16	21	14	0	5	11		6
零點偏移(率)	-0.20 %	-0.00 %	-0.06 %	0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	0.33 %	-0.32 %	0.13 %	0.09 %		0.30	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月05日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.78	4.65	55.00	1.39	17.10	10.36	1.74	87002.29
1	5.33	4.09	56.56	1.32	16.29	10.65	1.72	86058.86
2	5.51	5.60	59.13	1.79	14.54	11.10	1.72	84390.51
3	10.50	9.51	61.94	2.55	14.06	11.29	1.72	83903.89
4	10.42	11.37	57.40	3.63	13.12	11.17	1.72	85169.08
5	14.58	15.78	53.73	6.62	12.12	11.32	1.71	82013.95
6	3.11	7.84	58.35	2.63	13.04	11.57	1.72	81496.52
7	8.19	10.84	55.60	2.01	14.51	11.14	1.76	76233.05
8	10.12	7.71	59.69	2.80	13.56	11.39	1.81	83512.86
9	8.79	6.99	54.36	2.73	13.79	11.30	1.78	79911.71
10	6.27	8.36	57.55	2.90	13.03	11.34	1.78	77386.27
11	6.63	4.16	48.16	1.90	15.06	10.77	1.78	77583.20
12	1.85	2.77	64.94	1.17	16.65	11.26	1.80	80280.31
13	4.20	4.69	57.78	1.20	16.34	10.86	1.80	81567.33
14	6.34	6.35	52.70	1.34	16.66	10.38	1.80	85138.25
15	6.40	5.67	47.90	1.89	14.71	10.71	1.79	81864.62
16	9.01	3.94	57.44	1.80	15.63	10.76	1.78	81400.13
17	15.96	6.41	54.00	3.60	14.50	11.46	1.77	82720.39
18	4.95	6.57	49.50	2.08	14.18	11.03	1.76	81257.62
19	2.00	1.54	56.38	1.69	14.34	11.08	1.74	79135.26
20	1.87	2.30	56.44	1.81	14.00	11.21	1.77	79253.96
21	0.99	2.21	55.95	0.89	15.80	11.00	1.80	82706.23
22	1.61	2.76	63.04	0.89	15.79	11.12	1.80	82745.78
23	2.59	2.22	54.19	0.87	16.51	10.77	1.80	84742.20
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.38	6.01	56.16	2.15	14.81	11.04	1.77	81978.09
最大值	15.96	15.78	64.94	6.62	17.10	11.57	1.83	87002.29
發生時間	17	5	12	5	0	6		0
最小值	0.99	1.54	47.90	0.87	12.12	10.36	1.70	76233.05
發生時間	21	19	15	23	5	0		7
零點偏移(率)	-0.01 %	-0.01 %	-0.14 %	-0.01 %		0.03	0.00	0.00 %
全幅偏移(率)	-0.05 %	0.19 %	-0.27 %	-0.01 %		0.31	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								