

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年02月16日

項目 單位	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
0	12.03	3.03	52.12	2.19	16.28	11.32	1.13	81042.11
1	12.48	2.91	51.92	0.96	15.45	11.54	1.13	79778.21
2	10.43	3.23	44.86	2.17	14.50	11.35	1.13	81058.98
3	11.88	4.39	36.81	0.91	15.11	11.26	1.14	81694.00
4	14.39	1.50	39.38	1.18	15.51	11.43	1.11	80474.78
5	14.47	2.78	44.22	0.87	16.18	11.59	1.13	78434.75
6	15.23	5.17	46.46	2.83	13.82	11.58	1.13	77193.26
7	15.19	1.41	42.75	1.72	14.77	11.50	1.10	80925.00
8	10.81	2.16	42.43	1.93	16.26	11.24	1.10	82117.10
9	11.11	2.34	41.93	0.96	16.56	10.94	1.14	84210.23
10	10.33	2.69	49.81	1.05	18.55	10.95	1.12	82148.30
11	11.74	3.23	39.52	3.43	17.77	10.68	1.10	85231.20
12	12.66	2.78	56.31	2.32	16.60	11.13	1.09	82015.88
13	12.60	2.57	65.83	1.79	17.31	11.36	1.09	79954.91
14	13.05	2.71	47.22	2.03	18.31	10.58	1.09	84741.87
15	12.99	2.75	44.20	2.15	17.79	10.50	1.10	86035.54
16	10.00	2.78	47.25	2.24	16.39	10.89	1.10	84570.16
17	13.18	2.53	51.43	2.41	17.20	10.84	1.10	84664.76
18	12.66	5.48	49.79	2.38	16.01	10.90	1.10	85574.79
19	12.16	2.06	48.62	1.37	16.54	10.89	1.09	83929.95
20	12.83	2.41	50.24	1.44	16.78	10.78	1.09	84315.30
21	12.19	4.84	52.32	2.34	17.29	10.66	1.09	85059.26
22	10.71	3.81	49.08	1.97	17.40	10.89	1.09	82725.97
23	9.85	4.91	55.36	1.82	18.02	10.59	1.10	85375.52
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	12.29	3.10	47.91	1.85	16.52	11.06	1.11	82636.33
最 大 值	15.23	5.48	65.83	3.43	18.55	11.59	1.16	86035.54
發生時間	6	18	13	11	10	5		15
最 小 值	9.85	1.41	36.81	0.87	13.82	10.50	1.07	77193.26
發生時間	23	7	3	5	6	15		6
零點偏移(率)	-0.06 %	-0.01 %	-0.01 %	-0.02 %		-0.12		-0.10 %
全幅偏移(率)	-0.84 %	-0.06 %	-0.12 %	0.26 %		-0.06		0.00 %

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年02月16日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.42	3.65	47.29	0.41	16.66	11.04	1.55	77535.31
1	8.62	1.81	53.92	1.07	18.30	11.06	1.55	75884.26
2	12.00	7.77	53.21	2.40	14.87	11.04	1.55	78296.38
3	16.40	4.44	46.94	2.52	16.55	10.49	1.55	79357.98
4	13.30	3.65	47.48	2.89	15.74	10.97	1.56	79954.15
5	6.76	4.27	47.95	1.72	17.29	10.90	1.55	79272.19
6	11.09	2.89	50.11	2.20	16.40	10.80	1.55	79320.17
7	9.85	5.08	48.61	1.53	15.06	12.25	1.53	74054.80
8	15.49	4.58	51.35	3.23	18.28	10.94	1.52	79089.83
9	9.03	8.80	37.15	2.63	18.29	10.19	1.52	84772.93
10	7.15	2.49	45.60	1.48	17.96	10.71	1.52	81119.58
11	8.10	1.74	51.62	1.26	19.61	10.49	1.52	81156.16
12	12.09	6.30	41.29	1.19	19.38	9.84	1.52	86183.37
13	12.12	5.32	46.29	1.78	17.94	10.62	1.52	81545.57
14	12.00	4.26	46.45	1.25	18.22	10.65	1.52	80819.88
15	10.69	4.06	48.91	0.96	18.54	10.75	1.52	79483.02
16	8.87	6.08	44.86	0.57	19.35	10.19	1.52	82576.91
17	11.27	9.41	45.73	0.93	18.50	10.21	1.52	83744.38
18	8.92	6.04	48.09	1.28	17.03	10.80	1.52	80878.82
19	12.41	4.90	46.29	2.69	18.20	10.23	1.52	84390.30
20	8.44	5.31	43.35	1.92	18.78	10.34	1.52	82762.96
21	12.43	5.08	40.28	1.10	18.14	10.29	1.52	83311.83
22	11.45	2.48	47.35	1.57	16.86	11.12	1.52	77965.51
23	11.35	3.22	56.76	0.88	18.60	10.73	1.52	80640.66
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.76	4.73	47.37	1.64	17.69	10.69	1.53	80588.21
最 大 值	16.40	9.41	56.76	3.23	19.61	12.25	1.57	86183.37
發生時間	3	17	23	8	11	7		12
最 小 值	6.76	1.74	37.15	0.41	14.87	9.84	1.50	74054.80
發生時間	5	11	9	0	2	12		7
零點偏移(率)	-0.02 %	0.00 %	-0.03 %	-0.01 %		-0.10		-0.10 %
全幅偏移(率)	0.31 %	0.02 %	0.02 %	0.02 %		-0.25		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								