

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月01日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.40	3.18	58.25	1.38	19.35	11.93	1.43	70171.52
1	10.00	2.95	52.56	1.20	20.24	11.27	1.44	74625.17
2	7.19	3.38	48.92	1.43	19.08	11.43	1.44	74228.73
3	1.61	2.76	53.72	1.38	18.77	11.41	1.44	74964.85
4	1.05	2.71	64.11	1.27	19.43	11.64	1.48	73316.07
5	2.63	2.58	51.16	0.79	21.63	11.09	1.43	78256.48
6	5.77	2.51	49.34	1.02	21.18	11.26	1.42	74720.68
7	0.93	3.17	60.97	1.45	20.00	11.84	1.43	71384.01
8	0.92	4.69	61.42	1.55	19.46	12.18	1.46	68832.19
9	0.83	2.23	47.74	0.99	20.97	10.99	1.44	76286.38
10	6.26	10.95	40.00	1.81	18.38	11.60	1.45	73337.16
11	8.16	14.41	39.62	1.98	18.62	12.06	1.44	68062.13
12	7.27	9.77	45.18	1.86	19.92	11.73	1.46	70088.00
13	8.84	14.67	40.19	1.69	19.64	11.53	1.42	72750.12
14	8.72	21.68	43.58	1.72	19.16	11.74	1.41	72096.91
15	5.78	12.31	62.49	1.74	18.62	12.58	1.42	68974.86
16	0.52	11.86	80.77	0.96	20.59	11.96	1.49	74072.65
17	1.72	14.64	58.35	0.31	21.76	11.25	1.46	80112.11
18	1.59	6.68	55.32	0.88	20.70	11.16	1.47	74294.25
19	6.79	4.53	42.06	1.47	19.95	11.16	1.46	74749.91
20	6.65	11.08	47.65	4.03	12.54	12.67	1.42	67886.52
21	10.38	3.15	44.50	3.14	14.71	11.90	1.41	72758.94
22	7.42	2.21	48.14	3.69	13.35	12.45	1.41	69621.85
23	7.23	4.31	58.30	3.13	14.13	12.26	1.41	69924.97
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.07	7.18	52.26	1.70	18.84	11.71	1.44	72729.85
最大值	10.38	21.68	80.77	4.03	21.76	12.67	1.57	80112.11
發生時間	21	14	16	20	17	20		17
最小值	0.52	2.21	39.62	0.31	12.54	10.99	1.40	67886.52
發生時間	16	22	11	17	20	9		20
零點偏移(率)	0.00 %	-0.08 %	-0.01 %	-0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	1.08 %	0.57 %	-0.40 %	0.18 %		0.30	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月01日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.64	1.62	64.46	1.24	17.67	10.44	1.43	59993.87
1	3.32	1.92	59.46	0.82	19.49	10.32	1.45	63656.11
2	4.33	2.00	61.85	0.91	19.09	10.33	1.48	66423.71
3	1.87	1.80	67.11	0.89	18.93	10.86	1.49	63244.92
4	3.92	2.65	56.39	0.91	19.18	10.25	1.48	67510.42
5	1.48	3.49	62.08	1.15	17.56	10.85	1.49	64285.71
6	4.19	5.71	60.10	1.61	15.99	10.81	1.49	64389.38
7	1.71	2.41	69.06	1.35	16.85	11.52	1.50	59722.83
8	0.62	0.91	58.43	0.94	18.71	10.42	1.49	63363.06
9	0.46	3.59	50.08	1.41	16.19	10.60	1.43	61923.24
10	2.72	10.79	59.12	1.70	15.14	10.26	1.46	60197.83
11	3.62	5.09	51.64	1.86	14.29	10.17	1.46	60480.15
12	3.77	3.99	48.72	1.51	16.39	9.80	1.42	62242.84
13	3.51	5.90	52.24	1.20	17.49	9.53	1.42	65639.84
14	4.40	1.43	59.39	1.27	17.21	9.70	1.41	63008.03
15	1.33	8.89	61.84	0.75	19.45	9.11	1.40	60089.94
16	1.47	6.87	49.71	0.90	18.72	8.68	1.40	63151.74
17	2.38	8.80	51.55	0.95	18.42	9.13	1.41	62699.25
18	0.79	7.24	47.11	1.09	17.66	9.62	1.45	60538.32
19	3.66	5.94	40.59	1.27	17.68	9.50	1.46	63095.82
20	4.72	10.70	46.05	1.39	17.03	9.84	1.43	62053.87
21	7.19	5.01	44.27	1.33	17.96	9.37	1.43	64043.60
22	8.46	5.35	39.17	1.34	18.13	9.30	1.42	62585.29
23	9.06	5.41	46.23	1.48	17.00	9.89	1.40	59500.65
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.53	4.90	54.44	1.22	17.59	10.01	1.45	62660.02
最大值	9.06	10.79	69.06	1.86	19.49	11.52	1.52	67510.42
發生時間	23	10	7	11	1	7		4
最小值	0.46	0.91	39.17	0.75	14.29	8.68	1.39	59500.65
發生時間	9	8	22	15	11	16		23
零點偏移(率)	-0.16 %	-0.06 %	-0.02 %	0.00 %		-0.06	0.00	0.00 %
全幅偏移(率)	2.77 %	0.30 %	-0.61 %	0.19 %		0.07	-0.06	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月01日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.09	2.08	65.50	0.46	17.78	11.16	1.81	84212.95
1	9.71	3.28	59.78	0.51	18.80	10.70	1.85	87287.47
2	3.83	3.11	67.48	0.55	16.96	11.45	1.85	82586.60
3	3.07	2.05	60.56	0.49	17.50	10.98	1.83	86733.91
4	2.41	2.74	57.50	0.58	16.87	11.37	1.81	83781.44
5	4.02	2.54	58.02	0.59	16.86	10.86	1.81	88246.35
6	6.69	6.08	64.84	1.04	16.62	11.03	1.80	86051.97
7	3.10	1.53	59.27	0.66	18.04	10.39	1.85	82590.46
8	1.69	9.61	57.47	1.00	16.49	11.02	1.88	86546.04
9	1.41	3.86	56.24	0.86	15.93	11.12	1.86	83997.39
10	2.05	3.39	53.19	1.39	14.51	11.05	1.87	83590.67
11	1.48	1.17	61.39	1.45	14.48	11.36	1.88	82609.03
12	1.74	0.93	57.13	1.25	15.09	11.08	1.90	84400.88
13	5.10	1.90	58.25	1.32	15.12	10.94	1.89	84079.65
14	2.51	1.55	56.47	1.21	15.15	10.96	1.88	82357.59
15	4.01	0.68	55.57	0.96	15.79	10.76	1.88	82381.59
16	3.30	4.50	48.70	1.41	15.11	10.63	1.88	81958.61
17	4.92	1.53	59.32	1.24	15.43	11.04	1.89	81792.73
18	5.14	3.81	52.87	1.07	15.56	10.83	1.87	85144.38
19	3.60	1.36	54.33	1.22	14.85	11.16	1.85	82396.01
20	6.97	2.37	55.08	1.10	15.88	10.86	1.85	84614.80
21	12.23	4.37	52.78	1.15	15.37	10.88	1.86	84703.93
22	4.12	2.94	61.27	1.06	15.59	11.12	1.85	84158.17
23	6.73	3.52	60.42	1.01	15.61	11.09	1.85	86614.54
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.33	2.95	58.06	0.98	16.06	10.99	1.86	84284.88
最大值	12.23	9.61	67.48	1.45	18.80	11.45	1.90	88246.35
發生時間	21	8	2	11	1	2		5
最小值	1.41	0.68	48.70	0.46	14.48	10.39	1.80	81792.73
發生時間	9	15	16	0	11	7		17
零點偏移(率)	-0.33 %	-0.06 %	-0.02 %	0.00 %		-0.40	0.00	0.00 %
全幅偏移(率)	3.24 %	0.41 %	-0.41 %	0.27 %		0.08	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								