

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 115年08月12日

報表日期: 115年08月12日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.66	12.82	52.05	2.84	19.43	10.81	1.13	75796.47
1	8.85	12.57	56.07	2.30	20.25	10.68	1.13	76024.12
2	7.43	12.61	55.09	2.01	18.66	10.95	1.13	75449.01
3	9.87	12.94	48.91	2.09	18.22	11.20	1.13	74177.50
4	9.38	12.96	55.52	2.49	18.81	11.17	1.13	74173.71
5	7.12	11.45	52.44	1.76	19.36	10.96	1.16	79470.57
6	9.12	11.83	57.91	2.48	17.79	11.37	1.17	73096.25
7	8.15	11.97	55.49	1.80	19.34	10.83	1.18	75270.21
8	10.72	11.42	56.37	2.05	19.80	10.64	1.17	76769.34
9	10.43	11.66	58.88	3.32	17.94	11.29	1.18	73183.18
10	11.25	11.99	53.45	3.65	17.87	11.44	1.16	72718.34
11	9.20	11.94	57.64	3.66	17.28	11.63	1.16	72074.10
12	10.33	11.97	52.79	3.19	17.87	11.48	1.15	72074.07
13	8.87	12.11	50.21	2.12	19.01	11.40	1.15	71701.07
14	9.99	11.99	61.78	2.16	18.79	11.43	1.15	71499.21
15	9.85	11.91	60.18	2.57	17.75	11.49	1.14	72001.56
16	8.61	12.51	54.53	3.14	16.13	11.98	1.16	69076.24
17	9.63	11.97	54.06	2.10	16.41	11.69	1.17	71472.25
18	10.83	12.10	54.67	1.54	17.21	11.49	1.18	71878.48
19	9.43	13.67	56.73	1.29	18.56	10.94	1.18	74893.48
20	9.23	11.78	57.35	1.45	16.83	11.55	1.18	72126.72
21	9.01	11.76	57.73	1.37	17.02	11.52	1.18	71623.45
22	9.82	11.62	62.71	1.24	18.17	11.25	1.18	72655.52
23	10.57	11.65	48.47	2.42	17.71	11.24	1.18	72655.03
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.47	12.13	55.46	2.29	18.18	11.27	1.16	73410.83
最 大 值	11.25	13.67	62.71	3.66	20.25	11.98	1.18	79470.57
發生時間	10	19	22	11	1	16		5
最 小 值	7.12	11.42	48.47	1.24	16.13	10.64	1.12	69076.24
發生時間	5	8	23	22	16	8		16
零點偏移(率)	-0.02 %	-0.01 %	-0.05 %	0.01 %		-0.01	-0.01	0.20 %
全幅偏移(率)	-1.84 %	0.29 %	0.33 %	0.67 %		-0.26	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年08月12日

[illegible]