

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月02日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.75	3.65	59.98	3.83	12.95	12.71	1.38	67987.54
1	7.96	4.21	58.91	3.74	13.39	12.70	1.39	68200.53
2	7.38	4.10	49.64	3.81	13.69	12.57	1.41	68858.79
3	8.84	5.16	60.04	4.04	13.48	12.48	1.42	69952.75
4	10.46	6.19	59.31	4.35	13.54	12.53	1.43	69371.52
5	7.27	10.78	54.56	4.29	12.78	12.65	1.43	69601.83
6	6.13	3.65	55.56	3.79	13.42	12.44	1.44	70366.31
7	8.05	3.10	57.75	4.15	12.83	12.71	1.44	68802.21
8	9.06	3.87	51.42	4.38	12.67	12.71	1.44	68729.06
9	7.94	3.41	52.95	4.27	13.11	12.67	1.43	68805.74
10	9.72	2.58	58.68	3.79	13.72	12.31	1.43	71683.97
11	7.13	2.95	54.85	3.98	12.82	12.61	1.43	69808.44
12	4.26	3.09	51.94	3.88	12.50	12.70	1.43	68929.38
13	2.47	3.09	55.65	3.57	12.97	12.55	1.44	69636.82
14	1.06	2.93	57.01	3.06	13.58	12.44	1.43	70317.10
15	3.32	3.84	50.90	3.53	13.10	12.48	1.43	70130.57
16	7.60	3.80	57.56	4.02	12.62	12.56	1.43	70077.42
17	11.68	3.01	65.03	3.62	13.69	12.48	1.41	69931.00
18	9.41	3.04	55.41	3.31	13.80	12.36	1.38	71124.73
19	8.74	3.50	51.43	4.00	13.11	12.46	1.36	71048.94
20	3.56	3.66	58.97	3.38	13.37	12.67	1.38	68627.21
21	7.88	5.75	48.65	3.95	12.96	12.60	1.37	69525.08
22	7.34	4.47	57.77	3.83	13.29	12.60	1.38	69260.60
23	2.63	3.68	57.95	3.00	14.16	12.68	1.38	67854.71
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.03	4.06	55.91	3.82	13.23	12.57	1.41	69526.34
最大值	11.68	10.78	65.03	4.38	14.16	12.71	1.46	71683.97
發生時間	17	5	17	8	23	0		10
最小值	1.06	2.58	48.65	3.00	12.50	12.31	1.36	67854.71
發生時間	14	10	21	23	12	10		23
零點偏移(率)	-0.02 %	0.00 %	-0.00 %	-0.01 %		0.00	0.00	0.00 %
全幅偏移(率)	1.45 %	-2.67 %	-0.60 %	-0.58 %		0.47	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月02日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.93	3.41	43.32	2.39	15.80	10.45	1.34	82297.46
1	4.46	3.00	63.88	1.60	18.22	10.70	1.35	81004.00
2	8.01	4.04	50.35	2.32	17.15	10.33	1.37	84337.43
3	9.49	2.36	45.74	3.07	15.86	10.57	1.38	81969.41
4	9.33	3.56	52.13	2.99	16.56	10.15	1.38	86377.27
5	10.38	5.49	58.08	2.84	16.16	10.61	1.40	84855.88
6	9.29	7.87	39.54	2.95	15.06	10.66	1.41	80768.09
7	9.98	2.95	50.30	3.00	15.38	10.61	1.41	84138.65
8	9.87	2.60	48.39	2.76	16.02	10.46	1.41	82783.06
9	9.42	4.24	47.86	2.81	15.26	10.60	1.41	84008.95
10	6.58	3.53	54.38	2.58	14.65	10.84	1.41	81228.61
11	9.96	2.84	55.23	2.56	14.73	10.98	1.41	83121.63
12	6.46	2.46	52.67	1.92	16.37	10.21	1.40	83289.68
13	3.54	3.33	51.75	1.96	15.33	10.48	1.39	82475.18
14	5.10	2.48	61.72	1.86	16.26	10.55	1.38	83430.90
15	3.81	2.92	56.12	1.72	16.57	10.84	1.38	80455.74
16	10.63	2.67	56.20	2.16	16.70	10.28	1.39	87331.33
17	8.88	2.77	64.41	1.89	17.17	10.65	1.38	84508.88
18	8.76	2.76	48.73	1.86	17.12	10.28	1.37	88020.62
19	8.11	3.85	54.60	2.53	16.33	10.84	1.35	83752.56
20	8.10	3.32	52.51	2.25	15.74	10.63	1.34	84297.32
21	7.77	3.05	53.64	2.17	16.26	10.62	1.33	83081.13
22	8.07	3.32	54.07	1.90	17.20	10.69	1.33	82852.74
23	5.43	4.91	53.75	1.56	17.85	10.41	1.33	81446.32
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.97	3.49	52.89	2.32	16.24	10.56	1.38	83409.70
最大值	10.63	7.87	64.41	3.07	18.22	10.98	1.42	88020.62
發生時間	16	6	17	3	1	11		18
最小值	3.54	2.36	39.54	1.56	14.65	10.15	1.33	80455.74
發生時間	13	3	6	23	10	4		15
零點偏移(率)	-0.23 %	-0.08 %	-0.01 %	-0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	2.07 %	-2.93 %	-0.87 %	-1.10 %		0.35	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月02日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.41	2.76	64.66	2.33	14.97	11.29	1.84	81709.65
1	7.06	5.35	60.15	2.59	14.86	11.07	1.82	81030.19
2	4.64	3.24	55.23	2.12	16.21	10.69	1.80	80511.21
3	3.21	2.74	62.56	2.32	14.73	10.89	1.82	82266.56
4	8.77	11.31	51.88	3.78	14.40	10.88	1.82	81878.74
5	5.70	4.38	57.50	3.97	13.79	11.06	1.82	80624.89
6	4.89	5.04	59.78	2.42	14.95	10.91	1.85	81085.25
7	9.27	5.45	55.30	2.38	14.22	10.95	1.84	84173.65
8	5.17	3.18	60.19	2.37	13.51	11.24	1.84	80430.96
9	6.55	2.61	60.61	2.62	13.98	11.09	1.84	80473.34
10	4.72	2.27	59.51	2.49	13.61	11.25	1.83	80159.51
11	1.44	2.29	61.20	1.68	14.49	10.98	1.83	81213.79
12	0.68	2.53	61.67	1.90	14.24	11.20	1.83	81055.89
13	1.78	2.54	64.02	1.77	14.26	11.17	1.84	82241.08
14	2.14	2.74	64.60	1.77	14.64	11.17	1.83	83325.61
15	2.00	6.87	58.79	1.61	14.89	10.95	1.81	84303.04
16	2.11	1.74	67.01	2.47	13.22	11.22	1.83	81341.88
17	2.11	1.21	66.28	1.50	15.76	11.06	1.83	83366.74
18	2.40	1.13	63.27	1.15	16.86	10.52	1.80	88055.37
19	2.21	2.12	60.73	1.42	15.45	10.97	1.80	84755.29
20	4.60	3.77	62.20	1.86	15.55	10.75	1.80	85268.44
21	7.24	3.19	53.15	1.87	15.18	10.90	1.80	82039.93
22	4.63	3.84	55.07	1.60	15.48	10.61	1.80	83856.63
23	2.98	2.62	63.59	1.18	16.99	10.64	1.80	84192.21
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.28	3.54	60.37	2.13	14.84	10.98	1.82	82473.33
最大值	9.27	11.31	67.01	3.97	16.99	11.29	1.85	88055.37
發生時間	7	4	16	5	23	0		18
最小值	0.68	1.13	51.88	1.15	13.22	10.52	1.80	80159.51
發生時間	12	18	4	18	16	18		10
零點偏移(率)	-0.06 %	-0.00 %	-0.03 %	0.00 %		0.05	0.00	0.00 %
全幅偏移(率)	-3.41 %	-0.04 %	-0.04 %	-0.07 %		0.40	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								